

VENTILATION AUDIT REPORT

SCHOOL:	Francis Greenway High School (8439)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Maitland
LOCAL GOVERNMENT AREA:	Maitland

8439 - Francis Greenway High School
Site Plan (12525)













Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Duplicating Workroom - (13.14 SQM)	Office (3)	
B00A - R0006 - Principal Office - (19.92 SQM)	Office (4)	
B00A - R0017 - Staff Study - (36.39 SQM)	Office (9)	
B00A - R0022 - Stage - (24.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - General Learning Space - (52.23 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0024 - General Learning Space - (51.12 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0025 - Music Learning Space - (58.45 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0034 - Clinic - (5.2 SQM)	Office (1)	
B00A - R0036 - Deputy Principal Office - (26.38 SQM)	Office (6)	
B00A - R0040 - Administration - Clerical - (71.1 SQM)	Office (17)	
B00A - R0041 - Public Reception - (12.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Interview/Meeting - (10.8 SQM)	Office (2)	
B00A - R0043 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Student Reception - (18.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Administration - Executive - (26.52 SQM)	Office (6)	
B00A - R0046 - Movement - (7.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0047 - Movement - (22.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0051 - Movement - (171.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (59.55 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1003 - General Learning Space - (52.53 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1004 - General Learning Space - (54.93 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1009 - General Learning Space - (59.18 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1012 - General Learning Space - (52.96 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1015 - Computer Learning Space - (59.47 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1016 - General Learning Space - (52.61 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1017 - General Learning Space - (52.6 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1018 - Movement - (132.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R1021 - Commonroom - (29.86 SQM)	Office (7)	
B00A - R1023 - Computer Room - (75.65 SQM)	Student Space (35)	
B00B - R0002 - Computer Room - (27.75 SQM)	Student Space (12)	
B00B - R0003 - Design L.S. - (59.76 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0006 - Materials Technology L.S. - (112.67 SQM) - Teaching Space: 1	Student Space (52)	
B00B - R0007 - Materials Technology L.S. - (90.83 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0009 - Welding Area - (20.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Design L.S. - Type 8 - (39.32 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R0013 - Movement - (113.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Staff Study - (23.19 SQM)	Office (5)	
B00B - R0020 - Staff Kitchen - (6.51 SQM)	Office (1)	
B00B - R0022 - Staff Lounge - (100.23 SQM)	Office (25)	
B00B - R1005 - Materials Technology L.S. - (59.56 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1008 - Materials Technology L.S. - (81.5 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R1013 - Food Technology L.S. - (80.37 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R1019 - Movement - (95 SQM)	Not Applicable	Circulation or storage space.
B00B - R1022 - Food Technology L.S. - (91.8 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R1025 - Food Technology L.S. - (53.67 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0002 - Fitness Laboratory - (320.86 SQM)	Student Space (148)	
B00C - R0003 - Workshop Area - (43.22 SQM)	Student Space (20)	
B00C - R0006 - Movement - (5.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Movement - (6.52 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0014 - Movement - (27.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Movement - (14.67 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Student Canteen - (37.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Student Canteen - (20.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Movement - (15.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R1009 - Movement - (16.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R1010 - Darkroom Space - (30.05 SQM)	Office (7)	
B00D - R0001 - Laboratory L.S. - (98.31 SQM) - Teaching Space: 1	Student Space (45)	
B00D - R0006 - Laboratory L.S. - (85.26 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0007 - Preparation - (38.45 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Laboratory L.S. - (98.31 SQM) - Teaching Space: 1	Student Space (45)	
B00D - R0011 - Staff Study - (24.47 SQM)	Office (6)	
B00D - R0013 - Laboratory L.S. - (85.26 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0014 - Preparation - (38.45 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Movement - (164.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - General Learning Space - (58.73 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1005 - General Learning Space - (49.7 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1006 - Interview/Office - Type 1 - (12.79 SQM)	Office (3)	
B00D - R1009 - General Learning Space - (50.8 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1010 - General Learning Space - (50.8 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1011 - General Learning Space - (58.73 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1015 - Staff Study - (23.95 SQM)	Office (5)	
B00D - R1018 - Staff Study - (12.78 SQM)	Office (3)	
B00D - R1019 - General Learning Space - (58.72 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1026 - Movement - (156.17 SQM)	Not Applicable	Circulation or storage space.
B00D - R1027 - Movement - (8.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R1028 - General Learning Space - (48.75 SQM) - Teaching Space: 1	Student Space (22)	
B00D - R1033 - Laboratory L.S. - (73.28 SQM) - Teaching Space: 1	Student Space (33)	
B00E - R0005 - Music Learning Space - (59.34 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0006 - General Learning Space - (50.77 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0009 - Computer Learning Space - (59.54 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0021 - Food/Research Space - (16.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Food Technology L.S. - (42.41 SQM) - Teaching Space: 1	Student Space (19)	
B00E - R0025 - General Learning Space - (66.54 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0026 - Commonroom - (32.38 SQM)	Office (8)	
B00E - R0027 - General Learning Space - (52.53 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0029 - Special Learning Space - (44.5 SQM) - Teaching Space: 1	Student Space (20)	
B00E - R0031 - Movement - (111.72 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - General Learning Space - (60.34 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1002 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1004 - Art Learning Space - (60.08 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1005 - Art Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1009 - General Learning Space - (52.6 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1012 - General Learning Space - (59.51 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1013 - General Learning Space - (52.96 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1015 - Interview - (14.47 SQM)	Office (3)	
B00E - R1016 - Movement - (100.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R1019 - General Learning Space - (49.79 SQM) - Teaching Space: 1	Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1023 - Movement - (7.46 SQM)	Not Applicable	Circulation or storage space.
B00F - M0003 - Movement - (35.22 SQM)	Not Applicable	Circulation or storage space.
B00F - M0008 - Multi-Purpose Space - (91.97 SQM)	 Student Space (42)	
B00F - R0011 - Multi-Purpose Space - (481.4 SQM)	 Student Space (223)	
B00F - R0018 - Entry - (24.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Staff Kitchen - (12.57 SQM)	 Office (3)	
B00F - R0021 - Staff Study - (17.54 SQM)	 Office (4)	
B00F - R0032 - Stage - (81.38 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Main Area - (344.2 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Entry - (12.43 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Audio Visual Workroom - (22.93 SQM)	 Student Space (10)	
B00G - R0010 - Seminar - (13.13 SQM)	 Office (3)	
B00G - R0011 - Seminar - (14.26 SQM)	 Office (3)	
B00G - R0012 - Seminar - (14.26 SQM)	 Office (3)	
B00I - R0003 - Movement - (6.71 SQM)	Not Applicable	Circulation or storage space.
B00I - R1004 - Movement - (10.34 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Gymnasium - (33.38 SQM)	 Student Space (15)	
B00L - R0002 - Gymnasium - (68.38 SQM)	 Student Space (31)	