


VENTILATION AUDIT REPORT

SCHOOL:	Freemans Reach Public School (1944)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Hawkesbury
LOCAL GOVERNMENT AREA:	Hawkesbury



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Duplicating Workroom - (20.89 SQM)	Office (5)	
B00A - R0005 - Movement - (38.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (5.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Entry Vestibule - (13.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Clerical Office - (13.59 SQM)	Office (3)	
B00A - R0009 - Sick Bay - (8.28 SQM)	Student Space (3)	
B00A - R0013 - Deputy Principal - (13.63 SQM)	Office (3)	
B00A - R0017 - Staff Room - (34.18 SQM)	Office (8)	
B00A - R0018 - Staff Room Annexe - (12.38 SQM)	Office (3)	
B00A - R0019 - Interview - (13.75 SQM)	Office (3)	
B00A - R0022 - Principal - (15.35 SQM)	Office (3)	
B00A - R0024 - Clerical/Printing - (10.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Clerical Office - (9.94 SQM)	Office (2)	
B00A - R0027 - Movement - (35.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Entry Vestibule - (16.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (106.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Practical Activities - 1hb - (20.4 SQM)	Student Space (9)	
B00B - R0005 - Home Base - (61.35 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0007 - Withdrawal Space - 1hb - (9.15 SQM)	Student Space (4)	
B00B - R0008 - Movement - (9.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Home Base - (60.45 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0010 - Withdrawal Space - 1hb - (9.15 SQM)	Student Space (4)	
B00B - R0012 - Home Base - (60.72 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0015 - Practical Activities - 1hb - (20.35 SQM)	Student Space (9)	
B00B - R0018 - Practical Activities - 1hb - (19.46 SQM)	Student Space (9)	
B00C - R0001 - Movement - (37.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Canteen - (16.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (72.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - 1hb - (20.19 SQM)	Student Space (9)	
B00D - R0003 - Home Base - (60.47 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0004 - Movement - (5.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Withdrawal Space - 1hb - (12.03 SQM)	Student Space (5)	
B00D - R0006 - Movement - (6.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Home Base - (60.64 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0008 - Practical Activities - 1hb - (20.45 SQM)	Student Space (9)	
B00E - R0001 - Movement - (43.28 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (20.35 SQM)	Student Space (9)	
B00E - R0003 - Home Base - (60.48 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0004 - Movement - (5.87 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Withdrawal Space - 1hb - (12.03 SQM)	Student Space (5)	
B00E - R0006 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Home Base - (60.65 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0008 - Practical Activities - 1hb - (20.39 SQM)	Student Space (9)	
B00F - R0003 - Movement - (13.05 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Movement - (11.45 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Communal Space - (145.1 SQM)	Student Space (67)	
B00H - R0006 - Movement - (11.44 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Movement - (43.54 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Movement - (10.98 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Reading Area - (95.31 SQM)	Student Space (44)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0008 - Special Programs Room - (30.88 SQM)	● Student Space (14)	
B00L - R0009 - Movement - (12.15 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Practical Activities - 1hb - (18.95 SQM)	● Student Space (8)	
B00M - R0002 - Practical Activities - 1hb - (18.94 SQM)	● Student Space (8)	
B00M - R0003 - Withdrawal Space - 2hb - (11.54 SQM)	● Student Space (5)	
B00M - R0005 - Home Base - (60.69 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0006 - Home Base - (60.87 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0003 - Special Programs Room - (31.09 SQM)	● Student Space (14)	
B00N - R0006 - Special Programs Room - (31.02 SQM)	● Student Space (14)	