

VENTILATION AUDIT REPORT

SCHOOL:	Gadara School (5674)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Wagga Wagga
LOCAL GOVERNMENT AREA:	Snowy Valleys

5674 - Gadara School
Site Plan (13214)



1:629

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Duplicating Workroom - (11.09 SQM)	Office (2)	
B00A - R0005 - Home Base - (52.55 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0006 - Staff Room - (9.11 SQM)	Office (2)	
B00A - R0008 - Entry Vestibule - (27.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Clerical Office - (9.16 SQM)	Office (2)	
B00A - R0018 - Clerical Office - (21.53 SQM)	Office (5)	
B00A - R0019 - Sick Bay - (10.52 SQM)	Student Space (4)	
B00A - R0020 - Movement - (11.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Principal - (12.95 SQM)	Office (3)	
B00A - R0022 - Interview - (9.42 SQM)	Office (2)	
B00A - R0025 - Staff Room - (53.42 SQM)	Office (13)	
B00C - R0008 - Home Base - M - (72.27 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R0009 - Home Base - M - (68.98 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R0011 - Home Base - M - (60.74 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0020 - Movement - (17.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Movement - (48.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Movement - (10.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (87.13 SQM) - Teaching Space: 1	Student Space (40)	
B00D - R0003 - Staff Room - (30.92 SQM)	Office (7)	
B00D - R0006 - Movement - (33.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (46.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Home Base/Practical Activities - E - (60.74 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0012 - Movement - (27.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Home Base - E - (17.87 SQM) - Teaching Space: 1	Student Space (8)	
B00E - R0014 - Home Base - E - (24.27 SQM) - Teaching Space: 1	Student Space (11)	
B00E - R0015 - Home Base - E - (21.05 SQM) - Teaching Space: 1	Student Space (9)	
B00E - R0016 - Home Base - E - (17.31 SQM) - Teaching Space: 1	Student Space (8)	