

VENTILATION AUDIT REPORT

SCHOOL:	Galston High School (8481)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Hornsby
LOCAL GOVERNMENT AREA:	Hornsby

8481 - Galston High School
Site Plan (10383)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0001 - Entry - (9.39 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (40.48 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Tiered Learning Area - (21.05 SQM)	● Student Space (9)	
B00G - R0008 - Main Area - (99.53 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Clinic - Boys - (8.35 SQM)	● Office (2)	
B00G - R0013 - Clinic - Girls - (8.27 SQM)	● Office (2)	
B00G - R0017 - Movement - (38.29 SQM)	Not Applicable	Circulation or storage space.
B00G - R1002 - Shared Learning Space - (106.25 SQM)	● Student Space (49)	
B00G - R1003 - Seminar - (17.8 SQM)	● Office (4)	
B00G - R1004 - Seminar - (17.77 SQM)	● Office (4)	
B00G - R1005 - Seminar - (17.62 SQM)	● Office (4)	
B00G - R1006 - Seminar - (18.54 SQM)	● Office (4)	
B00G - R1007 - Main Area - (112.16 SQM)	Not Applicable	Circulation or storage space.
B00G - R1011 - Movement - (23.75 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - General Assistants - (44.94 SQM)	● Office (11)	
B00O - R0001 - Growing/Breeding - (53.25 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0003 - Administration - Clerical - (22.23 SQM)	● Office (5)	
BOAM - R0005 - Ancillary Staff - (23.58 SQM)	● Office (5)	
BOAM - R0010 - Interview/Meeting - (13.36 SQM)	● Office (3)	
BOAM - R0011 - General Assistants - (13.44 SQM)	● Office (3)	
BOAM - R0012 - General Learning Space - (95.85 SQM) - Teaching Space: 1	● Student Space (44)	
BOAM - R0016 - Interview/Office - Type 1 - (13.01 SQM)	● Office (3)	
BOAM - R0017 - Interview/Office - Type 1 - (12.01 SQM)	● Office (3)	
BOAM - R0018 - Interview/Office - Type 1 - (12.32 SQM)	● Office (3)	
BOAM - R0026 - Principal Office - (22.01 SQM)	● Office (5)	
BOAM - R0033 - Movement - (46.01 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0042 - Administration - Clerical - (46.95 SQM)	● Office (11)	
BOAM - R0043 - Entry - (11.5 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0044 - Movement - (12.23 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0045 - Movement - (41.85 SQM)	Not Applicable	Circulation or storage space.
BOAM - R0055 - Isolation Space - (10.21 SQM)	● Office (2)	
BOAM - R0056 - Staff Lounge - (103.88 SQM)	● Office (25)	
BOAM - R0057 - Staff Kitchen - (22.75 SQM)	● Office (5)	
BOAM - R1001 - Administration - Executive - (12.61 SQM)	● Office (3)	
BOAM - R1002 - Administration - Executive - (16.73 SQM)	● Office (4)	
BOAM - R1004 - Deputy Principal Office - (16.29 SQM)	● Office (4)	
BOAM - R1005 - Clinic - (12.61 SQM)	● Office (3)	
BOAM - R1011 - General Learning Space - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
BOAM - R1012 - General Learning Space - (64.32 SQM) - Teaching Space: 1	● Student Space (29)	
BOAM - R1013 - General Learning Space - (64.25 SQM) - Teaching Space: 1	● Student Space (29)	
BOAM - R1014 - General Learning Space - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
BOAM - R1015 - General Learning Space - (52.95 SQM) - Teaching Space: 1	● Student Space (24)	
BOAM - R1016 - General Learning Space - (52.31 SQM) - Teaching Space: 1	● Student Space (24)	
BOAM - R1017 - General Learning Space - (52.66 SQM) - Teaching Space: 1	● Student Space (24)	
BOAM - R1018 - Staff Study - (27.34 SQM)	● Office (6)	
BOAM - R1020 - Movement - (74.27 SQM)	Not Applicable	Circulation or storage space.
BOAM - R1021 - Movement - (58.79 SQM)	Not Applicable	Circulation or storage space.
BOAM - R1022 - Movement - (21.27 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0001 - Art Learning Space - (60.5 SQM) - Teaching Space: 1	● Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOC1 - R0003 - Art Learning Space - (61.3 SQM) - Teaching Space: 1	Student Space (28)	
BOC1 - R0004 - Staff Study - (21.52 SQM)	Office (5)	
BOC1 - R0005 - Visual Arts Workshop - (11.34 SQM)	Student Space (5)	
BOC1 - R1001 - Textiles Technology L.S. - (69.68 SQM) - Teaching Space: 1	Student Space (32)	
BOC1 - R1005 - Textiles Technology L.S. - (69.62 SQM) - Teaching Space: 1	Student Space (32)	
BOC1 - R1006 - Staff Study - (20.42 SQM)	Office (5)	
BOC1 - R1007 - Tea Room - (13.6 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R0001 - Art Learning Space - (67.43 SQM) - Teaching Space: 1	Student Space (31)	
BOC2 - R0003 - Wood Technology Bay - (31.64 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R0005 - Wood Technology Bay - (6.48 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R0006 - Wood Technology Bay - (5.93 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R0008 - Wood Technology L.S. - (79.19 SQM) - Teaching Space: 1	Student Space (36)	
BOC2 - R0011 - Wood Technology L.S. - (98.3 SQM) - Teaching Space: 1	Student Space (45)	
BOC2 - R1003 - Computer Learning Space - (31.83 SQM) - Teaching Space: 1	Student Space (14)	
BOC2 - R1005 - Food Technology L.S. - (96.42 SQM) - Teaching Space: 1	Student Space (44)	
BOC2 - R1007 - Preparation - Materials - (16.76 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R1009 - Food Technology L.S. - (94.28 SQM) - Teaching Space: 1	Student Space (43)	
BOC3 - R0003 - Metal Technology L.S. - (101.63 SQM) - Teaching Space: 1	Student Space (47)	
BOC3 - R0005 - Design/Technology L.S. - (73.45 SQM) - Teaching Space: 1	Student Space (34)	
BOC3 - R0010 - General Assistants - (13.08 SQM)	Office (3)	
BOC3 - R0012 - Welding Area - (5.5 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1001 - Computer Learning Space - (66.53 SQM) - Teaching Space: 1	Student Space (30)	
BOC3 - R1003 - Computer Learning Space - (66.44 SQM) - Teaching Space: 1	Student Space (30)	
BOC3 - R1004 - Movement - (7.55 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1008 - Staff Study - (52.18 SQM)	Office (13)	
BOEL - R0001 - General Learning Space - (54.12 SQM) - Teaching Space: 1	Student Space (25)	
BOEL - R0002 - General Learning Space - (52.73 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R0008 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R0009 - General Learning Space - (67.29 SQM) - Teaching Space: 1	Student Space (31)	
BOEL - R0010 - General Learning Space - (51.13 SQM) - Teaching Space: 1	Student Space (23)	
BOEL - R0011 - General Learning Space - (53.9 SQM) - Teaching Space: 1	Student Space (25)	
BOEL - R0013 - General Learning Space - (54.27 SQM) - Teaching Space: 1	Student Space (25)	
BOEL - R0019 - Staff Study - (53.66 SQM)	Office (13)	
BOEL - R1001 - General Learning Space - (53.24 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R1002 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R1006 - Staff Study - (48.01 SQM)	Office (12)	
BOEL - R1008 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R1009 - General Learning Space - (66.47 SQM) - Teaching Space: 1	Student Space (30)	
BOEL - R1010 - General Learning Space - (51.02 SQM) - Teaching Space: 1	Student Space (23)	
BOEL - R1011 - General Learning Space - (53.39 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R1012 - Art Learning Space - (53.46 SQM) - Teaching Space: 1	Student Space (24)	
BOEL - R1013 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
BOHC - R0001 - General Learning Space - (57.52 SQM) - Teaching Space: 1	Student Space (26)	
BOHC - R0003 - General Learning Space - (54.31 SQM) - Teaching Space: 1	Student Space (25)	
BOHC - R0004 - General Learning Space - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
BOHC - R0005 - Staff Study - (22.85 SQM)	Office (5)	
BOHC - R0010 - General Learning Space - (51.94 SQM) - Teaching Space: 1	Student Space (24)	
BOHC - R0011 - General Learning Space - (51.72 SQM) - Teaching Space: 1	Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0HC - R1001 - General Learning Space - (56.79 SQM) - Teaching Space: 1	● Student Space (26)	
B0HC - R1003 - General Learning Space - (53.82 SQM) - Teaching Space: 1	● Student Space (24)	
B0HC - R1004 - General Learning Space - (51.79 SQM) - Teaching Space: 1	● Student Space (24)	
B0HC - R1005 - Staff Study - (22.88 SQM)	● Office (5)	
B0HC - R1010 - General Learning Space - (72.99 SQM) - Teaching Space: 1	● Student Space (33)	
B0HC - R1011 - General Learning Space - (51.87 SQM) - Teaching Space: 1	● Student Space (24)	
B0S1 - R0003 - Staff Study - (23.1 SQM)	● Office (5)	
B0S2 - R0001 - Laboratory L.S. - (94.09 SQM) - Teaching Space: 1	● Student Space (43)	
B0S2 - R0004 - Preparation - Science - (12.68 SQM)	Not Applicable	Circulation or storage space.
B0S2 - R0006 - Laboratory L.S. - (94.17 SQM) - Teaching Space: 1	● Student Space (43)	
B0S2 - R1001 - Laboratory L.S. - (92.98 SQM) - Teaching Space: 1	● Student Space (43)	
B0S2 - R1002 - Preparation - Science - (32.57 SQM)	Not Applicable	Circulation or storage space.
B0S2 - R1006 - Laboratory L.S. - (92.98 SQM) - Teaching Space: 1	● Student Space (43)	
B0S3 - R0001 - Laboratory L.S. - (94.08 SQM) - Teaching Space: 1	● Student Space (43)	
B0S3 - R0006 - Laboratory L.S. - (94.45 SQM) - Teaching Space: 1	● Student Space (43)	
B0S3 - R0009 - Preparation - (52.17 SQM)	Not Applicable	Circulation or storage space.
B0S3 - R1001 - Laboratory L.S. - (92.88 SQM) - Teaching Space: 1	● Student Space (43)	
B0S3 - R1002 - Preparation - Science - (36.08 SQM)	Not Applicable	Circulation or storage space.
B0S3 - R1006 - Staff Study - (14.18 SQM)	● Office (3)	
B0S3 - R1007 - Laboratory L.S. - (93.18 SQM) - Teaching Space: 1	● Student Space (43)	
B0SC - R0001 - Performance Workshop - (101.81 SQM)	● Student Space (47)	
B0SC - R0002 - Multi-Purpose Space - (456.59 SQM)	● Student Space (211)	
B0SC - R0024 - Student Canteen - (55.95 SQM)	Not Applicable	Circulation or storage space.
B0SC - R1011 - Practice/Seminar - (13.23 SQM)	Not Applicable	Circulation or storage space.
B0SC - R1013 - Music Learning Space - (73.61 SQM) - Teaching Space: 1	● Student Space (34)	
B0SC - R1021 - Music Learning Space - (76.7 SQM) - Teaching Space: 1	● Student Space (35)	
B0SC - R1022 - Practice/Seminar - (10.5 SQM)	Not Applicable	Circulation or storage space.
B0SC - R1025 - Dark Room - (22.53 SQM)	● Office (5)	