


VENTILATION AUDIT REPORT

SCHOOL:	Galston Public School (1952)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Hornsby
LOCAL GOVERNMENT AREA:	Hornsby

1952 - Galston Public School
Site Plan (12669)



1:781

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Canteen - (44.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Canteen - (11.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Entry Vestibule - (10.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Withdrawal Space - 1hb - (26.29 SQM)	● Student Space (12)	
B00B - R0001 - Special Programs Room - (44.66 SQM)	● Student Space (20)	
B00C - R0001 - Movement - (33.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Home Base - (56.77 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0006 - Home Base - (56.77 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0002 - Movement - (37.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (62.31 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0001 - Movement - (35.45 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Movement - (8.85 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Movement - (39.81 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Home Base - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0007 - Home Base - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0008 - Withdrawal Space - 1hb - (9.31 SQM)	● Student Space (4)	
B00F - R0009 - Withdrawal Space - 1hb - (12.48 SQM)	● Student Space (5)	
B00F - R0010 - Home Base - (52.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0011 - Home Base - (53.75 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0012 - Practical Activities - 1hb - (22.22 SQM)	● Student Space (10)	
B00G - R0001 - Movement - (14.19 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (14.19 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Reading Area - (158.75 SQM)	● Student Space (73)	
B00G - R0006 - Special Programs Room - (42.75 SQM)	● Student Space (19)	
B00G - R0007 - Movement - (75.48 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (8.94 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Staff Room Annexe - (15.61 SQM)	● Office (3)	
B00J - R0004 - Staff Kitchen - (13.33 SQM)	● Office (3)	
B00J - R0005 - Duplicating Workroom - (11.16 SQM)	● Office (2)	
B00J - R0006 - Clerical Office/Workroom - (11.17 SQM)	● Office (2)	
B00J - R0007 - Principal - (13.4 SQM)	● Office (3)	
B00J - R0008 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Movement - (7.74 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Clerical Office/Workroom - (15.58 SQM)	● Office (3)	
B00J - R0011 - Staff Room - (20.59 SQM)	● Office (5)	
B00K - R0004 - Movement - (5.01 SQM)	Not Applicable	Circulation or storage space.
B00W - R0001 - Movement - (17.83 SQM)	Not Applicable	Circulation or storage space.
B00X - R0002 - Communal Space - (142.01 SQM)	● Student Space (65)	
B00X - R0003 - Raised Platform - (62.04 SQM)	Not Applicable	Circulation or storage space.
B00X - R0016 - Movement - (12.77 SQM)	Not Applicable	Circulation or storage space.
B00X - R0017 - Movement - (5.57 SQM)	Not Applicable	Circulation or storage space.
OS 602 11297 - OS 602 11297 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11639 - OS 602 11639 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14097 - OS 602 14097 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 13449 - OS 603 13449 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	