

VENTILATION AUDIT REPORT

SCHOOL:	Gardeners Road Public School (7418)
AMU REGION:	Sydney
STATE ELECTORATE:	Heffron
LOCAL GOVERNMENT AREA:	Sydney

7418 - Gardeners Road Public School
Site Plan (11547)



1:1,159

Printed: 01-May-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0002 - Movement - (4.07 SQM)	Not Applicable	Circulation or storage space.
B00A - M0003 - Movement - (5.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0001 - Movement - (29.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Canteen - (24.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Home Base - M - (62.05 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0005 - Movement - (126.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Practical Activities - 1hb - (13.15 SQM)	● Student Space (6)	
B00A - R0007 - Movement - (6.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Home Base - (52.17 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0010 - Movement - (5.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Communal Space - (137.32 SQM)	● Student Space (63)	
B00A - R0013 - Raised Platform - (21.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Clerical Office/Workroom - (48.65 SQM)	○ Office (12)	
B00A - R0017 - Principal - (17.39 SQM)	○ Office (4)	
B00A - R0018 - Movement - (8.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (33.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Interview - (13.02 SQM)	○ Office (3)	
B00A - R0021 - Entry Vestibule - (17.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Home Base - (52.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0024 - Home Base - (54 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0025 - Movement - (1.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Duplicating Workroom - (43.92 SQM)	○ Office (10)	
B00A - R1002 - Interview - (10.05 SQM)	○ Office (2)	
B00A - R1003 - Movement - (0.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Movement - (111.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R1005 - Home Base - (62.06 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R1006 - Practical Activities - 1hb - (13.14 SQM)	● Student Space (6)	
B00A - R1008 - Home Base - (54.61 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1009 - Movement - (15.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Home Base - (52.12 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1011 - Home Base - (54.02 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1012 - Home Base - (52.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1013 - Home Base - (47.59 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1014 - Home Base - (47.28 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1015 - Movement - (35.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Deputy Principal - (14.22 SQM)	○ Office (3)	
B00A - R1018 - Home Base - (52.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1019 - Home Base - (54.11 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0004 - Home Base - (73.88 SQM) - Teaching Space: 1	● Student Space (34)	
B00B - R0005 - Practical Activities - 1hb - (19.26 SQM)	● Student Space (8)	
B00B - R0006 - Movement - (22.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Home Base - (60.11 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0012 - Sick Bay - (7.37 SQM)	● Student Space (3)	
B00B - R0013 - Home Base - (80.93 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R0014 - Practical Activities - 1hb - (11.52 SQM)	● Student Space (5)	
B00B - R1006 - Movement - (12.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Home Base - (96.89 SQM) - Teaching Space: 1	● Student Space (44)	
B00B - R1016 - Home Base - (96.37 SQM) - Teaching Space: 1	● Student Space (44)	
B00C - R0001 - Home Base - M - (47.44 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R0004 - Movement - (30.85 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0006 - Staff Room - (38.76 SQM)	Office (9)	
B00C - R0008 - Staff Room Annexe - (22.4 SQM)	Office (5)	
B00C - R0009 - Movement - (15.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Communal Space - (156.46 SQM)	Student Space (72)	
B00C - R0011 - Home Base - (47.08 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0012 - Home Base - (46.83 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0013 - Movement - (15.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (4.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (4.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Home Base - (47.37 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0018 - Home Base - (47.26 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0019 - Movement - (48.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Home Base - M - (47.24 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0022 - Practical Activities - M - 1hb - (47.18 SQM)	Student Space (21)	
B00D - R0002 - Movement - (13.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (13.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (18.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Movement - (4.48 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Movement - (4.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Movement - (2.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Reading Area - (93.95 SQM)	Student Space (43)	
B00D - R0018 - Reading Area - (48.66 SQM)	Student Space (22)	
B00D - R1001 - Home Base - (46 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R1002 - Practical Activities - 1hb - (12.6 SQM)	Student Space (5)	
B00D - R1005 - Movement - (2.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R1006 - Movement - (6.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (16.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Communal Space - (145.2 SQM)	Student Space (67)	
B00F - R0002 - Raised Platform - (60.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Movement - (12.43 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Movement - (13 SQM)	Not Applicable	Circulation or storage space.