


VENTILATION AUDIT REPORT














SCHOOL:	George Bass School (5767)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Bankstown
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (19.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical/Printing - (26.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Sick Bay - (7.29 SQM)	● Student Space (3)	
B00A - R0009 - Staff Room - (36.34 SQM)	● Office (9)	
B00A - R0010 - Staff Room Annexe - (23.37 SQM)	● Office (5)	
B00A - R0014 - Staff Room - (11.77 SQM)	● Office (2)	
B00A - R0017 - Interview - (12.6 SQM)	● Office (3)	
B00A - R0018 - Interview - (16.45 SQM)	● Office (4)	
B00A - R0019 - Interview - (12.53 SQM)	● Office (3)	
B00A - R0020 - Principal - (16.16 SQM)	● Office (4)	
B00A - R0021 - Movement - (62.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Clerical/Printing - (27.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Staff Kitchen - (10.89 SQM)	● Office (2)	
B00B - R0003 - Staff Kitchen - (29.22 SQM)	● Office (7)	
B00B - R0004 - Special Programs Room - (28.92 SQM)	● Student Space (13)	
B00B - R0014 - Interview - (18.65 SQM)	● Office (4)	
B00C - R0001 - Practical Activities - S - 1hb - (21.68 SQM)	● Student Space (10)	
B00C - R0002 - Home Base - S - (59.4 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0005 - Withdrawal Space - 1hb - (9.71 SQM)	● Student Space (4)	
B00C - R0006 - Breakout Area - (17.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Practical Activities - S - 1hb - (21.7 SQM)	● Student Space (10)	
B00C - R0011 - Home Base - S - (59.43 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0014 - Withdrawal Space - 1hb - (9.7 SQM)	● Student Space (4)	
B00C - R0015 - Breakout Area - (17.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Withdrawal Space - 1hb - (9.62 SQM)	● Student Space (4)	
B00C - R0019 - Breakout Area - (17.7 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Practical Activities - S - 1hb - (21.52 SQM)	● Student Space (9)	
B00C - R0021 - Home Base - S - (59.59 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0025 - Practical Activities - S - 1hb - (21.52 SQM)	● Student Space (9)	
B00C - R0026 - Home Base - S - (59.57 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0028 - Withdrawal Space - 1hb - (9.75 SQM)	● Student Space (4)	
B00C - R0029 - Breakout Area - (17.62 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - S - (59.1 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0002 - Practical Activities - S - 1hb - (21.9 SQM)	● Student Space (10)	
B00D - R0005 - Withdrawal Space - 1hb - (9.72 SQM)	● Student Space (4)	
B00D - R0006 - Breakout Area - (18.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Home Base - S - (58.99 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0011 - Practical Activities - S - 1hb - (21.93 SQM)	● Student Space (10)	
B00D - R0012 - Withdrawal Space - 1hb - (9.73 SQM)	● Student Space (4)	
B00D - R0013 - Breakout Area - (19.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Practical Activities - S - 1hb - (21.94 SQM)	● Student Space (10)	
B00E - R0002 - Home Base - S - (59.26 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0005 - Withdrawal Space - 1hb - (9.75 SQM)	● Student Space (4)	
B00E - R0006 - Breakout Area - (17.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Practical Activities - S - 1hb - (21.92 SQM)	● Student Space (10)	
B00E - R0011 - Home Base - S - (58.91 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0014 - Withdrawal Space - 1hb - (9.64 SQM)	● Student Space (4)	
B00E - R0015 - Breakout Area - (17.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Withdrawal Space - 1hb - (9.63 SQM)	● Student Space (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0019 - Breakout Area - (17.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Practical Activities - S - 1hb - (21.86 SQM)	 Student Space (10)	
B00E - R0021 - Home Base - S - (59.16 SQM) - Teaching Space: 1	 Student Space (27)	
B00E - R0025 - Practical Activities - S - 1hb - (21.87 SQM)	 Student Space (10)	
B00E - R0026 - Home Base - S - (59.1 SQM) - Teaching Space: 1	 Student Space (27)	
B00E - R0028 - Withdrawal Space - 1hb - (9.73 SQM)	 Student Space (4)	
B00E - R0029 - Breakout Area - (18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (7.85 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Isolation Space - (17.31 SQM)	 Office (4)	
B00F - R0004 - Hydrotherapy - Pool - (200.82 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Movement - (6.71 SQM)	Not Applicable	Circulation or storage space.
OS 602 17959 - OS 602 17959 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 621 12349 - OS 621 12349 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	
OS 621 14743 - OS 621 14743 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	
OS 621 15032 - OS 621 15032 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	
OS 621 15594 - OS 621 15594 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	
OS 621 16026 - OS 621 16026 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	
OS 621 16029 - OS 621 16029 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	