

VENTILATION AUDIT REPORT

SCHOOL:	Georges Hall Public School (3702)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	East Hills
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

3702 - Georges Hall Public School
Site Plan (11899)



1:1,014











Printed: 29-May-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Deputy Principal - (13.76 SQM)	Office (3)	
B00A - R0002 - Interview - (10.32 SQM)	Office (2)	
B00A - R0003 - Principal - (22.79 SQM)	Office (5)	
B00A - R0004 - Clerical Office - (13.33 SQM)	Office (3)	
B00A - R0005 - Entry Vestibule - (14.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Deputy Principal - (13.28 SQM)	Office (3)	
B00A - R0007 - Sick Bay - (12.83 SQM)	Student Space (5)	
B00A - R0008 - Interview - (13.12 SQM)	Office (3)	
B00A - R0014 - Staff Room - (106.59 SQM)	Office (26)	
B00A - R0018 - Movement - (25.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (19.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (28.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Movement - (11.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Reading Area - (253.58 SQM)	Student Space (117)	
B00A - R1012 - Movement - (28.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Communal Space - (271.56 SQM)	Student Space (125)	
B00B - R0004 - Movement - (7.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Canteen - (42.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Raised Platform - (49.48 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (14.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Movement - (98.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Movement - (13.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Practical Activities - 1hb - (14.16 SQM)	Student Space (6)	
B00C - R0006 - Home Base - (76.5 SQM) - Teaching Space: 1	Student Space (35)	
B00C - R0007 - Movement - (16.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (76.11 SQM) - Teaching Space: 1	Student Space (35)	
B00C - R0009 - Practical Activities - 1hb - (14.16 SQM)	Student Space (6)	
B00D - R0003 - Movement - (11.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Home Base - (53.42 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0008 - Practical Activities - (12.72 SQM)	Student Space (5)	
B00D - R0009 - Practical Activities - (53.26 SQM)	Student Space (24)	
B00D - R0011 - Practical Activities - (12.72 SQM)	Student Space (5)	
B00D - R1003 - Movement - (11.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R1005 - Home Base - (53.42 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1007 - Practical Activities - (12.72 SQM)	Student Space (5)	
B00D - R1008 - Special Programs Room - (66.26 SQM)	Student Space (30)	
B00E - R0006 - Movement - (20.25 SQM)	Not Applicable	Circulation or storage space.
B00E - R1006 - Movement - (20.25 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (31.79 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (23.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R1003 - Movement - (30.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R1005 - Practical Activities - (12.72 SQM)	Student Space (5)	
B00F - R1007 - Home Base - (52.46 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0010 - Movement - (67.45 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Practical Activities - (12.72 SQM)	Student Space (5)	
B00G - R0013 - Home Base - (53.15 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0014 - Home Base - (50.67 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0016 - Practical Activities - (12.52 SQM)	Student Space (5)	
B00G - R0017 - Practical Activities - (12.52 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0019 - Home Base - (51.22 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R0020 - Home Base - (52.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0021 - Practical Activities - (12.72 SQM)	● Student Space (5)	
B00G - R1010 - Movement - (67.45 SQM)	Not Applicable	Circulation or storage space.
B00G - R1011 - Practical Activities - (12.72 SQM)	● Student Space (5)	
B00G - R1013 - Home Base - (53.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1014 - Home Base - (50.67 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R1016 - Practical Activities - (12.52 SQM)	● Student Space (5)	
B00G - R1017 - Practical Activities - (12.52 SQM)	● Student Space (5)	
B00G - R1019 - Home Base - (51.22 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R1020 - Home Base - (52.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R1021 - Practical Activities - (12.72 SQM)	● Student Space (5)	
B00H - R0011 - Movement - (81.47 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Practical Activities - (12.72 SQM)	● Student Space (5)	
B00H - R0016 - Home Base - (51.7 SQM) - Teaching Space: 1	● Student Space (23)	
B00H - R0017 - Home Base - (51.53 SQM) - Teaching Space: 1	● Student Space (23)	
B00H - R0018 - Practical Activities - (12.72 SQM)	● Student Space (5)	
B00H - R1011 - Movement - (81.64 SQM)	Not Applicable	Circulation or storage space.
B00H - R1013 - Practical Activities - (12.72 SQM)	● Student Space (5)	
B00H - R1015 - Home Base - (52.37 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R1016 - Home Base - (52.34 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R1017 - Practical Activities - (12.72 SQM)	● Student Space (5)	
B00I - R0001 - Movement - (38.47 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Practical Activities - 1hb - (19.39 SQM)	● Student Space (8)	
B00I - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00I - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00J - R0001 - Practical Activities - 1hb - (13.87 SQM)	● Student Space (6)	
B00J - R0003 - Home Base - (87.83 SQM) - Teaching Space: 1	● Student Space (40)	
B00J - R0004 - Home Base - (87.83 SQM) - Teaching Space: 1	● Student Space (40)	
B00J - R0005 - Practical Activities - 1hb - (13.87 SQM)	● Student Space (6)	
B00J - R0008 - Movement - (71 SQM)	Not Applicable	Circulation or storage space.
B00J - R1007 - Movement - (72.54 SQM)	Not Applicable	Circulation or storage space.
B00J - R1010 - Practical Activities - (12.72 SQM)	● Student Space (5)	
B00J - R1012 - Home Base - (53.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R1013 - Practical Activities - (12.72 SQM)	● Student Space (5)	
B00J - R1015 - Home Base - (51.98 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R1016 - Home Base - (49.91 SQM) - Teaching Space: 1	● Student Space (23)	
B00J - R1017 - Practical Activities - (12.72 SQM)	● Student Space (5)	
B00K - R0001 - Deputy Principal - (10.85 SQM)	● Office (2)	
B00L - R0003 - Movement - (42.02 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Duplicating Workroom - (31.2 SQM)	● Office (7)	
B00L - R0007 - Practical Activities - (15.6 SQM)	● Student Space (7)	
B00L - R0009 - Home Base - (50.56 SQM) - Teaching Space: 1	● Student Space (23)	
B00L - R0010 - Home Base - (52.12 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R0012 - Practical Activities - (12.84 SQM)	● Student Space (5)	
B00L - R1003 - Movement - (41.93 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R1007 - Practical Activities - (15.6 SQM)	 Student Space (7)	
B00L - R1009 - Home Base - (50.56 SQM) - Teaching Space: 1	 Student Space (23)	
B00L - R1010 - Home Base - (52.12 SQM) - Teaching Space: 1	 Student Space (24)	
B00L - R1012 - Practical Activities - (12.84 SQM)	 Student Space (5)	
OS 602 10046 - OS 602 10046 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 11757 - OS 602 11757 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 11808 - OS 602 11808 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 11977 - OS 602 11977 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 10177 - OS 603 10177 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 14915 - OS 603 14915 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	