

VENTILATION AUDIT REPORT

SCHOOL:	Georges River College Penshurst Girls Campus (8857)
AMU REGION:	Sydney
STATE ELECTORATE:	Oatley
LOCAL GOVERNMENT AREA:	Georges River

8857 - Georges River College Penshurst Girls Campus
Site Plan (10754)



1.915















Printed: 07-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Administration - Clerical - (33.62 SQM)	Office (8)	
B00A - R0003 - Public Entry - (72.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Principal Office - (25.92 SQM)	Office (6)	
B00A - R0008 - General Learning Space - (51.34 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0009 - General Learning Space - (51.32 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0023 - Commonroom - (91.21 SQM)	Office (22)	
B00A - R0026 - General Learning Space - (49.94 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0027 - Clinic - Girls - (19.15 SQM)	Office (4)	
B00A - R0029 - Interview/Office - Type 1 - (13.98 SQM)	Office (3)	
B00A - R0030 - Deputy Principal Office - (16.82 SQM)	Office (4)	
B00A - R0031 - Movement - (27.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Movement - (33.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Movement - (134.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Movement - (19.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Interview/Office - Type 1 - (12.46 SQM)	Office (3)	
B00A - R0038 - Textiles Technology L.S. - (81.62 SQM) - Teaching Space: 1	Student Space (37)	
B00A - R0040 - Food Technology L.S. - (93.86 SQM) - Teaching Space: 1	Student Space (43)	
B00A - R0041 - Food/Research Space - (26.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Food Technology L.S. - (99.29 SQM) - Teaching Space: 1	Student Space (46)	
B00A - R0048 - Clinic - (14.45 SQM)	Office (3)	
B00A - R1002 - Administration - Clerical - (24.8 SQM)	Office (6)	
B00A - R1010 - Seminar - Type 1 - (25.92 SQM)	Office (6)	
B00A - R1012 - Staff Study - (11.99 SQM)	Office (2)	
B00A - R1014 - Staff Study - (13.28 SQM)	Office (3)	
B00A - R1016 - Movement - (7.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - General Learning Space - (51.32 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1018 - General Learning Space - (51.55 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1020 - Seminar - Type 1 - (19.21 SQM)	Office (4)	
B00A - R1023 - Leading Teacher - (10.71 SQM)	Office (2)	
B00A - R1024 - General Learning Space - (70.55 SQM) - Teaching Space: 1	Student Space (32)	
B00A - R1026 - Computer Learning Space - (52.68 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1033 - Commonroom - (7.31 SQM)	Office (1)	
B00A - R1036 - Design L.S. - (57.82 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1039 - Design L.S. - (56.28 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1042 - Computer Learning Space - (60.09 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1044 - Movement - (182.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R1045 - Movement - (20.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R1047 - Staff Study - (32.03 SQM)	Office (8)	
B00B - R0002 - Student Canteen - (7.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Gymnasium - (22.99 SQM)	Student Space (10)	
B00B - R0008 - Movement - (17.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Senior Study - (93.51 SQM)	Office (23)	
B00B - R0015 - Movement - (74.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (16.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Movement - (22.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Student Canteen - (61.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Movement - (284 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - General Learning Space - (49.63 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1005 - General Learning Space - (49.5 SQM) - Teaching Space: 1	Student Space (22)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1006 - General Learning Space - (49.63 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1007 - General Learning Space - (49.7 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1008 - General Learning Space - (49.82 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1009 - General Learning Space - (49.63 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1011 - Staff Study - (41.76 SQM)	○ Office (10)	
B00B - R1013 - Staff Study - (42.53 SQM)	○ Office (10)	
B00B - R1015 - Movement - (141.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R1016 - Movement - (14.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R2004 - General Learning Space - (49.82 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R2005 - General Learning Space - (49.69 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R2006 - General Learning Space - (49.62 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R2007 - General Learning Space - (49.62 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R2008 - General Learning Space - (49.62 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R2009 - General Learning Space - (49.62 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R2010 - Movement - (149.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R2011 - Interview/Office - Type 1 - (14.81 SQM)	○ Office (3)	
B00B - R2012 - Interview/Office - Type 1 - (13.92 SQM)	○ Office (3)	
B00B - R2013 - Staff Study - (35.81 SQM)	○ Office (8)	
B00B - R2015 - Interview/Office - Type 1 - (15.89 SQM)	○ Office (3)	
B00B - R2016 - Staff Study - (14.99 SQM)	○ Office (3)	
B00C - R0003 - Darkroom Space - (25.1 SQM)	○ Office (6)	
B00C - R0005 - Music Learning Space - (52.06 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0007 - Music Learning Space - (91.39 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0009 - Movement - (36.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Movement - (21.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Staff Study - (47.73 SQM)	○ Office (11)	
B00C - R1004 - Art Learning Space - (64.82 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1010 - Art Learning Space - (78.59 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R1011 - Movement - (74.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - General Learning Space - (63.03 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R1016 - Movement - (11.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R9007 - Movement - (6.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R9008 - Art Learning Space - (66.8 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R9010 - General Assistants - (25.42 SQM)	○ Office (6)	
B00C - R9012 - Movement - (67.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Stage - (78.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Movement - (24.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Multi-Purpose Space - (290.16 SQM)	● Student Space (134)	
B00D - R0011 - Movement - (15.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R9004 - Staff Study - (30.72 SQM)	○ Office (7)	
B00D - R9009 - Movement - (17.66 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (16.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement Studio - (120.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Stage - (36.91 SQM)	Not Applicable	Circulation or storage space.
B00F - M1002 - Seminar - (14.89 SQM)	○ Office (3)	
B00F - M1004 - Main Area - (68.23 SQM)	Not Applicable	Circulation or storage space.
B00F - M1005 - Senior Study - (37.33 SQM)	○ Office (9)	
B00F - R0001 - Laboratory L.S. - (91.1 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R0002 - Preparation - (44.68 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0004 - Laboratory L.S. - (91.19 SQM) - Teaching Space: 1	 Student Space (42)	
B00F - R0006 - Staff Study - (41.1 SQM)	 Office (10)	
B00F - R0009 - Laboratory L.S. - (91.19 SQM) - Teaching Space: 1	 Student Space (42)	
B00F - R0010 - Preparation - (44.85 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Laboratory L.S. - (90.82 SQM) - Teaching Space: 1	 Student Space (42)	
B00F - R0015 - Movement - (40.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (54.26 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Laboratory L.S. - (74.92 SQM) - Teaching Space: 1	 Student Space (34)	
B00F - R0022 - Computer Room - (23.48 SQM)	 Student Space (10)	
B00F - R1007 - Seminar - (25.33 SQM)	 Office (6)	
B00F - R1008 - Main Area - (328.36 SQM)	Not Applicable	Circulation or storage space.
B00F - R1009 - Audio Visual Workroom - (28.59 SQM)	 Student Space (13)	
B00F - R1010 - Audio Visual Workroom - (12.86 SQM)	 Student Space (5)	
B00F - R1011 - Workroom - (18.01 SQM)	 Office (4)	
B00F - R1015 - Seminar - (72.03 SQM)	 Office (18)	
B00F - R1016 - Computer Learning Space - (49.17 SQM) - Teaching Space: 1	 Student Space (22)	
B00F - R1017 - General Learning Space - (49.02 SQM) - Teaching Space: 1	 Student Space (22)	
B00F - R1018 - Movement - (51.53 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (10.98 SQM)	Not Applicable	Circulation or storage space.
OS 522 10648 - OS 522 10648 - Staff Study - (38 SQM)	 Office (9)	