

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Gerringong Public School (1971)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Kiama</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Kiama</b>

1971 - Gerringong Public School  
Site Plan (13257)



1:958

Printed: 29-Apr-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Entry Vestibule - (21.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical Office/Workroom - (17.74 SQM)	Office (4)	
B00A - R0003 - Sick Bay - (10.76 SQM)	Student Space (4)	
B00A - R0005 - Special Programs Room - (13.23 SQM)	Student Space (6)	
B00A - R0006 - Staff Room Annexe - (13.08 SQM)	Office (3)	
B00A - R0007 - Staff Room Annexe - (13.11 SQM)	Office (3)	
B00A - R0009 - Staff Room Annexe - (19.47 SQM)	Office (4)	
B00A - R0010 - Staff Room - (45.59 SQM)	Office (11)	
B00A - R0011 - Movement - (33.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Principal - (16.69 SQM)	Office (4)	
B00A - R0017 - Duplicating Workroom - (19.94 SQM)	Office (4)	
B00A - R0019 - Movement - (60.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Canteen - (26.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Raised Platform - (50.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Communal Space - (138.26 SQM)	Student Space (64)	
B00B - R0018 - Special Programs Room - (8.29 SQM)	Student Space (3)	
B00B - R0024 - Movement - (114.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Practical Activities - 1hb - (27.55 SQM)	Student Space (12)	
B00C - R0003 - Withdrawal Space - 1hb - (5.9 SQM)	Student Space (2)	
B00C - R0004 - Home Base - (50.55 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0005 - Practical Activities - 1hb - (27.79 SQM)	Student Space (12)	
B00C - R0007 - Withdrawal Space - 1hb - (5.9 SQM)	Student Space (2)	
B00C - R0008 - Home Base - (51.12 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0009 - Movement - (40.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Practical Activities - 1hb - (27.66 SQM)	Student Space (12)	
B00D - R0003 - Withdrawal Space - 1hb - (5.88 SQM)	Student Space (2)	
B00D - R0004 - Home Base - (50.2 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0005 - Practical Activities - 1hb - (27.17 SQM)	Student Space (12)	
B00D - R0007 - Withdrawal Space - 1hb - (5.88 SQM)	Student Space (2)	
B00D - R0008 - Home Base - (50.56 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0009 - Movement - (144.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (27.06 SQM)	Student Space (12)	
B00E - R0004 - Withdrawal Space - 1hb - (5.88 SQM)	Student Space (2)	
B00E - R0005 - Home Base - (50.34 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0006 - Practical Activities - 1hb - (27.43 SQM)	Student Space (12)	
B00E - R0008 - Withdrawal Space - 1hb - (5.88 SQM)	Student Space (2)	
B00E - R0009 - Home Base - (50.06 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0010 - Movement - (44.23 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Practical Activities - 1hb - (28.26 SQM)	Student Space (13)	
B00F - R0003 - Withdrawal Space - 1hb - (5.79 SQM)	Student Space (2)	
B00F - R0004 - Home Base - (50.83 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0005 - Practical Activities - 1hb - (27.06 SQM)	Student Space (12)	
B00F - R0007 - Withdrawal Space - 1hb - (5.86 SQM)	Student Space (2)	
B00F - R0008 - Home Base - (51.05 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0009 - Movement - (39.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Practical Activities - 1hb - (27.74 SQM)	Student Space (12)	
B00G - R0003 - Withdrawal Space - 1hb - (5.91 SQM)	Student Space (2)	
B00G - R0004 - Home Base - (51.11 SQM) - Teaching Space: 1	Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0005 - Practical Activities - 1hb - (24.8 SQM)	● Student Space (11)	
B00G - R0007 - Withdrawal Space - 1hb - (5.95 SQM)	● Student Space (2)	
B00G - R0008 - Home Base - (46.92 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0013 - Movement - (61.71 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Reading Area - (164.16 SQM)	● Student Space (76)	
B00H - R0009 - Movement - (64.44 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Practical Activities/Movement - 1hb - (19.17 SQM)	● Student Space (8)	
B00I - R0004 - Home Base - (61.06 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0005 - Withdrawal Space - 2hb - (11.71 SQM)	● Student Space (5)	
B00I - R0006 - Home Base - (61.15 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0008 - Practical Activities/Movement - 1hb - (19.16 SQM)	● Student Space (8)	
B00I - R0009 - Movement - (5.31 SQM)	Not Applicable	Circulation or storage space.
B00I - R0012 - Special Programs Room - (32.43 SQM)	● Student Space (15)	
B00I - R0013 - Practical Activities/Movement - 1hb - (19.28 SQM)	● Student Space (8)	
B00I - R0015 - Home Base - (61.38 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0016 - Withdrawal Space - 2hb - (11.71 SQM)	● Student Space (5)	
B00I - R0017 - Home Base - (61 SQM) - Teaching Space: 1	● Student Space (28)	
B00I - R0019 - Practical Activities/Movement - 1hb - (19.16 SQM)	● Student Space (8)	
OS 602 11789 - OS 602 11789 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12177 - OS 602 12177 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12702 - OS 602 12702 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13541 - OS 602 13541 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 17449 - OS 602 17449 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19206 - OS 606 19206 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	