

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Gilgai Public School (1978)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Northern Tablelands</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Inverell</b>

1978 - Gilgai Public School  
Site Plan (12727)



1:839

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Duplicating Workroom - (5.91 SQM)	Office (1)	
B00A - R0002 - Clerical Office - (11.12 SQM)	Office (2)	
B00A - R0003 - Principal - (10.88 SQM)	Office (2)	
B00A - R0004 - Home Base - (53.69 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0005 - Withdrawal Space - 1hb - (16.96 SQM)	Student Space (7)	
B00B - R0002 - Staff Room - (44.36 SQM)	Office (11)	
B00B - R0004 - Home Base - (50.69 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0005 - Withdrawal Space - 1hb - (23.65 SQM)	Student Space (10)	
B00B - R0006 - Staff Room - (15.98 SQM)	Office (3)	
B00B - R0007 - Withdrawal Space - 1hb - (7.74 SQM)	Student Space (3)	
B00C - R0001 - Canteen - (20.91 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Communal Space - (108.04 SQM)	Student Space (50)	
B00H - R0003 - Clerical/Printing - (12.98 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Principal - (12.98 SQM)	Office (3)	
B00H - R0011 - Clerical Office - (10.6 SQM)	Office (2)	
B00H - R0012 - Staff Kitchen - (15.38 SQM)	Office (3)	
B00H - R0013 - Staff Room - (21.11 SQM)	Office (5)	
B00H - R0016 - Movement - (5.54 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Clerical Office/Workroom - (15.89 SQM)	Office (3)	
B00I - R0002 - Reading Area - (58.33 SQM)	Student Space (27)	
OS 531 10677 - OS 531 10677 - Library - (76 SQM)	Student Space (35)	