

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Girraween Public School (1988)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Prospect</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Cumberland</b>

1988 - Girraween Public School  
Site Plan (12729)



1:912

Printed: 12-Jan-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (57.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Home Base - (47.33 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0007 - Home Base - (47.57 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0011 - Interview - (12.56 SQM)	● Office (3)	
B00A - R0016 - Movement - (54.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Special Programs Room - (64.25 SQM)	● Student Space (29)	
B00A - R0020 - Staff Room - (89.55 SQM)	● Office (22)	
B00A - R0021 - Staff Kitchen - (15.73 SQM)	● Office (3)	
B00B - R0003 - Sick Bay - (11.17 SQM)	● Student Space (5)	
B00B - R0006 - Interview - (9.52 SQM)	● Office (2)	
B00B - R0007 - Deputy Principal - (9.66 SQM)	● Office (2)	
B00B - R0008 - Deputy Principal - (10.89 SQM)	● Office (2)	
B00B - R0009 - Principal - (18.44 SQM)	● Office (4)	
B00B - R0010 - Entry Vestibule - (9.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Movement - (11.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (30.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Clerical Office - (11.81 SQM)	● Office (2)	
B00B - R0014 - Duplicating Workroom - (16.92 SQM)	● Office (4)	
B00C - R0001 - Home Base - (56.87 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0004 - Movement - (16.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Interview - (12.96 SQM)	● Office (3)	
B00C - R0009 - Home Base - (56.32 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0010 - Home Base - (56.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0013 - Movement - (7.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Home Base - (56.87 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0021 - Movement - (7.31 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Movement - (7.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Special Programs Room - (41.75 SQM)	● Student Space (19)	
B00D - R0001 - Withdrawal Space - 1hb - (29.13 SQM)	● Student Space (13)	
B00D - R0005 - Home Base - (56.69 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0006 - Home Base - (56.77 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0009 - Home Base - (58.01 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0011 - Movement - (6.45 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Movement - (9.88 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0001 - Withdrawal - S - (12.57 SQM)	● Student Space (5)	
B00F - R0002 - Practical Activity Area - (47.74 SQM)	● Student Space (22)	
B00F - R0005 - Movement - (15.53 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Home Base - (68.87 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R0010 - Home Base - (92.47 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R0013 - Movement - (6.97 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (44.94 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00G - R0004 - Home Base - (59.23 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00G - R0006 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00J - R0004 - Movement - (5.57 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0006 - Home Base - (53.49 SQM) - Teaching Space: 1	Student Space (24)	
B00J - R0007 - Home Base - (53.68 SQM) - Teaching Space: 1	Student Space (24)	
B00K - R0001 - Communal Space - (203.62 SQM)	Student Space (94)	
B00K - R0002 - Raised Platform - (61.94 SQM)	Not Applicable	Circulation or storage space.
B00K - R0014 - Canteen - (43.83 SQM)	Not Applicable	Circulation or storage space.
B00K - R0018 - Movement - (5.66 SQM)	Not Applicable	Circulation or storage space.
B00K - R0019 - Movement - (12.86 SQM)	Not Applicable	Circulation or storage space.
B00K - R0020 - Movement - (13.83 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Reading Area - (229.1 SQM)	Student Space (106)	
B00L - R0010 - Home Base - (58.68 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0012 - Withdrawal Space - 1hb - (8.67 SQM)	Student Space (4)	
B00L - R0013 - Practical Activities - 1hb - (19.12 SQM)	Student Space (8)	
DS 615 18150 - DS 615 18150 - Learning Unit - Quad with PAA 2 Storey - (304 SQM)	Student Space (141)	
DS 615 18151 - DS 615 18151 - Learning Unit - Quad with PAA 2 Storey - (304 SQM)	Student Space (141)	
OS 520 12116 - OS 520 12116 - Staff Study - (57 SQM)	Office (14)	
OS 601 10171 - OS 601 10171 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11201 - OS 601 11201 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 13537 - OS 601 13537 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14979 - OS 601 14979 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 15455 - OS 601 15455 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 602 10120 - OS 602 10120 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11605 - OS 602 11605 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11899 - OS 602 11899 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12069 - OS 602 12069 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12132 - OS 602 12132 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12709 - OS 602 12709 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13022 - OS 602 13022 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13306 - OS 602 13306 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13548 - OS 602 13548 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14094 - OS 602 14094 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14143 - OS 602 14143 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14324 - OS 602 14324 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14617 - OS 602 14617 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14675 - OS 602 14675 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14982 - OS 602 14982 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14990 - OS 602 14990 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15748 - OS 602 15748 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15988 - OS 602 15988 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 16236 - OS 602 16236 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 10037 - OS 603 10037 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 603 13798 - OS 603 13798 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 603 14125 - OS 603 14125 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 603 15229 - OS 603 15229 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 603 17954 - OS 603 17954 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 606 19043 - OS 606 19043 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19241 - OS 606 19241 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 612 19519 - OS 612 19519 - Learning Unit - Double With Resource - (152 SQM)	Student Space (70)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 612 19521 - OS 612 19521 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 750 15858 - OS 750 15858 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	