

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Glebe Public School (7419)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Balmain</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sydney</b>

7419 - Glebe Public School  
Site Plan (12731)




1:641

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (7.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Home Base - (68.38 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R0005 - Practical Activities - 1hb - (14.48 SQM)	● Student Space (6)	
B00A - R0008 - Practical Activities - 1hb - (14.58 SQM)	● Student Space (6)	
B00A - R0009 - Home Base - (69.27 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R0011 - Withdrawal Space - 1hb - (17.42 SQM)	● Student Space (8)	
B00A - R0012 - Movement - (20.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (29.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Practical Activities - 1hb - (5.42 SQM)	● Student Space (2)	
B00A - R1002 - Home Base - (66.91 SQM) - Teaching Space: 1	● Student Space (31)	
B00A - R1005 - Home Base - (73.17 SQM) - Teaching Space: 1	● Student Space (33)	
B00A - R1007 - Practical Activities - 1hb - (16.1 SQM)	● Student Space (7)	
B00A - R1009 - Practical Activities - 1hb - (15.83 SQM)	● Student Space (7)	
B00A - R1010 - Home Base - (73.19 SQM) - Teaching Space: 1	● Student Space (33)	
B00A - R1012 - Staff Room - (12.24 SQM)	● Office (3)	
B00A - R1015 - Movement - (36.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (65.35 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0002 - Clerical Office - (46.94 SQM)	● Office (11)	
B00B - R0003 - Movement - (18.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Principal - (14.6 SQM)	● Office (3)	
B00B - R0005 - Staff Room - (64.34 SQM)	● Office (16)	
B00B - R0006 - Duplicating Workroom - (24.66 SQM)	● Office (6)	
B00B - R0007 - Sick Bay - (19.18 SQM)	● Student Space (8)	
B00B - R0008 - Movement - (73.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Home Base - (65.65 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1002 - Home Base - (66.96 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R1004 - Reading Area - (111.35 SQM)	● Student Space (51)	
B00B - R1005 - Movement - (46.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R1006 - Darkroom Space - (16.06 SQM)	● Office (4)	
B00B - R1007 - Deputy Principal - (9.67 SQM)	● Office (2)	
B00B - R1008 - Practical Activities - 1hb - (10.4 SQM)	● Student Space (4)	
B00C - R0001 - Special Programs Room - (42.19 SQM)	● Student Space (19)	
B00C - R0002 - Deputy Principal - (11.85 SQM)	● Office (2)	
B00C - R0011 - Home Base - (57.88 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0013 - Home Base - (58.95 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0014 - Practical Activities - 1hb - (5.47 SQM)	● Student Space (2)	
B00C - R0016 - Movement - (20.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Raised Platform - (21.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Communal Space - (173.73 SQM)	● Student Space (80)	
B00C - R1001 - Home Base - (42.8 SQM) - Teaching Space: 1	● Student Space (19)	
B00C - R1002 - Withdrawal Space - 1hb - (15.43 SQM)	● Student Space (7)	
B00C - R1003 - Movement - (45.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - Practical Activities - M - 1hb - (11.93 SQM)	● Student Space (5)	
B00C - R1007 - Special Programs Room - (31.09 SQM)	● Student Space (14)	
B00C - R1008 - Home Base - M - (43.93 SQM) - Teaching Space: 1	● Student Space (20)	
B00C - R9003 - Movement - (11.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R9005 - Movement - (7.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R9006 - Movement - (12.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R9010 - Canteen - (26.95 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R9014 - Movement - (19.23 SQM)	Not Applicable	Circulation or storage space.
OS 602 19701 - OS 602 19701 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	