


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Gledswood Hills Public School (4667)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Camden</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Camden</b>

4667 - Gledswood Hills Public School  
Site Plan (15704)



1:1,031

Printed: 13-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1001 - Entry Vestibule - (22.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Interview - (18.53 SQM)	Office (4)	
B00A - R1003 - Clerical Office - (75.71 SQM)	Office (18)	
B00A - R1008 - Sick Bay - (9.7 SQM)	Student Space (4)	
B00A - R1009 - Principal - (19.87 SQM)	Office (4)	
B00A - R1010 - Interview - (17.28 SQM)	Office (4)	
B00A - R1011 - Movement - (24.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R1018 - Canteen - (57.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R2002 - Staff Kitchen - (6.11 SQM)	Office (1)	
B00A - R2003 - Staff Kitchen - (8.98 SQM)	Office (2)	
B00A - R2005 - Staff Room - (9.53 SQM)	Office (2)	
B00A - R2006 - Staff Room - (32.22 SQM)	Office (8)	
B00A - R2008 - Staff Room - (35.52 SQM)	Office (8)	
B00A - R2009 - Staff Room - (35.18 SQM)	Office (8)	
B00A - R2015 - Deputy Principal - Type 2 - (66.02 SQM)	Office (16)	
B00A - R2016 - Clerical/Printing - (13.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R2017 - Interview - (18.03 SQM)	Office (4)	
B00A - R2022 - Movement - (25.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R2026 - Staff Room - (81.91 SQM)	Office (20)	
B00A - R2027 - Staff Room Annexe - (45.35 SQM)	Office (11)	
B00A - R2028 - Staff Kitchen - (5.92 SQM)	Office (1)	
B00B - R0003 - Movement - (21.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Communal Space - (269.14 SQM)	Student Space (124)	
B00B - R1002 - Raised Platform - (54.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R1014 - Movement - (10.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R1015 - Movement - (18.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Reading Area - (207.02 SQM)	Student Space (96)	
B00C - R1002 - Entry Vestibule - (49.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Clerical Office/Workroom - (19.2 SQM)	Office (4)	
B00C - R1014 - Tiered Learning Space - (31.41 SQM)	Student Space (14)	
B00C - R2004 - Reading Area - (72.15 SQM)	Student Space (33)	
B00C - R2005 - Special Programs Room - (20.97 SQM)	Student Space (9)	
B00C - R2006 - Tiered Learning Space - (17.01 SQM)	Student Space (7)	
B00C - R3001 - Home Base X4 - (345.08 SQM) - Teaching Space: 3	Student Space (160)	
B00C - R3003 - Withdrawal Space - 2hb - (15.71 SQM)	Student Space (7)	
B00C - R3005 - Withdrawal Space - 2hb - (16.27 SQM)	Student Space (7)	
B00D - R0001 - Home Base - (59.98 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0002 - Practical Activities - 1hb - (12.73 SQM)	Student Space (5)	
B00D - R0003 - Presentation Area - (6.92 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Withdrawal Space - 1hb - (12.12 SQM)	Student Space (5)	
B00D - R0005 - Home Base - (59.97 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0006 - Practical Activities - 1hb - (13.41 SQM)	Student Space (6)	
B00D - R0007 - Presentation Area - (6.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Withdrawal Space - 1hb - (12.58 SQM)	Student Space (5)	
B00D - R0009 - Home Base - (60.03 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0010 - Practical Activities - 1hb - (13.39 SQM)	Student Space (6)	
B00D - R0011 - Presentation Area - (6.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Withdrawal Space - 1hb - (12.58 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0013 - Home Base - (60.01 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0014 - Practical Activities - 1hb - (12.92 SQM)	Student Space (5)	
B00D - R0015 - Presentation Area - (6.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Withdrawal Space - 1hb - (12.12 SQM)	Student Space (5)	
B00D - R1001 - Home Base - (60.3 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1002 - Practical Activities - 1hb - (12.92 SQM)	Student Space (5)	
B00D - R1003 - Presentation Area - (6.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R1004 - Withdrawal Space - 1hb - (12.12 SQM)	Student Space (5)	
B00D - R1005 - Home Base - (60.47 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R1006 - Practical Activities - 1hb - (13.62 SQM)	Student Space (6)	
B00D - R1007 - Presentation Area - (6.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R1008 - Withdrawal Space - 1hb - (12.58 SQM)	Student Space (5)	
B00D - R1009 - Home Base - (60.01 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1010 - Practical Activities - 1hb - (13.41 SQM)	Student Space (6)	
B00D - R1011 - Presentation Area - (6.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R1012 - Withdrawal Space - 1hb - (12.57 SQM)	Student Space (5)	
B00D - R1013 - Home Base - (60.01 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1014 - Practical Activities - 1hb - (13.01 SQM)	Student Space (6)	
B00D - R1015 - Presentation Area - (6.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R1016 - Withdrawal Space - 1hb - (12.12 SQM)	Student Space (5)	
B00D - R2001 - Home Base - (60.02 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R2002 - Practical Activities - 1hb - (12.99 SQM)	Student Space (6)	
B00D - R2003 - Presentation Area - (6.71 SQM)	Not Applicable	Circulation or storage space.
B00D - R2004 - Withdrawal Space - 1hb - (12.12 SQM)	Student Space (5)	
B00D - R2005 - Home Base - (60.2 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R2006 - Practical Activities - 1hb - (13.42 SQM)	Student Space (6)	
B00D - R2007 - Presentation Area - (6.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R2008 - Withdrawal Space - 1hb - (12.58 SQM)	Student Space (5)	
B00D - R2009 - Home Base - (60.01 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R2010 - Practical Activities - 1hb - (13.42 SQM)	Student Space (6)	
B00D - R2011 - Presentation Area - (6.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R2012 - Withdrawal Space - 1hb - (12.57 SQM)	Student Space (5)	
B00D - R2013 - Home Base - (60.01 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R2014 - Practical Activities - 1hb - (13.04 SQM)	Student Space (6)	
B00D - R2015 - Presentation Area - (6.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R2016 - Withdrawal Space - 1hb - (12.12 SQM)	Student Space (5)	
B00E - R0009 - Home Base - (60.24 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0010 - Practical Activities - 1hb - (13.06 SQM)	Student Space (6)	
B00E - R0011 - Presentation Area - (6.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Withdrawal Space - 1hb - (12.12 SQM)	Student Space (5)	
B00E - R0013 - Home Base - (60.26 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0014 - Practical Activities - 1hb - (13.43 SQM)	Student Space (6)	
B00E - R0015 - Presentation Area - (6.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Withdrawal Space - 1hb - (12.58 SQM)	Student Space (5)	
B00E - R0017 - Home Base - (59.66 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0018 - Practical Activities - 1hb - (13.43 SQM)	Student Space (6)	
B00E - R0019 - Presentation Area - (6.98 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0020 - Withdrawal Space - 1hb - (12.58 SQM)	● Student Space (5)	
B00E - R1009 - Home Base - (60.24 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1010 - Practical Activities - 1hb - (12.78 SQM)	● Student Space (5)	
B00E - R1011 - Presentation Area - (6.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R1012 - Withdrawal Space - 1hb - (12.12 SQM)	● Student Space (5)	
B00E - R1013 - Home Base - (60.24 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1014 - Practical Activities - 1hb - (12.79 SQM)	● Student Space (5)	
B00E - R1016 - Withdrawal Space - 1hb - (12.39 SQM)	● Student Space (5)	
B00E - R1017 - Home Base - (60.62 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R1018 - Practical Activities - 1hb - (12.79 SQM)	● Student Space (5)	
B00E - R1019 - Withdrawal Space - 1hb - (12.39 SQM)	● Student Space (5)	
B00E - R9001 - Movement - (6.13 SQM)	Not Applicable	Circulation or storage space.
B00E - R9007 - Home Base - (59.84 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R9008 - Practical Activities - 1hb - (13.68 SQM)	● Student Space (6)	
B00E - R9009 - Presentation Area - (6.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R9010 - Withdrawal Space - 1hb - (12.15 SQM)	● Student Space (5)	
B00E - R9011 - Home Base - (60.38 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R9012 - Practical Activities - 1hb - (13.5 SQM)	● Student Space (6)	
B00E - R9013 - Presentation Area - (7.14 SQM)	Not Applicable	Circulation or storage space.
B00E - R9014 - Withdrawal Space - 1hb - (12.61 SQM)	● Student Space (5)	
B00E - R9015 - Home Base - (59.79 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R9016 - Practical Activities - 1hb - (13.48 SQM)	● Student Space (6)	
B00E - R9017 - Presentation Area - (7.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R9018 - Withdrawal Space - 1hb - (12.61 SQM)	● Student Space (5)	
OS 612 19389 - OS 612 19389 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 19394 - OS 612 19394 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 19395 - OS 612 19395 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 19403 - OS 612 19403 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 19404 - OS 612 19404 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 19405 - OS 612 19405 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 19406 - OS 612 19406 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 19407 - OS 612 19407 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 19530 - OS 612 19530 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	