

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Glendale Technology High School (8466)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Wallsend</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

8466 - Glendale Technology High School  
Site Plan (10992)



1:2,777

Printed: 30-Sep-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Deputy Principal Office - (16.9 SQM)	Office (4)	
B00A - R0005 - Clinic - Girls - (13.05 SQM)	Office (3)	
B00A - R0006 - Clinic - Boys - (13.61 SQM)	Office (3)	
B00A - R0007 - Administration - Clerical - (40.11 SQM)	Office (10)	
B00A - R0008 - Duplicating Workroom - (23.73 SQM)	Office (5)	
B00A - R0010 - Teachers Aides - (13.43 SQM)	Office (3)	
B00A - R0011 - Interview/Office - Type 1 - (13.24 SQM)	Office (3)	
B00A - R0012 - Leading Teacher - (13.24 SQM)	Office (3)	
B00A - R0013 - Principal Office - (19.96 SQM)	Office (4)	
B00A - R0016 - Interview/Office - Type 1 - (12.58 SQM)	Office (3)	
B00A - R0017 - Interview/Office - Type 1 - (11.83 SQM)	Office (2)	
B00A - R0018 - Movement - (84.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (22.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Workroom - (18.46 SQM)	Office (4)	
B00B - R0009 - Workroom - (5.7 SQM)	Office (1)	
B00B - R0011 - Senior Study - (52.25 SQM)	Office (13)	
B00B - R0012 - Seminar - (139.47 SQM)	Office (34)	
B00B - R0013 - Main Area - (205.39 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Seminar - (12.92 SQM)	Office (3)	
B00B - R0015 - Seminar - (12.92 SQM)	Office (3)	
B00B - R0016 - Workroom - (54.01 SQM)	Office (13)	
B00B - R0017 - Audio Visual Workroom - (26.57 SQM)	Student Space (12)	
B00B - R0019 - Movement - (71.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Movement - (52.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Computer Learning Space - (52.92 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1002 - General Learning Space - (52.92 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1003 - Staff Study - (19.35 SQM)	Office (4)	
B00B - R1006 - Movement - (20.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R1007 - General Learning Space - (52.92 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1008 - General Learning Space - (52.92 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1009 - General Learning Space - (52.92 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1010 - General Learning Space - (65.41 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1011 - General Learning Space - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1015 - Staff Study - (39.06 SQM)	Office (9)	
B00B - R1016 - Movement - (18.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R1018 - Movement - (37.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - General Learning Space - (54.02 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0002 - Staff Study - (39.59 SQM)	Office (9)	
B00C - R0003 - General Learning Space - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0004 - General Learning Space - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0005 - Staff Study - (53.65 SQM)	Office (13)	
B00C - R0013 - Staff Study - (14.84 SQM)	Office (3)	
B00C - R0014 - Staff Study - (22.86 SQM)	Office (5)	
B00C - R0016 - General Learning Space - (54.02 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0018 - Movement - (93.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - General Learning Space - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1002 - Computer Learning Space - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1003 - Staff Study - (19.22 SQM)	Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1004 - Movement - (18.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R1005 - General Learning Space - (52.91 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1006 - General Learning Space - (52.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1007 - General Learning Space - (52.91 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1008 - General Learning Space - (52.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1009 - Staff Study - (19.17 SQM)	○ Office (4)	
B00C - R1013 - Staff Study - (38.88 SQM)	○ Office (9)	
B00C - R1014 - Computer Learning Space - (52.91 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1016 - Movement - (27.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Laboratory L.S. - (91.04 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0003 - Preparation - (30.62 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Laboratory L.S. - (91.04 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0008 - Movement - (36.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Movement - (70.91 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Art Learning Space - (91.86 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R1002 - Staff Study - (30.08 SQM)	○ Office (7)	
B00D - R1005 - Art Learning Space - (91.86 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R1010 - Movement - (68.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Materials Technology L.S. - (82.26 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R0002 - Welding Area - (21.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Design/Technology L.S. - (81.9 SQM) - Teaching Space: 1	● Student Space (37)	
B00E - R0006 - Workshop - (73.36 SQM)	● Student Space (34)	
B00E - R0012 - Movement - (33.25 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (9.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Movement - (88.57 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Materials Technology L.S. - (81.73 SQM) - Teaching Space: 1	● Student Space (37)	
B00E - R1004 - Materials Technology L.S. - (81.91 SQM) - Teaching Space: 1	● Student Space (38)	
B00E - R1008 - Design L.S. - (52.93 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1009 - Staff Study - (25.7 SQM)	○ Office (6)	
B00E - R1011 - Design L.S. - (52.93 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1015 - Movement - (48.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R1021 - Movement - (57.52 SQM)	Not Applicable	Circulation or storage space.
B00E - R9002 - General Assistants - (17.64 SQM)	○ Office (4)	
B00F - R0001 - Stage - (60.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Multi-Purpose Space - (249.89 SQM)	● Student Space (115)	
B00F - R0009 - Student Canteen - (53.9 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Movement - (80.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Movement - (22.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R1015 - Movement - (56.16 SQM)	Not Applicable	Circulation or storage space.
B00F - R1016 - Movement - (11.07 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Movement - (30.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Food Technology L.S. - (82.35 SQM) - Teaching Space: 1	● Student Space (38)	
B00G - R0015 - Food/Research Space - (16.2 SQM)	Not Applicable	Circulation or storage space.
B00G - R0021 - Movement - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00G - R0023 - Movement - (14.77 SQM)	Not Applicable	Circulation or storage space.
B00G - R0024 - Preparation - (15.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R0026 - Kitchen - Type 1 - (104.56 SQM)	● Student Space (48)	
B00G - R0027 - Preparation - (14.34 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Movement - (10.44 SQM)	Not Applicable	Circulation or storage space.
B00G - R0029 - Staff Lounge - (48.94 SQM)	○ Office (12)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0030 - Staff Study - (32.02 SQM)	Office (8)	
B00G - R0031 - Movement - (59.54 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - General Learning Space - (65.97 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R1003 - General Learning Space - (65.97 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R1004 - General Learning Space - (65.52 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R1005 - Staff Study - (13.64 SQM)	Office (3)	
B00G - R1006 - Movement - (16.56 SQM)	Not Applicable	Circulation or storage space.
B00G - R1007 - Music Learning Space - (65.79 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R1008 - Music Learning Space - (65.79 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R1009 - Staff Study - (32.3 SQM)	Office (8)	
B00G - R1010 - General Learning Space - (65.97 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R1013 - Movement - (75.9 SQM)	Not Applicable	Circulation or storage space.
B00G - R1016 - Movement - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Laboratory L.S. - (91.12 SQM) - Teaching Space: 1	Student Space (42)	
B00H - R0002 - Preparation - (30.9 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Preparation - (13.24 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Laboratory L.S. - (90.66 SQM) - Teaching Space: 1	Student Space (42)	
B00H - R0015 - Movement - (8.59 SQM)	Not Applicable	Circulation or storage space.
B00H - R1001 - Laboratory L.S. - (92 SQM) - Teaching Space: 1	Student Space (42)	
B00H - R1002 - Preparation - (31.25 SQM)	Not Applicable	Circulation or storage space.
B00H - R1005 - Laboratory L.S. - (92 SQM) - Teaching Space: 1	Student Space (42)	
B00H - R1016 - Movement - (8.89 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Stage - (66.59 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Movement - (53.31 SQM)	Not Applicable	Circulation or storage space.
B00I - R0008 - Student Canteen - (15.8 SQM)	Not Applicable	Circulation or storage space.
B00I - R0018 - Multi-Purpose Space - (514.74 SQM)	Student Space (238)	
B00I - R0021 - Movement - (196.11 SQM)	Not Applicable	Circulation or storage space.
OS 523 11291 - OS 523 11291 - Staff Study With Toilets - (76 SQM)	Office (19)	
OS 601 19780 - OS 601 19780 - Learning Unit - Standard/Withdrawal - (57 SQM)	Student Space (26)	
OS 601 19781 - OS 601 19781 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 19782 - OS 601 19782 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 19783 - OS 601 19783 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 19784 - OS 601 19784 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 621 19539 - OS 621 19539 - Learning Unit Single - PWD - (95 SQM)	Student Space (44)	