

VENTILATION AUDIT REPORT

SCHOOL:	Glendenning Public School (4608)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Mount Druitt
LOCAL GOVERNMENT AREA:	Blacktown

4608 - Glendenning Public School
Site Plan (13498)










































1:1,007

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (17.73 SQM)	 Office (4)	
B00A - R0002 - Entry Vestibule - (19.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Duplicating Workroom - (32.65 SQM)	 Office (8)	
B00A - R0005 - Principal - (16.96 SQM)	 Office (4)	
B00A - R0011 - Staff Room Annexe - (31.38 SQM)	 Office (7)	
B00A - R0012 - Staff Room - (53.78 SQM)	 Office (13)	
B00A - R0013 - Practical Activities - 1hb - (27.15 SQM)	 Student Space (12)	
B00A - R0014 - Withdrawal Space - 1hb - (5.85 SQM)	 Student Space (2)	
B00A - R0016 - Home Base - (50.4 SQM) - Teaching Space: 1	 Student Space (23)	
B00A - R0017 - Home Base - (50.98 SQM) - Teaching Space: 1	 Student Space (23)	
B00A - R0018 - Withdrawal Space - 1hb - (5.85 SQM)	 Student Space (2)	
B00A - R0020 - Practical Activities - 1hb - (27.33 SQM)	 Student Space (12)	
B00A - R0021 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Deputy Principal - (13.19 SQM)	 Office (3)	
B00A - R0027 - Deputy Principal - (13.26 SQM)	 Office (3)	
B00A - R0028 - Interview - (13.15 SQM)	 Office (3)	
B00A - R0030 - Sick Bay - (8.62 SQM)	 Student Space (3)	
B00A - R0031 - Movement - (37.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (17.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Communal Space - (206.69 SQM)	 Student Space (95)	
B00B - R0016 - Movement - (7.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Communal Space - (34.08 SQM)	 Student Space (15)	
B00B - R0018 - Movement - (7.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Movement - (205.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (35.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Practical Activities - 1hb - (27.24 SQM)	 Student Space (12)	
B00C - R0007 - Withdrawal Space - 1hb - (5.85 SQM)	 Student Space (2)	
B00C - R0008 - Home Base - (50.91 SQM) - Teaching Space: 1	 Student Space (23)	
B00C - R0009 - Practical Activities - 1hb - (27.22 SQM)	 Student Space (12)	
B00C - R0010 - Home Base - (50.62 SQM) - Teaching Space: 1	 Student Space (23)	
B00C - R0012 - Withdrawal Space - 1hb - (5.9 SQM)	 Student Space (2)	
B00C - R0014 - Reading Area - (226.26 SQM)	 Student Space (104)	
B00D - R0001 - Special Programs Room - (44.5 SQM)	 Student Space (20)	
B00E - R0005 - Practical Activities - 1hb - (27.45 SQM)	 Student Space (12)	
B00E - R0007 - Withdrawal Space - 1hb - (5.81 SQM)	 Student Space (2)	
B00E - R0008 - Home Base - (51.34 SQM) - Teaching Space: 1	 Student Space (23)	
B00E - R0009 - Practical Activities - 1hb - (27.13 SQM)	 Student Space (12)	
B00E - R0010 - Home Base - (51.05 SQM) - Teaching Space: 1	 Student Space (23)	
B00E - R0012 - Withdrawal Space - 1hb - (12.11 SQM)	 Student Space (5)	
B00E - R0013 - Home Base - (50.62 SQM) - Teaching Space: 1	 Student Space (23)	
B00E - R0015 - Practical Activities - 1hb - (27.29 SQM)	 Student Space (12)	
B00E - R0016 - Home Base - (51.2 SQM) - Teaching Space: 1	 Student Space (23)	
B00E - R0017 - Practical Activities - 1hb - (26.35 SQM)	 Student Space (12)	
B00E - R0020 - Withdrawal Space - 1hb - (5.88 SQM)	 Student Space (2)	
B00E - R0021 - Movement - (17.57 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Practical Activities - 1hb - (30.71 SQM)	 Student Space (14)	
B00F - R0005 - Withdrawal Space - 1hb - (5.83 SQM)	 Student Space (2)	
B00F - R0006 - Home Base - (51.13 SQM) - Teaching Space: 1	 Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0007 - Home Base - (50.98 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R0008 - Withdrawal Space - 1hb - (5.88 SQM)	● Student Space (2)	
B00F - R0010 - Practical Activities - 1hb - (31.58 SQM)	● Student Space (14)	
B00G - R0002 - Practical Activities - 1hb - (27.5 SQM)	● Student Space (12)	
B00G - R0004 - Withdrawal Space - 1hb - (5.88 SQM)	● Student Space (2)	
B00G - R0005 - Home Base - (50.76 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R0006 - Home Base - (50.76 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R0007 - Practical Activities - 1hb - (27.71 SQM)	● Student Space (12)	
B00G - R0008 - Withdrawal Space - 1hb - (12.18 SQM)	● Student Space (5)	
B00G - R0011 - Home Base - (50.76 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R0012 - Practical Activities - 1hb - (27.24 SQM)	● Student Space (12)	
B00G - R0013 - Practical Activities - 1hb - (26.89 SQM)	● Student Space (12)	
B00G - R0014 - Home Base - (51.05 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R0016 - Withdrawal Space - 1hb - (5.88 SQM)	● Student Space (2)	
B00H - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00H - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00H - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00J - R0001 - Practical Activities - 1hb - (18.96 SQM)	● Student Space (8)	
B00J - R0003 - Withdrawal Space - 2hb - (11.61 SQM)	● Student Space (5)	
B00J - R0004 - Practical Activities - 1hb - (18.86 SQM)	● Student Space (8)	
B00J - R0006 - Practical Activities - 1hb - (18.9 SQM)	● Student Space (8)	
B00J - R0008 - Withdrawal Space - 2hb - (11.61 SQM)	● Student Space (5)	
B00J - R0009 - Practical Activities - 1hb - (18.89 SQM)	● Student Space (8)	
B00J - R0011 - Special Programs Room - (41.04 SQM)	● Student Space (19)	
B00J - R0013 - Home Base - (60.95 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0014 - Home Base - (60.77 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0015 - Home Base - (60.92 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0016 - Home Base - (60.65 SQM) - Teaching Space: 1	● Student Space (28)	
OS 602 12534 - OS 602 12534 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12575 - OS 602 12575 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 18270 - OS 602 18270 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 12407 - OS 606 12407 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19014 - OS 606 19014 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 750 14159 - OS 750 14159 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	