


VENTILATION AUDIT REPORT

| | |
|-------------------------------|--------------------------------------|
| SCHOOL: | Glendore Public School (4620) |
| AMU REGION: | Hunter/Central Coast |
| STATE ELECTORATE: | Wallsend |
| LOCAL GOVERNMENT AREA: | Newcastle |

4620 - Glendore Public School
Site Plan (13276)



1:1,121

Printed: 04-Sep-2021

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0004 - Principal - (16.75 SQM) | Office (4) | |
| B00A - R0006 - Deputy Principal - (13.89 SQM) | Office (3) | |
| B00A - R0008 - Staff Room Annexe - (20.13 SQM) | Office (5) | |
| B00A - R0009 - Staff Room - (45.02 SQM) | Office (11) | |
| B00A - R0015 - Deputy Principal - (13.2 SQM) | Office (3) | |
| B00A - R0016 - Interview - (13.13 SQM) | Office (3) | |
| B00A - R0019 - Clerical Office - (18.12 SQM) | Office (4) | |
| B00A - R0021 - Movement - (111.47 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0022 - Clerical/Printing - (10.99 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0024 - Sick Bay - (5.45 SQM) | Student Space (2) | |
| B00A - R0025 - Movement - (56.58 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0026 - Clerical Office - (9.8 SQM) | Office (2) | |
| B00B - R0001 - Movement - (171.88 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0007 - Withdrawal Space - 1hb - (5.87 SQM) | Student Space (2) | |
| B00B - R0009 - Practical Activities - 1hb - (22.86 SQM) | Student Space (10) | |
| B00B - R0011 - Home Base - (51.17 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00B - R0013 - Practical Activities - 1hb - (23.34 SQM) | Student Space (10) | |
| B00B - R0014 - Home Base - (50.74 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00B - R0016 - Withdrawal Space - 1hb - (6.34 SQM) | Student Space (2) | |
| B00B - R0017 - Withdrawal Space - 1hb - (6.39 SQM) | Student Space (2) | |
| B00B - R0019 - Practical Activities - 1hb - (23.27 SQM) | Student Space (10) | |
| B00B - R0021 - Home Base - (51.09 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00B - R0022 - Home Base - (51.02 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00B - R0024 - Practical Activities - 1hb - (22.1 SQM) | Student Space (10) | |
| B00B - R0026 - Withdrawal Space - 1hb - (5.85 SQM) | Student Space (2) | |
| B00C - R0002 - Special Programs Room - (32.08 SQM) | Student Space (14) | |
| B00C - R0006 - Reading Area - (167.91 SQM) | Student Space (77) | |
| B00C - R0011 - Movement - (44.9 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0008 - Movement - (7.26 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0009 - Communal Space - (192.77 SQM) | Student Space (89) | |
| B00D - R0010 - Raised Platform - (48.42 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0016 - Movement - (6.66 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0019 - Staff Kitchen - (18.59 SQM) | Office (4) | |
| B00D - R0021 - Movement - (7.24 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0022 - Entry Vestibule - (13.43 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0023 - Movement - (32.6 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0024 - Staff Room Annexe - (17.53 SQM) | Office (4) | |
| B00D - R0026 - Interview - (15.46 SQM) | Office (3) | |
| B00D - R0027 - Interview - (15.38 SQM) | Office (3) | |
| B00D - R0031 - Movement - (11.22 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0001 - Canteen - (25.25 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0003 - Movement - (234.81 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0001 - Movement - (127.93 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0002 - Practical Activities - 1hb - (16.19 SQM) | Student Space (7) | |
| B00F - R0004 - Home Base - (59.05 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00F - R0006 - Withdrawal Space - 1hb - (10.86 SQM) | Student Space (5) | |
| B00F - R0009 - Practical Activities - 1hb - (16.21 SQM) | Student Space (7) | |
| B00F - R0010 - Home Base - (58.59 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00F - R0013 - Practical Activities - 1hb - (16.49 SQM) | Student Space (7) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00F - R0015 - Home Base - (60 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00F - R0016 - Withdrawal Space - 1hb - (10.83 SQM) | Student Space (5) | |
| B00F - R0018 - Practical Activities - 1hb - (16.62 SQM) | Student Space (7) | |
| B00F - R0019 - Home Base - (59.75 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00F - R0023 - Practical Activities - 1hb - (16.22 SQM) | Student Space (7) | |
| B00F - R0025 - Home Base - (59.31 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00F - R0026 - Withdrawal Space - 1hb - (10.87 SQM) | Student Space (5) | |
| B00F - R0028 - Practical Activities - 1hb - (16.08 SQM) | Student Space (7) | |
| B00F - R0029 - Home Base - (58.87 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00G - R0001 - Movement - (38.51 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0002 - Practical Activities - 1hb - (19.41 SQM) | Student Space (9) | |
| B00G - R0004 - Home Base - (59.25 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00G - R0005 - Withdrawal Space - 2hb - (11.37 SQM) | Student Space (5) | |
| B00G - R0006 - Home Base - (59.25 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00G - R0008 - Practical Activities - 1hb - (19.42 SQM) | Student Space (9) | |
| B00H - R0002 - Practical Activities - 1hb - (19.09 SQM) | Student Space (8) | |
| B00H - R0004 - Home Base - (60.64 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00H - R0005 - Withdrawal Space - 2hb - (11.55 SQM) | Student Space (5) | |
| B00H - R0006 - Practical Activities - 1hb - (19.09 SQM) | Student Space (8) | |
| B00H - R0007 - Home Base - (60.64 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00I - R0002 - Practical Activities - 1hb - (19.09 SQM) | Student Space (8) | |
| B00I - R0004 - Home Base - (60.64 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00I - R0005 - Withdrawal Space - 2hb - (11.55 SQM) | Student Space (5) | |
| B00I - R0006 - Practical Activities - 1hb - (19.09 SQM) | Student Space (8) | |
| B00I - R0007 - Home Base - (60.64 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00J - R0006 - Practical Activities - 1hb - (18.94 SQM) | Student Space (8) | |
| B00J - R0008 - Home Base - (60.84 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00J - R0009 - Withdrawal Space - 2hb - (11.48 SQM) | Student Space (5) | |
| B00J - R0010 - Practical Activities - 1hb - (18.94 SQM) | Student Space (8) | |
| B00J - R0011 - Home Base - (60.84 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00K - R0002 - Special Programs Room - (60.57 SQM) | Student Space (28) | |
| OS 521 16372 - OS 521 16372 - Staff Study - (76 SQM) | Office (19) | |
| OS 602 14285 - OS 602 14285 - Learning Unit - Standard With P.A.A. - (76 SQM) | Student Space (35) | |
| OS 602 14656 - OS 602 14656 - Learning Unit - Standard With P.A.A. - (76 SQM) | Student Space (35) | |
| OS 602 15289 - OS 602 15289 - Learning Unit - Standard With P.A.A. - (76 SQM) | Student Space (35) | |
| OS 602 19792 - OS 602 19792 - Learning Unit - Standard With P.A.A. - (76 SQM) | Student Space (35) | |
| OS 606 19190 - OS 606 19190 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | Student Space (35) | |
| OS 606 19191 - OS 606 19191 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | Student Space (35) | |
| OS 606 19278 - OS 606 19278 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | Student Space (35) | |
| OS 606 19902 - OS 606 19902 - Learning Unit - Standard With P.A.A A/C - (SQM) | Student Space () | |