

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Glenfield Public School (2001)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Macquarie Fields</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Campbelltown</b>

2001 - Glenfield Public School  
Site Plan (12734)



1:1,053

Printed: 10-Apr-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (69.4 SQM) - Teaching Space: 1	Student Space (32)	
B00A - R0005 - Home Base - (78.18 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0006 - Practical Activities - 1hb - (10.3 SQM)	Student Space (4)	
B00A - R0009 - Practical Activities - 1hb - (10.3 SQM)	Student Space (4)	
B00A - R0010 - Home Base - (78.18 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0013 - Home Base - (50.61 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0014 - Practical Activities - 1hb - (17.25 SQM)	Student Space (8)	
B00B - R0001 - Practical Activities - 1hb - (17.33 SQM)	Student Space (8)	
B00B - R0002 - Home Base - (50.99 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0005 - Home Base - (50.85 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0006 - Practical Activities - 1hb - (17.26 SQM)	Student Space (8)	
B00B - R0007 - Clerical Office - (39.24 SQM)	Office (9)	
B00B - R0009 - Staff Room Annexe - (10.76 SQM)	Office (2)	
B00B - R0010 - Staff Room - (32.11 SQM)	Office (8)	
B00B - R0013 - Special Programs Room - (17.4 SQM)	Student Space (8)	
B00B - R0014 - Duplicating Workroom - (14.05 SQM)	Office (3)	
B00B - R0018 - Movement - (11.39 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Principal - (22.58 SQM)	Office (5)	
B00B - R0024 - Sick Bay - (6.76 SQM)	Student Space (3)	
B00C - R0014 - Practical Activities - 1hb - (5.07 SQM)	Student Space (2)	
B00C - R0015 - Home Base - (71.27 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R0016 - Reading Area - (70.82 SQM)	Student Space (32)	
B00D - R0002 - Home Base - (57.01 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0007 - Home Base - (57 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0009 - Home Base - (57.15 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0013 - Home Base - (56.72 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0014 - Staff Room Annexe - (13 SQM)	Office (3)	
B00D - R0018 - Movement - (8.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0026 - Special Programs Room - (28.88 SQM)	Student Space (13)	
B00D - R0027 - Practical Activities/Movement - 2hb - (13.96 SQM)	Student Space (6)	
B00D - R0028 - Practical Activities/Movement - 2hb - (15.69 SQM)	Student Space (7)	
B00E - R0001 - Withdrawal Space - 1hb - (16.82 SQM)	Student Space (7)	
B00E - R0003 - Home Base - (53.6 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0004 - Home Base - (53.53 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0001 - Communal Space - (135.2 SQM)	Student Space (62)	
B00F - R0002 - Raised Platform - (52.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Movement - (6.58 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Canteen - (27.48 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Reading Area - (91.5 SQM)	Student Space (42)	
OS 602 10149 - OS 602 10149 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 10210 - OS 602 10210 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 10681 - OS 602 10681 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12901 - OS 602 12901 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 18226 - OS 602 18226 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 750 17816 - OS 750 17816 - Learning Unit - ESL - (38 SQM)	Student Space (17)	