

VENTILATION AUDIT REPORT

SCHOOL:	Glenmore Park High School (8276)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Mulgoa
LOCAL GOVERNMENT AREA:	Penrith

8276 - Glenmore Park High School
Site Plan (13592)



1:1,287

Printed: 07-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (70.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Movement - (8.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Interview/Office - Type 1 - (11.98 SQM)	Office (2)	
B00A - R0008 - Interview/Office - Type 1 - (11.82 SQM)	Office (2)	
B00A - R0009 - Public Entry - (21.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Public Entry - (21.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Interview/Office - Type 1 - (12.53 SQM)	Office (3)	
B00A - R0012 - Administration - Clerical - (61.76 SQM)	Office (15)	
B00A - R0015 - Movement - (7.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Principal Office - (19.53 SQM)	Office (4)	
B00A - R0017 - Leading Teacher - (25.95 SQM)	Office (6)	
B00A - R0018 - Movement - (11.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Deputy Principal Office - (11.97 SQM)	Office (2)	
B00A - R0020 - Pupil Entry - (40.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Interview/Office - Type 1 - (12.19 SQM)	Office (3)	
B00A - R0022 - Clinic - Girls - (12.55 SQM)	Office (3)	
B00A - R0025 - Clinic - Boys - (12.18 SQM)	Office (3)	
B00A - R0026 - Movement - (10.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Interview/Office - Type 1 - (12.51 SQM)	Office (3)	
B00A - R0028 - Interview/Office - Type 1 - (12.34 SQM)	Office (3)	
B00B - R0001 - Computer Learning Space - (62.19 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0007 - Entry - (24.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Senior Study - (60.89 SQM)	Office (15)	
B00B - R0013 - Movement - (77.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Main Area - (416.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Seminar - (12.03 SQM)	Office (3)	
B00B - R0017 - Seminar - (12.12 SQM)	Office (3)	
B00B - R0018 - Seminar - (12.04 SQM)	Office (3)	
B00B - R0019 - Movement - (7.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (121.13 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - General Learning Space - (59.45 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0004 - Movement - (22.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Computer Learning Space - (67.05 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R0006 - General Learning Space - (58.03 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0007 - Seminar - (24.1 SQM)	Office (6)	
B00C - R0008 - General Learning Space - (57.39 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0009 - General Learning Space - (58.77 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0011 - General Learning Space - (60.07 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0012 - Movement - (36.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (5.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (36.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Shared Learning Space - (103.52 SQM)	Student Space (48)	
B00C - R1001 - Movement - (100.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - General Learning Space - (59.39 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1004 - Movement - (19.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - Computer Learning Space - (66.99 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R1007 - General Learning Space - (58.25 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1008 - Seminar - (24.16 SQM)	Office (6)	
B00C - R1009 - General Learning Space - (57.69 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1010 - General Learning Space - (58.91 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1012 - General Learning Space - (59.55 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1013 - Shared Learning Space - (102.19 SQM)	● Student Space (47)	
B00D - R0001 - Movement - (62.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Design L.S. - (57.6 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0005 - Design/Technology L.S. - (57.44 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0006 - Materials Workshop - Type 3 - (99.16 SQM)	● Student Space (46)	
B00D - R1001 - Movement - (63.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Design/Technology L.S. - (57.22 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1003 - Design/Technology L.S. - (57.22 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1005 - Materials Workshop - Type 3 - (94.73 SQM)	● Student Space (43)	
B00D - R1012 - Metal Technology Bay - (95.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R1014 - Materials Workshop - Type 3 - (118.32 SQM)	● Student Space (54)	
B00D - R1016 - Design/Technology L.S. - (59.93 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1017 - Design/Technology L.S. - (59.86 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1018 - Movement - (50.52 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (140.39 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Movement - (17.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (21.59 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (19.05 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (43.11 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (78.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - Movement - (45.07 SQM)	Not Applicable	Circulation or storage space.
B00E - R1005 - Movement - (8.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R1006 - Performance Workshop - (163.5 SQM)	● Student Space (75)	
B00F - R0003 - Movement - (246.68 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Preparation - (83.16 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Growing/Breeding - (14.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (38.39 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - General Learning Space - (59.51 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0019 - Science Laboratory - (49.73 SQM)	● Student Space (23)	
B00F - R0020 - Science Laboratory - (47.79 SQM)	● Student Space (22)	
B00F - R0021 - General Learning Space - (59.18 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0022 - General Learning Space - (58.71 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0023 - Science Laboratory - (47.79 SQM)	● Student Space (22)	
B00F - R0024 - Science Laboratory - (49.67 SQM)	● Student Space (23)	
B00F - R0025 - General Learning Space - (59.34 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0026 - General Assistants - (16.69 SQM)	● Office (4)	
B00F - R1001 - Movement - (98.45 SQM)	Not Applicable	Circulation or storage space.
B00F - R1002 - Interview/Office - Type 1 - (12.18 SQM)	● Office (3)	
B00F - R1003 - Interview/Office - Type 1 - (11.96 SQM)	● Office (2)	
B00F - R1004 - Duplicating Workroom - (34.32 SQM)	● Office (8)	
B00F - R1006 - Interview/Office - Type 1 - (12.01 SQM)	● Office (3)	
B00F - R1007 - Interview/Office - Type 1 - (12.04 SQM)	● Office (3)	
B00F - R1008 - Movement - (5.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R1010 - Movement - (58.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R1016 - Staff Study - (195.17 SQM)	● Office (48)	
B00F - R1017 - Commonroom - (105.92 SQM)	● Office (26)	
B00F - R1018 - Staff Study - (193.93 SQM)	● Office (48)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0001 - Movement - (33.35 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (41.71 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Study Space - (38.77 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Outdoor Learning Area - (35.83 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Outdoor Learning Area - (35.67 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Movement - (82.14 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Study Space - (9.62 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Special Learning Space - (58.13 SQM) - Teaching Space: 1	 Student Space (26)	
B00G - R0018 - Study Space - (9.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - Special Learning Space - (58.14 SQM) - Teaching Space: 1	 Student Space (26)	
B00G - R0020 - Special Learning Space - (58.8 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R0021 - Study Space - (9.91 SQM)	Not Applicable	Circulation or storage space.
B00G - R0023 - Practical Activity Area - (129.32 SQM)	 Student Space (59)	
B00G - R1001 - Movement - (80.77 SQM)	Not Applicable	Circulation or storage space.
B00G - R1003 - General Learning Space - (59.31 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R1004 - General Learning Space - (58.1 SQM) - Teaching Space: 1	 Student Space (26)	
B00G - R1005 - Seminar - (24.32 SQM)	 Office (6)	
B00G - R1006 - General Learning Space - (57.69 SQM) - Teaching Space: 1	 Student Space (26)	
B00G - R1007 - General Learning Space - (58.82 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R1009 - General Learning Space - (59.47 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R1010 - Movement - (103.67 SQM)	Not Applicable	Circulation or storage space.
B00G - R1011 - General Learning Space - (67.26 SQM) - Teaching Space: 1	 Student Space (31)	
B00G - R1012 - Movement - (21.5 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - General Learning Space - (67.19 SQM) - Teaching Space: 1	 Student Space (31)	
B00H - R0002 - Movement - (22.43 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - General Learning Space - (58.83 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0004 - General Learning Space - (57.53 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R0005 - Seminar - (24.24 SQM)	 Office (6)	
B00H - R0006 - General Learning Space - (58.18 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R0007 - General Learning Space - (59.47 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0009 - General Learning Space - (59.62 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0010 - Movement - (103.94 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Movement - (35.88 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Movement - (35.78 SQM)	Not Applicable	Circulation or storage space.
B00H - R1002 - Movement - (21.83 SQM)	Not Applicable	Circulation or storage space.
B00H - R1003 - General Learning Space - (59.38 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R1004 - General Learning Space - (58.17 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R1005 - Seminar - (24.16 SQM)	 Office (6)	
B00H - R1006 - General Learning Space - (57.7 SQM) - Teaching Space: 1	 Student Space (26)	
B00H - R1007 - General Learning Space - (58.67 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R1009 - General Learning Space - (59.32 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R1010 - Movement - (103.15 SQM)	Not Applicable	Circulation or storage space.
B00H - R1013 - General Learning Space - (67.17 SQM) - Teaching Space: 1	 Student Space (31)	
B00I - R0003 - Movement - (54.68 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - General Learning Space - (57.87 SQM) - Teaching Space: 1	 Student Space (26)	
B00I - R0005 - General Learning Space - (57.95 SQM) - Teaching Space: 1	 Student Space (26)	
B00I - R0007 - Kitchen - Type 1 - (105.91 SQM)	 Student Space (49)	
B00I - R0008 - Food/Research Space - (19.27 SQM)	Not Applicable	Circulation or storage space.
B00I - R0011 - Movement - (16.42 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R1001 - Movement - (54.67 SQM)	Not Applicable	Circulation or storage space.
B00I - R1002 - General Learning Space - (58.23 SQM) - Teaching Space: 1	● Student Space (27)	
B00I - R1003 - General Learning Space - (58.17 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R1005 - Darkroom Space - (26.82 SQM)	● Office (6)	
B00I - R1008 - Multi Media Workshop - (100.75 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (122.04 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Seminar - (18.71 SQM)	● Office (4)	
B00J - R0006 - General Learning Space - (57.24 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0007 - General Learning Space - (56.17 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0008 - Fitness Laboratory - (98.12 SQM)	● Student Space (45)	
B00J - R0015 - Movement - (16.46 SQM)	Not Applicable	Circulation or storage space.
B00J - R0016 - General Assistants - (39.46 SQM)	● Office (9)	
B00J - R1001 - Movement - (18.91 SQM)	Not Applicable	Circulation or storage space.
B00J - R1006 - General Learning Space - (58.17 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R1007 - General Learning Space - (58.16 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R1010 - Practice/Seminar - (18.77 SQM)	Not Applicable	Circulation or storage space.
B00J - R1012 - Performance Workshop - (98.38 SQM)	● Student Space (45)	
B00J - R1014 - Movement - (114.15 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Movement - (98.04 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Gymnasium - (457.59 SQM)	● Student Space (212)	
B00K - R0009 - Stage - (101.83 SQM)	Not Applicable	Circulation or storage space.
B00K - R0010 - Movement - (5.74 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Student Canteen - (51.9 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - General Assistants - (40.43 SQM)	● Office (10)	
B00N - R0001 - Metal Technology Bay - (140.11 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Metal Technology Bay - (8.25 SQM)	Not Applicable	Circulation or storage space.
OS 601 10002 - OS 601 10002 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13053 - OS 601 13053 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 720 10694 - OS 720 10694 - Science Laboratory/Prep Room - (SQM)	Not Applicable	Circulation or storage space.