

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Glenroi Heights Public School (4020)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Orange</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Orange</b>

4020 - Glenroi Heights Public School  
Site Plan (10995)













1:839

Printed: 08-Sep-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (55.42 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0002 - Practical Activities - 1hb - (13.45 SQM)	Student Space (6)	
B00A - R0006 - Home Base - M - (55.57 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0007 - Practical Activities - M - 1hb - (13.9 SQM)	Student Space (6)	
B00A - R0012 - Practical Activities - (69.82 SQM)	Student Space (32)	
B00A - R1001 - Home Base - (55.41 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1002 - Practical Activities - 1hb - (13.44 SQM)	Student Space (6)	
B00A - R1003 - Practical Activities - 1hb - (13.43 SQM)	Student Space (6)	
B00A - R1004 - Home Base - (55.41 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1006 - Home Base - (55.63 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1007 - Practical Activities - 1hb - (14.07 SQM)	Student Space (6)	
B00B - R0002 - Deputy Principal - (14.2 SQM)	Office (3)	
B00B - R0003 - Interview - (14.25 SQM)	Office (3)	
B00B - R0006 - Sick Bay - (9.33 SQM)	Student Space (4)	
B00B - R0008 - Clerical Office/Workroom - (14.69 SQM)	Office (3)	
B00B - R0011 - Principal - (20.44 SQM)	Office (5)	
B00B - R0012 - Movement - (11.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Duplicating Workroom - (16.65 SQM)	Office (4)	
B00B - R0017 - Staff Room - (67.43 SQM)	Office (16)	
B00B - R0019 - Movement - (11.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Entry Vestibule - (13.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Clerical Office - (24.26 SQM)	Office (6)	
B00B - R0024 - Sick Bay - (5.29 SQM)	Student Space (2)	
B00B - R0026 - Movement - (40.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Reading Area - (219.88 SQM)	Student Space (102)	
B00B - R1002 - Seminar/Study - (14.67 SQM)	Office (3)	
B00B - R1003 - Seminar/Study - (14.64 SQM)	Office (3)	
B00B - R1012 - Movement - (23.84 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Communal Space - (222.59 SQM)	Student Space (103)	
B00D - R0008 - Canteen - (28.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (67.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Home Base - (57.86 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0006 - Home Base - (57.78 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0010 - Home Base - (55.33 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0011 - Practical Activities - 1hb - (14.81 SQM)	Student Space (6)	
B00F - R0001 - Movement - (102.66 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Home Base - (56.77 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0005 - Home Base - (55.74 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R0006 - Home Base - (54.07 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R0008 - Home Base - (58.34 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0007 - Movement - (63.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (58.17 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0002 - Practical Activities - 1hb - (14.68 SQM)	Student Space (6)	
B00H - R0003 - Practical Activities - 1hb - (14.44 SQM)	Student Space (6)	
B00H - R0004 - Home Base - (58.09 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0005 - Movement - (160.97 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Home Base - (56.69 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0001 - Home Base - M - (41.81 SQM) - Teaching Space: 1	 Student Space (19)	
B00I - R0005 - Home Base - (39.36 SQM) - Teaching Space: 1	 Student Space (18)	
B00I - R0007 - Home Base - (44.36 SQM) - Teaching Space: 1	 Student Space (20)	
B00I - R0008 - Home Base - (44.67 SQM) - Teaching Space: 1	 Student Space (20)	
B00I - R0010 - Movement - (5.57 SQM)	Not Applicable	Circulation or storage space.
B00I - R0011 - Staff Kitchen - (16.06 SQM)	 Office (4)	
B00I - R0012 - Interview - (18 SQM)	 Office (4)	
B00I - R0014 - Movement - (62.41 SQM)	Not Applicable	Circulation or storage space.
B00I - R0015 - Movement - (5.19 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (90.16 SQM)	Not Applicable	Circulation or storage space.
B00J - R0008 - Movement - (83.39 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Home Base - (85.85 SQM) - Teaching Space: 1	 Student Space (39)	
B00J - R0013 - Home Base - (85.86 SQM) - Teaching Space: 1	 Student Space (39)	
B00J - R0016 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00J - R0022 - Home Base - E - (41.45 SQM) - Teaching Space: 1	 Student Space (19)	
B00J - R0023 - Practical Activities - E - (28.5 SQM)	 Student Space (13)	
B0B1 - R1001 - Movement - (5.19 SQM)	Not Applicable	Circulation or storage space.