

VENTILATION AUDIT REPORT

SCHOOL:	Glenvale School (5627)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Gosford
LOCAL GOVERNMENT AREA:	Central Coast

5627 - Glenvale School
Site Plan (11945)



1:993

Printed: 18-May-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Practical Activities - S - 1hb - (16.88 SQM)	Student Space (7)	
B00A - R0003 - Practical Activities - S - 1hb - (22.33 SQM)	Student Space (10)	
B00A - R0007 - Home Base - S - (58.5 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0008 - Home Base - S - (58.49 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0010 - Withdrawal - S - (5.52 SQM)	Student Space (2)	
B00A - R0012 - Withdrawal - S - (5.29 SQM)	Student Space (2)	
B00B - R0005 - Principal - (17.8 SQM)	Office (4)	
B00B - R0006 - Deputy Principal - (12.68 SQM)	Office (3)	
B00B - R0007 - Duplicating Workroom - (17.56 SQM)	Office (4)	
B00B - R0008 - Movement - (37.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Sick Bay - (16.81 SQM)	Student Space (7)	
B00B - R0015 - Clerical Office - (13.07 SQM)	Office (3)	
B00B - R0016 - Entry Vestibule - (14.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Interview - (11.8 SQM)	Office (2)	
B00B - R0021 - Movement - (8.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Raised Platform - (24.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Communal Space - (98.51 SQM)	Student Space (45)	
B00B - R0025 - Canteen - (16.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Staff Kitchen - (5.31 SQM)	Office (1)	
B00B - R0031 - Special Programs Room - (56.18 SQM)	Student Space (26)	
B00B - R0034 - Home Base - (65.14 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0035 - Movement - (19.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0037 - Home Base - (58.5 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0039 - Withdrawal Space - 1hb - (5.55 SQM)	Student Space (2)	
B00B - R0041 - Withdrawal Space - 1hb - (5.52 SQM)	Student Space (2)	
B00B - R0043 - Home Base - (58.51 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0044 - Practical Activities - 1hb - (39.93 SQM)	Student Space (18)	
B00C - R0003 - Withdrawal - S - (7.36 SQM)	Student Space (3)	
B00C - R0005 - Home Base - S - (62.31 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0006 - Withdrawal - S - (11.69 SQM)	Student Space (5)	
B00C - R0007 - Practical Activity Area - (53.46 SQM)	Student Space (24)	
B00C - R0008 - Staff Kitchen - (11.79 SQM)	Office (2)	
B00C - R0012 - Staff Room - (70.45 SQM)	Office (17)	
B00C - R0020 - Home Base - S - (62.13 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0001 - Withdrawal - S - (7.99 SQM)	Student Space (3)	
B00E - R0002 - Home Base - S - (59.72 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0006 - Practical Activities - S - 1hb - (49.02 SQM)	Student Space (22)	
B00E - R0007 - Outdoor Learning Area - (22.33 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Withdrawal - S - (7.99 SQM)	Student Space (3)	
B00E - R0009 - Home Base - S - (59.71 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0011 - Staff Room Annexe - (36.68 SQM)	Office (9)	
B00E - R0015 - Reading Area - (59.1 SQM)	Student Space (27)	
B00F - R0001 - Withdrawal - S - (7.99 SQM)	Student Space (3)	
B00F - R0002 - Home Base - S - (60.84 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0006 - Practical Activities - E - (49.03 SQM)	Student Space (22)	
B00F - R0008 - Withdrawal - S - (7.99 SQM)	Student Space (3)	
B00F - R0009 - Home Base - E - (62.11 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0002 - Deputy Principal - (11.07 SQM)	Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0004 - Home Base - S - (57.25 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0006 - Withdrawal - S - (11.07 SQM)	● Student Space (5)	
B00G - R0007 - Home Base - S - (58.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0009 - Home Base - S - (58.13 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0011 - Withdrawal - S - (11.01 SQM)	● Student Space (5)	
B00G - R0012 - Home Base - S - (57.71 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0015 - Practical Activities - S - 1hb - (22.53 SQM)	● Student Space (10)	
B00G - R0016 - Clerical Office - (18.14 SQM)	● Office (4)	
B00G - R0017 - Special Programs Room - (68.76 SQM)	● Student Space (31)	
B00L - R0002 - Practical Activities - P - 1hb - (19.37 SQM)	● Student Space (8)	
B00L - R0004 - Home Base - P - (58.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	● Student Space (4)	
B00L - R0006 - Home Base - P - (58.7 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0008 - Practical Activities - P - 1hb - (19.37 SQM)	● Student Space (8)	
B00M - R0001 - Special Programs Room - (34.68 SQM)	● Student Space (16)	
B00O - R0003 - Home Base - (44.55 SQM) - Teaching Space: 1	● Student Space (20)	
B00O - R0004 - Home Base - (44.49 SQM) - Teaching Space: 1	● Student Space (20)	
B00O - R0007 - Staff Kitchen - (9.38 SQM)	● Office (2)	
B00P - R0001 - Clerical Office - (14.99 SQM)	● Office (3)	
B00P - R0002 - Movement - (10.4 SQM)	Not Applicable	Circulation or storage space.
B00P - R0004 - Clerical Office - (18.66 SQM)	● Office (4)	
B00P - R0005 - Staff Room - (21.13 SQM)	● Office (5)	
B00S - R0001 - Movement - (41.31 SQM)	Not Applicable	Circulation or storage space.
B00S - R0002 - Clerical Office - (20.92 SQM)	● Office (5)	
B00S - R0003 - Clerical/Printing - (11.25 SQM)	Not Applicable	Circulation or storage space.
B00S - R0004 - Principal - (15.49 SQM)	● Office (3)	
B00S - R0007 - Deputy Principal - (13.16 SQM)	● Office (3)	
B00S - R0008 - Interview - (13.51 SQM)	● Office (3)	
B00S - R0010 - Sick Bay - (10.03 SQM)	● Student Space (4)	
B00S - R0017 - Staff Room - (36.84 SQM)	● Office (9)	
B00S - R0020 - Practical Activities - P - 1hb - (10.07 SQM)	● Student Space (4)	
B00S - R0021 - Home Base - P - (59.17 SQM) - Teaching Space: 1	● Student Space (27)	
B00S - R0025 - Home Base - M - (56.93 SQM) - Teaching Space: 1	● Student Space (26)	
B00S - R0026 - Practical Activities - M - 1hb - (10.02 SQM)	● Student Space (4)	
OS 505 13421 - OS 505 13421 - Admin Staff/Principal/Secure Store - (76 SQM)	● Office (19)	
OS 601 13961 - OS 601 13961 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 621 14501 - OS 621 14501 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	
OS 621 15608 - OS 621 15608 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	
OS 621 16790 - OS 621 16790 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	
OS 710 11649 - OS 710 11649 - Home Science/Pantry/Laundry - (95 SQM)	● Office (23)	