


VENTILATION AUDIT REPORT

SCHOOL:	Glenwood High School (8268)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Riverstone
LOCAL GOVERNMENT AREA:	Blacktown

8268 - Glenwood High School
Site Plan (14600)



1:1,471

Printed: 21-Mar-2020


Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Movement - (27.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Seminar - Type 1 - (31.61 SQM)	Office (7)	
B00A - R0013 - General Learning Space - S/P - (58.98 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0014 - General Learning Space - Type 2 - (65.24 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0015 - Movement - (82.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - General Learning Space - Type 1 - (58.93 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0018 - Movement - (25.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - General Learning Space - S/P - (59.37 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0022 - Movement - (51.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Practical Activity Area - (60.03 SQM)	Student Space (27)	
B00A - R0024 - Movement - (22.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - General Learning Space - S/P - (56.91 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1001 - General Learning Space - Type 1 - (59.84 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1003 - Movement - (9.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R1005 - General Learning Space - Type 1 - (60.53 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1006 - Shared Learning Space - (44.73 SQM)	Student Space (20)	
B00A - R1007 - General Learning Space - Type 2 - (66.16 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1008 - Movement - (102.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Movement - (53.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - General Learning Space - Type 1 - (59.09 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1015 - General Learning Space - Type 1 - (59.09 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1016 - Seminar - Type 1 - (24.55 SQM)	Office (6)	
B00A - R1017 - General Learning Space - Type 1 - (59.17 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0001 - General Learning Space - Type 1 - (60.21 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0003 - Movement - (23.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - General Learning Space - Type 1 - (59.77 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0006 - General Learning Space - Type 1 - (59.04 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0007 - Seminar - Type 1 - (24.58 SQM)	Office (6)	
B00B - R0008 - General Learning Space - Type 1 - (59.43 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0009 - General Learning Space - Type 1 - (58.77 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0013 - Movement - (115.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (90.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - General Learning Space - Type 2 - (62.66 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0019 - Shared Learning Space - (43.11 SQM)	Student Space (20)	
B00B - R0020 - Movement - (15.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - General Learning Space - Type 1 - (60.28 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1003 - Movement - (10.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R1005 - General Learning Space - Type 1 - (59.75 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1006 - General Learning Space - Type 1 - (59.08 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1007 - Seminar - Type 1 - (24.55 SQM)	Office (6)	
B00B - R1008 - General Learning Space - Type 1 - (59.01 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1009 - General Learning Space - Type 1 - (59.26 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1016 - Movement - (97.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R1018 - Movement - (96.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R1019 - General Learning Space - Type 2 - (65.46 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1020 - Shared Learning Space - (43.87 SQM)	Student Space (20)	
B00C - R0001 - Movement - (173.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Fitness Laboratory - (98.36 SQM)	Student Space (45)	
B00C - R0003 - General Learning Space - Type 1 - (60.27 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0004 - General Learning Space - Type 1 - (58.59 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0010 - Seminar - Type 2 - (19.26 SQM)	Office (4)	
B00C - R1001 - General Learning Space - Type 1 - (59.09 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1004 - General Learning Space - Type 1 - (60.34 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1005 - Shared Learning Space - (49.19 SQM)	Student Space (22)	
B00C - R1006 - Movement - (76.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R1007 - Movement - (5.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - General Learning Space - Type 1 - (58.93 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1013 - Seminar - Type 1 - (24.59 SQM)	Office (6)	
B00C - R1014 - General Learning Space - Type 1 - (59.01 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0001 - Movement - (360.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Interview/Office - Type 1 - (12.76 SQM)	Office (3)	
B00D - R0004 - Interview/Office - Type 1 - (12.5 SQM)	Office (3)	
B00D - R0008 - Principal Office - (19.13 SQM)	Office (4)	
B00D - R0009 - Movement - (7.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Administration - Clerical - (96.21 SQM)	Office (24)	
B00D - R0011 - Deputy Principal Office - (13.16 SQM)	Office (3)	
B00D - R0012 - Deputy Principal Office - (13.19 SQM)	Office (3)	
B00D - R0013 - Clinic - Girls - (13.12 SQM)	Office (3)	
B00D - R0015 - Clinic - Boys - (12.88 SQM)	Office (3)	
B00D - R0016 - Interview/Office - Type 2 - (13.69 SQM)	Office (3)	
B00D - R0017 - Student Reception - (50.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Tea Room - (5.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Visitors Office - (13.9 SQM)	Office (3)	
B00D - R0023 - Public Reception - (40.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - General Learning Space - Type 1 - (60.36 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R1003 - Movement - (16.17 SQM)	Not Applicable	Circulation or storage space.
B00D - R1005 - General Learning Space - Type 1 - (59.69 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1006 - General Learning Space - Type 1 - (59.18 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1007 - Seminar - Type 1 - (24.52 SQM)	Office (6)	
B00D - R1008 - General Learning Space - Type 1 - (58.38 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1009 - General Learning Space - Type 1 - (59.01 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1013 - Movement - (98.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R1014 - Movement - (41.8 SQM)	Not Applicable	Circulation or storage space.
B00D - R1015 - General Learning Space - Type 2 - (65.72 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1016 - Shared Learning Space - (43.4 SQM)	Student Space (20)	
B00E - R0001 - Movement - (183.44 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - General Learning Space - Type 3 - (59.9 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0004 - Preparation - Science - (73.28 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - General Learning Space - Type 3 - (59.52 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0007 - General Learning Space - Type 3 - (59.53 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0012 - Seminar - Type 2 - (19.7 SQM)	Office (4)	
B00E - R0014 - General Learning Space - Type 3 - (59.42 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0015 - Science Laboratory - (50.42 SQM)	Student Space (23)	
B00E - R0016 - Science Laboratory - (50.42 SQM)	Student Space (23)	
B00E - R0017 - General Learning Space - Type 10 - (50.42 SQM) - Teaching Space: 0.5	Student Space (23)	
B00E - R0018 - General Learning Space - Type 10 - (50.43 SQM) - Teaching Space: 0.5	Student Space (23)	
B00E - R1001 - Movement - (122.18 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1002 - Senior Study - (62.8 SQM)	Office (15)	
B00E - R1004 - Main Area - (427.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R1005 - Main Entry - (23.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R1010 - Seminar - Type 3 - (12.81 SQM)	Office (3)	
B00E - R1011 - Seminar - Type 3 - (12.62 SQM)	Office (3)	
B00E - R1012 - Seminar - Type 3 - (12.99 SQM)	Office (3)	
B00E - R1016 - Computer Learning Space - (64.73 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0001 - Movement - (176.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Interview/Meeting - (12.48 SQM)	Office (3)	
B00F - R0005 - Interview/Meeting - (12.57 SQM)	Office (3)	
B00F - R0007 - Interview/Meeting - (12.48 SQM)	Office (3)	
B00F - R0008 - Interview/Meeting - (12.51 SQM)	Office (3)	
B00F - R0009 - Movement - (93.39 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Staff Study - (199.96 SQM)	Office (49)	
B00F - R0011 - Movement - (27.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Staff Lounge - (107.92 SQM)	Office (26)	
B00F - R0021 - Staff Study - (201.28 SQM)	Office (50)	
B00G - R0001 - Movement - (200.28 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - General Learning Space - Type 7 - (59.5 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0006 - General Learning Space - Type 6 - (59.48 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0007 - Seminar - Type 2 - (19.69 SQM)	Office (4)	
B00G - R0008 - General Learning Space - Type 6 - (59.4 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0009 - General Learning Space - Type 7 - (58.85 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0012 - Kitchen - Type 1 - (99.64 SQM)	Student Space (46)	
B00G - R0013 - Preparation - Materials - (29.31 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Kitchen - Type 1 - (100.14 SQM)	Student Space (46)	
B00H - R0001 - Movement - (397.69 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - General Learning Space - Type 8 - (60.79 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0005 - General Learning Space - Type 9 - (61.04 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0006 - General Learning Space - Type 9 - (60.94 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0007 - General Learning Space - Type 8 - (60.94 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0011 - Welding/Hot Metals Area - (10.66 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Outdoor Workshop - (88.29 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Materials Workshop - Type 2 - (174.16 SQM)	Student Space (80)	
B00H - R0018 - Materials Workshop - Type 2 - (173.95 SQM)	Student Space (80)	
B00J - R0002 - Student Canteen - (54.41 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Performance Workshop - (98.34 SQM)	Student Space (45)	
B00J - R0007 - Practice/Seminar - (19.75 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Visual Arts Workshop - (139.47 SQM)	Student Space (64)	
B00J - R0013 - Movement - (10.24 SQM)	Not Applicable	Circulation or storage space.
B00J - R0015 - Dark Room - (27.85 SQM)	Office (6)	
B00J - R0016 - General Learning Space - Type 5 - (60.69 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0017 - General Learning Space - Type 4 - (60.7 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0018 - General Learning Space - Type 1 - (59.85 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0019 - General Learning Space - Type 1 - (59.69 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0001 - Movement - (417.85 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Movement - (18.98 SQM)	Not Applicable	Circulation or storage space.
B00K - R0009 - Stage - (96.84 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Gymnasium - (622.6 SQM)	Student Space (288)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0020 - General Assistants - (12.7 SQM)	 Office (3)	