

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Glenwood Public School (4529)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Macquarie Fields</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Campbelltown</b>

4529 - Glenwood Public School  
Site Plan (12718)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Kitchen - (16.65 SQM)	Office (4)	
B00A - R0002 - Staff Room - (36.35 SQM)	Office (9)	
B00A - R0006 - Staff Room Annexe - (12.36 SQM)	Office (3)	
B00A - R0007 - Staff Room Annexe - (13.14 SQM)	Office (3)	
B00A - R0008 - Interview - (12.15 SQM)	Office (3)	
B00A - R0009 - Duplicating Workroom - (21.76 SQM)	Office (5)	
B00A - R0010 - Clerical Office - (13.08 SQM)	Office (3)	
B00A - R0011 - Sick Bay - (8.12 SQM)	Student Space (3)	
B00A - R0012 - Principal - (19.27 SQM)	Office (4)	
B00A - R0020 - Movement - (27.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Entry Vestibule - (14.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Movement - (45.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Special Programs Room - (52.3 SQM)	Student Space (24)	
B00B - R0005 - Reading Area - (67.16 SQM)	Student Space (31)	
B00B - R0006 - Reading Area - (102.23 SQM)	Student Space (47)	
B00B - R0014 - Movement - (23.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Movement - (6.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Canteen - (31.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Raised Platform - (38.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Communal Space - (152.44 SQM)	Student Space (70)	
B00D - R0004 - Practical Activities - 1hb - (54.69 SQM)	Student Space (25)	
B00D - R0006 - Home Base - (59.79 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0007 - Withdrawal Space - 1hb - (12.25 SQM)	Student Space (5)	
B00D - R0008 - Home Base - (59.95 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0001 - Practical Activities - 1hb - (54.5 SQM)	Student Space (25)	
B00E - R0004 - Home Base - (59.77 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0005 - Withdrawal Space - 1hb - (12.25 SQM)	Student Space (5)	
B00E - R0006 - Home Base - (59.7 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0008 - Withdrawal Space - 1hb - (17.9 SQM)	Student Space (8)	
B00E - R0009 - Movement - (18.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Practical Activities - 1hb - (55.44 SQM)	Student Space (25)	
B00E - R0014 - Home Base - (59.75 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0015 - Withdrawal Space - 1hb - (12.25 SQM)	Student Space (5)	
B00E - R0017 - Home Base - (59.75 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0024 - Movement - (34.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Movement - (11.16 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Practical Activities - 1hb - (54.49 SQM)	Student Space (25)	
B00F - R0003 - Home Base - (60.09 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0005 - Withdrawal Space - 1hb - (12.25 SQM)	Student Space (5)	
B00F - R0006 - Home Base - (60.2 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0008 - Special Programs Room - (17.82 SQM)	Student Space (8)	
B00F - R0009 - Movement - (18.05 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Movement - (33.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (9.01 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (9.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Practical Activities - 1hb - (19.79 SQM)	Student Space (9)	
B00G - R0002 - Home Base - (60.61 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0004 - Withdrawal Space - 2hb - (11.78 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0005 - Practical Activities - 1hb - (19.77 SQM)	● Student Space (9)	
B00G - R0006 - Home Base - (60.61 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0008 - Practical Activities - 1hb - (19.22 SQM)	● Student Space (8)	
B00G - R0009 - Home Base - (60.61 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0011 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00G - R0012 - Practical Activities - 1hb - (19.77 SQM)	● Student Space (9)	
B00G - R0013 - Home Base - (60.61 SQM) - Teaching Space: 1	● Student Space (28)	