

VENTILATION AUDIT REPORT

SCHOOL:	Glossodia Public School (2021)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Hawkesbury
LOCAL GOVERNMENT AREA:	Hawkesbury

2021 - Glossodia Public School
Site Plan (11768)














1:1,074

Printed: 30-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Movement - (12.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Raised Platform - (41.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Communal Space - (213.6 SQM)	● Student Space (99)	
B00A - R0022 - Movement - (6.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (44.83 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (70.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Canteen - (28.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Staff Room Annexe - (18.78 SQM)	● Office (4)	
B00C - R0002 - Staff Room - (47.28 SQM)	● Office (11)	
B00C - R0003 - Deputy Principal - (12.66 SQM)	● Office (3)	
B00C - R0004 - Principal - (17.07 SQM)	● Office (4)	
B00C - R0006 - Duplicating Workroom - (21.04 SQM)	● Office (5)	
B00C - R0007 - Entry Vestibule - (18.31 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Movement - (5.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Clerical Office - (17.89 SQM)	● Office (4)	
B00C - R0011 - Sick Bay - (8.37 SQM)	● Student Space (3)	
B00C - R0013 - Interview - (12.78 SQM)	● Office (3)	
B00C - R0014 - Deputy Principal - (12.66 SQM)	● Office (3)	
B00C - R0018 - Movement - (34.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (5.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Movement - (7.16 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Reading Area - (50.3 SQM)	● Student Space (23)	
B00D - R0004 - Special Programs Room - (35.29 SQM)	● Student Space (16)	
B00D - R0007 - Movement - (42.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Reading Area - (110.97 SQM)	● Student Space (51)	
B00D - R0013 - Special Programs Room - (46.62 SQM)	● Student Space (21)	
B00D - R0014 - Special Programs Room - (20.42 SQM)	● Student Space (9)	
B00E - R0001 - Movement - (166.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (20.67 SQM)	● Student Space (9)	
B00E - R0003 - Home Base - (57.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0005 - Withdrawal Space - 1hb - (11.16 SQM)	● Student Space (5)	
B00E - R0009 - Practical Activities - 1hb - (20.68 SQM)	● Student Space (9)	
B00E - R0010 - Home Base - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0011 - Home Base - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0012 - Practical Activities - 1hb - (20.75 SQM)	● Student Space (9)	
B00E - R0015 - Withdrawal Space - 1hb - (5.92 SQM)	● Student Space (2)	
B00E - R0016 - Movement - (20.43 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - Practical Activities - 1hb - (20.7 SQM)	● Student Space (9)	
B00E - R1003 - Home Base - (57.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R1005 - Withdrawal Space - 1hb - (11.09 SQM)	● Student Space (5)	
B00E - R1009 - Practical Activities - 1hb - (20.67 SQM)	● Student Space (9)	
B00E - R1010 - Home Base - (57.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R1011 - Home Base - (57.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R1012 - Practical Activities - 1hb - (20.85 SQM)	● Student Space (9)	
B00E - R1015 - Withdrawal Space - 1hb - (5.94 SQM)	● Student Space (2)	
B00E - R1016 - Special Programs Room - (37.23 SQM)	● Student Space (17)	
B00E - R1019 - Movement - (101.1 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (63.27 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Withdrawal Space - 1hb - (5.96 SQM)	● Student Space (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0008 - Home Base - (58 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0009 - Practical Activities - 1hb - (20.69 SQM)	 Student Space (9)	
B00F - R0010 - Practical Activities - 1hb - (20.7 SQM)	 Student Space (9)	
B00F - R0011 - Home Base - (58 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0012 - Withdrawal Space - 1hb - (5.92 SQM)	 Student Space (2)	
B00F - R1001 - Movement - (48.6 SQM)	Not Applicable	Circulation or storage space.
B00F - R1007 - Withdrawal Space - 1hb - (5.93 SQM)	 Student Space (2)	
B00F - R1008 - Home Base - (58 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R1009 - Practical Activities - 1hb - (20.72 SQM)	 Student Space (9)	
B00F - R1010 - Practical Activities - 1hb - (20.7 SQM)	 Student Space (9)	
B00F - R1011 - Home Base - (58 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R1012 - Withdrawal Space - 1hb - (5.93 SQM)	 Student Space (2)	