

VENTILATION AUDIT REPORT

SCHOOL:	Goodooga Central School (2033)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Brewarrina

2033 - Goodooga Central School
Site Plan (14738)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0001 - Craft Room - (37.59 SQM)	Office (9)	
B00C - R0001 - Home Base - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0010 - Food Technology L.S. - (66.12 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0011 - Staff Kitchen - (12.48 SQM)	Office (3)	
B00E - R0012 - Staff Room Annexe - (12.48 SQM)	Office (3)	
B00E - R0013 - Movement - (6.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Staff Room Annexe - (25.54 SQM)	Office (6)	
B00E - R0021 - Staff Room Annexe - (26.35 SQM)	Office (6)	
B00E - R0022 - General Learning Space - (52.7 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0029 - General Learning Space - (52.84 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0030 - Computer Learning Space - (39.41 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R0031 - General Learning Space - (52.69 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0032 - General Learning Space - (50.87 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0001 - Home Base - (57.14 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0002 - Practical Activities - 1hb - (19.87 SQM)	Student Space (9)	
B00F - R0005 - Withdrawal Space - 1hb - (11.72 SQM)	Student Space (5)	
B00F - R0007 - Home Base - (57.34 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0008 - Practical Activities - 1hb - (19.94 SQM)	Student Space (9)	
B00F - R0009 - Home Base - (63.21 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0010 - Practical Activities - 1hb - (19.95 SQM)	Student Space (9)	
B00F - R0014 - Interview - (12.54 SQM)	Office (3)	
B00G - R0007 - General Learning Space - (66.25 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R0010 - Staff Room - (15.82 SQM)	Office (3)	
B00G - R0011 - Practical Activities - (66.25 SQM)	Student Space (30)	
B00K - R0002 - Main Area - (91.79 SQM)	Not Applicable	Circulation or storage space.
OS 502 14352 - OS 502 14352 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	Office (38)	
OS 712 17743 - OS 712 17743 - TTC/Hospitality - (57 SQM)	Student Space (26)	
OS 771 13387 - OS 771 13387 - TTC/Metal Technology - (57 SQM)	Student Space (26)	
OS 780 10986 - OS 780 10986 - Woodwork/Metalwork/Heat Area/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 811 10995 - OS 811 10995 - FSU/Shelter/Stores - (209 SQM)	Not Applicable	Circulation or storage space.