



# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Goonellabah Public School (2041)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lismore</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lismore</b>

2041 - Goonellabah Public School  
Site Plan (12722)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Special Programs Room - (38.53 SQM)	● Student Space (17)	
B00A - R0003 - Reading Area - (227.96 SQM)	● Student Space (105)	
B00A - R0005 - Seminar/Study - (11.79 SQM)	● Office (2)	
B00A - R0006 - Seminar/Study - (15.41 SQM)	● Office (3)	
B00A - R0009 - Movement - (26.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Deputy Principal - (12.15 SQM)	● Office (3)	
B00A - R0014 - Deputy Principal - (12.11 SQM)	● Office (3)	
B00A - R0015 - Duplicating Workroom - (32.37 SQM)	● Office (8)	
B00A - R0016 - Clerical Office - (11.83 SQM)	● Office (2)	
B00A - R0017 - Principal - (20.42 SQM)	● Office (5)	
B00A - R0018 - Sick Bay - (12.04 SQM)	● Student Space (5)	
B00A - R0019 - Entry Vestibule - (20.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (5.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Clerical Office - (12.96 SQM)	● Office (3)	
B00A - R0023 - Canteen - (34.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Raised Platform - (67.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Communal Space - (218.61 SQM)	● Student Space (101)	
B00A - R0042 - Movement - (24.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0047 - Staff Room - (63.73 SQM)	● Office (15)	
B00A - R0048 - Staff Kitchen - (11.68 SQM)	● Office (2)	
B00B - R0001 - Movement - (8.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (56.49 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0006 - Withdrawal Space - 1hb - (8.31 SQM)	● Student Space (3)	
B00B - R0009 - Staff Room Annexe - (13.61 SQM)	● Office (3)	
B00B - R0012 - Practical Activities - 1hb - (12.97 SQM)	● Student Space (6)	
B00B - R0013 - Home Base - S - (57.07 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0015 - Movement - (9.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (13.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Home Base - (56.18 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0018 - Withdrawal Space - 1hb - (8.31 SQM)	● Student Space (3)	
B00B - R0022 - Movement - (7.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Withdrawal - Pre - (30.95 SQM)	● Student Space (14)	
B00C - R0001 - Movement - (103.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (52.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0003 - Practical Activities - 1hb - (19.3 SQM)	● Student Space (8)	
B00C - R0006 - Practical Activities - 1hb - (15.36 SQM)	● Student Space (7)	
B00C - R0007 - Home Base - (85.32 SQM) - Teaching Space: 1	● Student Space (39)	
B00C - R0008 - Home Base - (83.73 SQM) - Teaching Space: 1	● Student Space (38)	
B00C - R0009 - Practical Activities - 1hb - (15.43 SQM)	● Student Space (7)	
B00C - R0013 - Movement - (8.35 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Movement - (87.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R1005 - Interview - (15.07 SQM)	● Office (3)	
B00C - R1006 - Withdrawal Space - 1hb - (15.19 SQM)	● Student Space (7)	
B00C - R1008 - Home Base - (58.92 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1009 - Practical Activities - 1hb - (18.98 SQM)	● Student Space (8)	
B00C - R1011 - Practical Activities - 1hb - (18.98 SQM)	● Student Space (8)	
B00C - R1012 - Home Base - (59.1 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1013 - Home Base - (58.68 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1014 - Practical Activities - 1hb - (19.36 SQM)	● Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R9001 - Movement - (37.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R9004 - Special Programs Room - (60.64 SQM)	● Student Space (28)	
B00D - M0003 - Movement - (6.34 SQM)	Not Applicable	Circulation or storage space.
B00D - M0004 - Movement - (6.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (143.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - (54.38 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0005 - Movement - (13.76 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Home Base - (54.46 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0008 - Practical Activities - 1hb - (16.2 SQM)	● Student Space (7)	
B00D - R0011 - Home Base - (51.89 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0013 - Movement - (15.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Movement - (116.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - Practical Activities - 1hb - (13.92 SQM)	● Student Space (6)	
B00D - R1004 - Home Base - (60.94 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1005 - Home Base - (55.79 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1007 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R1008 - Home Base - (55.79 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1010 - Movement - (12.44 SQM)	Not Applicable	Circulation or storage space.
B00D - R1013 - Home Base - (56.02 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1014 - Home Base - (56.18 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1016 - Movement - (6.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Staff Room Annexe - (23.64 SQM)	● Office (5)	
B00E - R0002 - Movement - (10.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Home Base - (94.41 SQM) - Teaching Space: 1	● Student Space (43)	
B00E - R0004 - Practical Activities - 1hb - (14.18 SQM)	● Student Space (6)	
B00E - R0005 - Staff Room Annexe - (13.82 SQM)	● Office (3)	
B00E - R0006 - Staff Room Annexe - (13.68 SQM)	● Office (3)	
B00E - R0007 - Withdrawal Space - 1hb - (15.01 SQM)	● Student Space (6)	
B00E - R1001 - Home Base - (52.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1002 - Practical Activities - 1hb - (41.85 SQM)	● Student Space (19)	
B00E - R1004 - Home Base - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1005 - Movement - (17.07 SQM)	Not Applicable	Circulation or storage space.
B00E - R1011 - Practical Activities - 1hb - (27.67 SQM)	● Student Space (12)	
B00E - R1012 - Home Base - (58.79 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1013 - Movement - (9.9 SQM)	Not Applicable	Circulation or storage space.