


VENTILATION AUDIT REPORT

SCHOOL:	Gordon East Public School (3985)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Davidson
LOCAL GOVERNMENT AREA:	Ku-Ring-Gai

3985 - Gordon East Public School
Site Plan (12723)




1:973

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (57.35 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0004 - Movement - (5.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Home Base - (57.43 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0010 - Movement - (46.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (32.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (42.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Clerical Office - (14.74 SQM)	Office (3)	
B00B - R0019 - Clerical Office - (9.78 SQM)	Office (2)	
B00B - R0020 - Principal - (20.82 SQM)	Office (5)	
B00B - R0023 - Sick Bay - (6.52 SQM)	Student Space (3)	
B00B - R0024 - Clerical/Printing - (12.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Clerical Office - (15.87 SQM)	Office (3)	
B00B - R0026 - Movement - (23.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Staff Room - (47.25 SQM)	Office (11)	
B00C - R0001 - Reading Area - (109.1 SQM)	Student Space (50)	
B00C - R0004 - Movement - (52.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Special Programs Room - (36.84 SQM)	Student Space (17)	
B00D - R0003 - Home Base - (64.83 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0005 - Home Base - (67.12 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0008 - Movement - (5.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Special Programs Room - (17.11 SQM)	Student Space (7)	
B00D - R0017 - Movement - (7.61 SQM)	Not Applicable	Circulation or storage space.
B00G - M0001 - Communal Space - (38.79 SQM)	Student Space (17)	
B00G - R0002 - Movement - (82.21 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Canteen - (19.15 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Staff Kitchen - (9.65 SQM)	Office (2)	
B00G - R0013 - Communal Space - (173.31 SQM)	Student Space (80)	
B00G - R0020 - Raised Platform - (28.19 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Home Base - (58.06 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0003 - Withdrawal Space - 1hb - (5.84 SQM)	Student Space (2)	
B00H - R0005 - Practical Activities - 1hb - (15.79 SQM)	Student Space (7)	
B00H - R0006 - Home Base - (63.19 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0007 - Practical Activities - 1hb - (17.19 SQM)	Student Space (7)	
B00H - R0008 - Withdrawal Space - 1hb - (5.87 SQM)	Student Space (2)	
B00H - R0011 - Movement - (55.1 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Staff Kitchen - (8.47 SQM)	Office (2)	
B00I - R0004 - Clerical Office - (8.15 SQM)	Office (2)	
B00J - R0002 - Practical Activities - (19.87 SQM)	Student Space (9)	
B00J - R0004 - Home Base - (60.26 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0005 - Withdrawal Space - 2hb - (11.59 SQM)	Student Space (5)	
B00J - R0006 - Practical Activities - 2hb - (19 SQM)	Student Space (8)	
B00J - R0007 - Home Base - (60.82 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0009 - Practical Activities - (18.93 SQM)	Student Space (8)	
B00J - R0011 - Home Base - (60.59 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0012 - Withdrawal Space - 2hb - (11.63 SQM)	Student Space (5)	
B00J - R0013 - Practical Activities - (19.92 SQM)	Student Space (9)	
B00J - R0014 - Home Base - (60.4 SQM) - Teaching Space: 1	Student Space (28)	
OS 602 10725 - OS 602 10725 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14230 - OS 602 14230 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 603 12512 - OS 603 12512 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	