


VENTILATION AUDIT REPORT

SCHOOL:	Gordon West Public School (3943)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Ku-Ring-Gai
LOCAL GOVERNMENT AREA:	Ku-Ring-Gai

3943 - Gordon West Public School
Site Plan (10389)



1:943

Printed: 05-Jun-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (68.71 SQM)	Office (17)	
B00A - R0005 - Movement - (6.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Principal - (20.07 SQM)	Office (5)	
B00A - R0008 - Clerical Office - (20.07 SQM)	Office (5)	
B00A - R0011 - Duplicating Workroom - (20.07 SQM)	Office (5)	
B00A - R0017 - Home Base - (68.15 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0018 - Home Base - (67.67 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0021 - Movement - (6.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Home Base - (68.81 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R0027 - Entry Vestibule - (13.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (6.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Home Base - (64.98 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0005 - Home Base - (94.06 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0011 - Outdoor Learning Area - (138.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (53.51 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0005 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0006 - Withdrawal Space - 1hb - (12.76 SQM)	Student Space (5)	
B00C - R0007 - Interview - (9.33 SQM)	Office (2)	
B00C - R0008 - Home Base - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0009 - Home Base - (53.73 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0018 - Staff Kitchen - (7.25 SQM)	Office (1)	
B00D - R0001 - Home Base - (53.29 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0002 - Home Base - (40.5 SQM) - Teaching Space: 1	Student Space (18)	
B00D - R0003 - Practical Activities - 1hb - (12.49 SQM)	Student Space (5)	
B00D - R0005 - Movement - (26.35 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (54.24 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0002 - Home Base - (54.16 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R0001 - Communal Space - (235.11 SQM)	Student Space (109)	
B00F - R0005 - Raised Platform - (72.62 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Home Base - (88.42 SQM) - Teaching Space: 1	Student Space (41)	
B00G - R0006 - Movement - (6.1 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Special Programs Room - (66.6 SQM)	Student Space (30)	
B00I - R0002 - Practical Activities - 1hb - (19.39 SQM)	Student Space (8)	
B00I - R0004 - Home Base - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	Student Space (5)	
B00I - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0008 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00M - R0002 - Canteen - (26.29 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Special Programs Room - Type 1 - (36.12 SQM)	Student Space (16)	
B00N - R0011 - Reading Area - (230.88 SQM)	Student Space (107)	
B00N - R1002 - Home Base - (58.95 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R1004 - Practical Activities - (19.98 SQM)	Student Space (9)	
B00N - R1005 - Withdrawal Space - 1hb - (9.18 SQM)	Student Space (4)	
B00N - R1007 - Home Base - (60.27 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R1008 - Practical Activities - (18.94 SQM)	Student Space (8)	
B00N - R1009 - Withdrawal Space - 2hb - (11.61 SQM)	Student Space (5)	
B00N - R1010 - Home Base - (60.33 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R1012 - Practical Activities - (18.91 SQM)	● Student Space (8)	
OS 601 12319 - OS 601 12319 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 12651 - OS 602 12651 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14332 - OS 602 14332 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16324 - OS 602 16324 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	