

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Gorokan High School (8515)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Wyong</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

8515 - Gorokan High School  
Site Plan (10997)



1:1,559

Printed: 03-Oct-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal Office - (22.79 SQM)	Office (5)	
B00A - R0002 - Deputy Principal Office - (16.16 SQM)	Office (4)	
B00A - R0009 - Deputy Principal Office - (13 SQM)	Office (3)	
B00A - R0021 - Interview/Office - Type 1 - (13.08 SQM)	Office (3)	
B00A - R0022 - Administration - Executive - (13.08 SQM)	Office (3)	
B00A - R0023 - Clinic - Boys - (13.04 SQM)	Office (3)	
B00A - R0024 - Public Reception - (47.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Student Waiting - (46.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Laboratory L.S. - (90.9 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0028 - Preparation - Science - (47.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Laboratory L.S. - (90.91 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0043 - Interview/Office - Type 1 - (21.29 SQM)	Office (5)	
B00A - R0044 - Administration - Clerical - (13.08 SQM)	Office (3)	
B00A - R0050 - Commonroom - (100.28 SQM)	Office (25)	
B00A - R0051 - Staff Kitchen - (13.11 SQM)	Office (3)	
B00A - R0052 - Administration - Clerical - (43.32 SQM)	Office (10)	
B00A - R0053 - Interview/Meeting - (10.14 SQM)	Office (2)	
B00A - R0054 - General Learning Space - (69.99 SQM) - Teaching Space: 1	Student Space (32)	
B00A - R1001 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1002 - General Learning Space - (52.67 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1004 - General Learning Space - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1005 - General Learning Space - (51.66 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1009 - Laboratory L.S. - (91.29 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R1010 - Preparation - Science - (46.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Laboratory L.S. - (91.28 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R1017 - General Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1018 - General Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1020 - General Learning Space - (52.59 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1021 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1034 - Staff Study - (38.34 SQM)	Office (9)	
B00A - R1036 - Staff Study - (52.9 SQM)	Office (13)	
B00B - R0001 - Student Canteen - (73.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Multi-Purpose Space - (458.79 SQM)	Student Space (212)	
B00B - R0013 - Movement - (23.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Dark Room - (9.74 SQM)	Office (2)	
B00B - R1001 - Music Learning Space - (70.87 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R1002 - Music Learning Space - (91.77 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R1004 - Food Technology L.S. - (101.27 SQM) - Teaching Space: 1	Student Space (46)	
B00B - R1009 - Food Technology L.S. - (97.53 SQM) - Teaching Space: 1	Student Space (45)	
B00B - R1023 - Preparation - Materials - (17.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R1026 - Coffee Kiosk - (69.8 SQM)	Not Applicable	Circulation or storage space.
B00C - M0003 - Workshop - (15.68 SQM)	Student Space (7)	
B00C - M0004 - Main Area - (232.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Interview/Office - Type 1 - (8.96 SQM)	Office (2)	
B00C - R0003 - Main Area - (221.96 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Audio Visual Workroom - (24.75 SQM)	Student Space (11)	
B00C - R0007 - Main Entry - (42.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Interview/Office - Type 1 - (11.56 SQM)	Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0023 - Seminar - (21.83 SQM)	Office (5)	
B00D - R0004 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0005 - General Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0007 - General Learning Space - (52.67 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0010 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0016 - General Learning Space - (52.96 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0017 - General Learning Space - (52.89 SQM)	Student Space (24)	
B00D - R0019 - Movement - (6.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0029 - Senior Study - (84.05 SQM)	Office (21)	
B00D - R0033 - Staff Study - (36.18 SQM)	Office (9)	
B00D - R0038 - General Learning Space - Bd/Cd/Ed - (51.63 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0039 - Commonroom - (21.43 SQM)	Office (5)	
B00D - R0040 - General Learning Space - Bd/Cd/Ed - (55.95 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0041 - General Learning Space - Bd/Cd/Ed - (62.71 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0042 - Movement - (17.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0044 - Staff Study - (25.35 SQM)	Office (6)	
B00D - R0045 - Staff Kitchen - (7.93 SQM)	Office (1)	
B00D - R0048 - Special Learning Space - (51.6 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1004 - Leading Teacher - (19.63 SQM)	Office (4)	
B00D - R1007 - General Learning Space - (52.67 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1010 - Computer Learning Space - (52.81 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1011 - General Learning Space - (52.81 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1012 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1013 - General Learning Space - (52.67 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1014 - General Learning Space - (66.42 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1015 - General Learning Space - (52.67 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1021 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1022 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1023 - Interview/Office - Type 1 - (13 SQM)	Office (3)	
B00D - R1027 - Student Waiting - (6.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R1034 - Staff Study - (35.26 SQM)	Office (8)	
B00D - R1036 - Staff Study - (9.81 SQM)	Office (2)	
B00D - R1038 - General Learning Space - Bd/Cd/Ed - (59.46 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1039 - General Learning Space - Bd/Cd/Ed - (61.64 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0001 - Staff Kitchen - (16.6 SQM)	Office (4)	
B00E - R0002 - Staff Study - (16.22 SQM)	Office (4)	
B00E - R0004 - Staff Study - (6.63 SQM)	Office (1)	
B00E - R0005 - Laboratory L.S. - (90.64 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0006 - Preparation - Science - (48.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Laboratory L.S. - (91 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0011 - Growing/Breeding - (16.45 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Interview/Office - Type 1 - (28.58 SQM)	Office (7)	
B00E - R1003 - General Learning Space - (65.92 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R1004 - General Learning Space - (66.03 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R1005 - General Learning Space - (65.85 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R1006 - General Learning Space - (65.94 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0001 - Multi-Purpose Space - (620.76 SQM)	Student Space (288)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0002 - Staff Study - (12.29 SQM)	Office (3)	
B00F - R0004 - Staff Study - (25.33 SQM)	Office (6)	
B00F - R0005 - Tea Room - (8.15 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - General Assistants - (34.1 SQM)	Office (8)	
B00H - R0003 - Seminar - Type 1 - (25.58 SQM)	Office (6)	
B00H - R0005 - Computer Learning Space - (71.33 SQM) - Teaching Space: 1	Student Space (33)	
B00H - R0007 - Main Entry - (7.78 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Staff Study - (10.52 SQM)	Office (2)	
B00J - R0001 - General Learning Space - (92.03 SQM) - Teaching Space: 1	Student Space (42)	
B00J - R0002 - Study Space - (18.82 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Deputy Principal Office - (12.85 SQM)	Office (3)	
B00K - R0003 - Clinic - (12.85 SQM)	Office (3)	
B00K - R0004 - Deputy Principal Office - (12.85 SQM)	Office (3)	
B00K - R0006 - Public Reception - (44.33 SQM)	Not Applicable	Circulation or storage space.
B00K - R0009 - Interview/Meeting - (15.16 SQM)	Office (3)	
B00K - R0010 - Clinic - (12.81 SQM)	Office (3)	
B00K - R0011 - Administration - Executive - (10.73 SQM)	Office (2)	
B00K - R0012 - Administration - Clerical - (100.88 SQM)	Office (25)	
B00K - R0013 - Leading Teacher - (13.51 SQM)	Office (3)	
B00K - R0014 - Staff Kitchen - (12.85 SQM)	Office (3)	
B00K - R0019 - Interview/Meeting - (15.16 SQM)	Office (3)	
B00K - R0020 - Principal Office - (17.8 SQM)	Office (4)	
B00K - R0021 - Interview/Meeting - (12.42 SQM)	Office (3)	
B00K - R0022 - Deputy Principal Office - (12.85 SQM)	Office (3)	
B00K - R0023 - Interview/Meeting - (14.64 SQM)	Office (3)	
B00K - R0024 - Movement - (29.64 SQM)	Not Applicable	Circulation or storage space.
B00K - R0025 - Movement - (17.96 SQM)	Not Applicable	Circulation or storage space.
B00K - R0027 - Public Reception - (35.16 SQM)	Not Applicable	Circulation or storage space.
B01B - R0002 - Multi Media Workshop - (52.81 SQM)	Not Applicable	Circulation or storage space.
B01B - R0003 - Art Learning Space - (52.96 SQM) - Teaching Space: 1	Student Space (24)	
B01B - R0004 - Workshop - (52.07 SQM)	Student Space (24)	
B01B - R0006 - Art Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (24)	
B01B - R0019 - Dark Room - (18.67 SQM)	Office (4)	
B01B - R0020 - Staff Study - (33.11 SQM)	Office (8)	
B01B - R1001 - Leading Teacher - (18.82 SQM)	Office (4)	
B01B - R1002 - Design/Technology L.S. - (66.22 SQM) - Teaching Space: 1	Student Space (30)	
B01B - R1016 - Staff Study - (46.28 SQM)	Office (11)	
B01B - R1018 - Design/Technology L.S. - (50.8 SQM) - Teaching Space: 1	Student Space (23)	
B01B - R1020 - Design/Technology L.S. - (63.49 SQM) - Teaching Space: 1	Student Space (29)	
B01B - R1022 - Computer Learning Space - (50.66 SQM) - Teaching Space: 1	Student Space (23)	
B02B - R0010 - Metal Technology L.S. - (123.41 SQM) - Teaching Space: 1	Student Space (57)	
B02B - R0013 - Metal Technology Bay - (65.63 SQM)	Not Applicable	Circulation or storage space.
B03B - R0010 - Wood Technology L.S. - (197.93 SQM) - Teaching Space: 1	Student Space (91)	
B03B - R0015 - Outdoor Workshop - (187.33 SQM)	Not Applicable	Circulation or storage space.
NS 200 10908 - NS 200 10908 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
OS 601 10909 - OS 601 10909 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	