


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Gosford East Public School (4218)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Gosford</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

4218 - Gosford East Public School  
Site Plan (12664)



1:1,059

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (7.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Movement - (6.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (44.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Home Base - (57.13 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0012 - Movement - (10.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (43.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Home Base - (57.08 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0017 - Home Base - (56.92 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0020 - Movement - (11.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Movement - (34.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Entry Vestibule - (8.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Clerical Office - (12.13 SQM)	● Office (3)	
B00A - R0031 - Movement - (10.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Clerical Office - (18.17 SQM)	● Office (4)	
B00A - R0035 - Sick Bay - (8.52 SQM)	● Student Space (3)	
B00A - R0039 - Practical Activities - 1hb - (17.1 SQM)	● Student Space (7)	
B00A - R0041 - Withdrawal Space - 2hb - (12.44 SQM)	● Student Space (5)	
B00A - R0042 - Practical Activities - 1hb - (17.92 SQM)	● Student Space (8)	
B00A - R0044 - Practical Activities - 1hb - (17.58 SQM)	● Student Space (8)	
B00A - R0046 - Withdrawal Space - 2hb - (13.31 SQM)	● Student Space (6)	
B00A - R0047 - Practical Activities - 1hb - (17.4 SQM)	● Student Space (8)	
B00A - R0049 - Home Base - (57.15 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0050 - Principal - (17.74 SQM)	● Office (4)	
B00A - R1006 - Home Base - (57.09 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1007 - Movement - (6.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Movement - (45.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Movement - (11.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Movement - (43.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - Home Base - (57.09 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1014 - Home Base - (56.54 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1017 - Movement - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00A - R1020 - Practical Activities - 1hb - (17.09 SQM)	● Student Space (7)	
B00A - R1022 - Withdrawal Space - 2hb - (12.59 SQM)	● Student Space (5)	
B00A - R1023 - Practical Activities - 1hb - (17.92 SQM)	● Student Space (8)	
B00A - R1025 - Practical Activities - 1hb - (17.51 SQM)	● Student Space (8)	
B00A - R1027 - Withdrawal Space - 2hb - (13.38 SQM)	● Student Space (6)	
B00A - R1028 - Practical Activities - 1hb - (17.37 SQM)	● Student Space (8)	
B00A - R1030 - Home Base - (57.03 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0001 - Movement - (23.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Staff Room - (52.52 SQM)	● Office (13)	
B00B - R0018 - Home Base - P - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0026 - Practical Activities - P - 1hb - (10.93 SQM)	● Student Space (5)	
B00B - R0028 - Home Base - P - (53.32 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0033 - Movement - (143.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Home Base - (62.09 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0036 - Withdrawal - M - (20.2 SQM)	● Student Space (9)	
B00B - R0037 - Movement - (13.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0038 - Study Annexe - (12.29 SQM)	● Office (3)	
B00B - R0039 - Study Annexe - (11.75 SQM)	● Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0040 - Study Annexe - (12.33 SQM)	Office (3)	
B00D - R0003 - Special Programs Room - (43.29 SQM)	Student Space (20)	
B00D - R0008 - Reading Area - (153.93 SQM)	Student Space (71)	
B00D - R0010 - Movement - (143.12 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (20.29 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Teachers Aide Special Ed - (23.83 SQM)	Office (5)	
B00F - R0014 - Home Base - (59.29 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0015 - Movement - (6.52 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Withdrawal Space - 1hb - (28.36 SQM)	Student Space (13)	
B00F - R0017 - Home Base - (82.78 SQM) - Teaching Space: 1	Student Space (38)	
B00F - R9004 - Canteen - (18.84 SQM)	Not Applicable	Circulation or storage space.
B00F - R9005 - Canteen - (18.19 SQM)	Not Applicable	Circulation or storage space.
B00F - R9006 - Movement - (21.02 SQM)	Not Applicable	Circulation or storage space.
B00F - R9008 - Movement - (15.55 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (6.27 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Home Base - (79.31 SQM) - Teaching Space: 1	Student Space (36)	
B00G - R0006 - Home Base - (58.33 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0009 - Movement - (12.08 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Home Base - (56.62 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0015 - Home Base - (56.47 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0017 - Movement - (11.14 SQM)	Not Applicable	Circulation or storage space.
B00G - R0022 - Home Base - (59.45 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0027 - Movement - (12.51 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Practical Activities - 1hb - (10.62 SQM)	Student Space (4)	
B00G - R0030 - Withdrawal Space - 2hb - (12.92 SQM)	Student Space (5)	
B00G - R0031 - Withdrawal Space - 2hb - (13.97 SQM)	Student Space (6)	
B00G - R0032 - Practical Activities - 1hb - (10.82 SQM)	Student Space (5)	
B00G - R0034 - Practical Activities - 1hb - (10.67 SQM)	Student Space (4)	
B00G - R0036 - Withdrawal Space - 2hb - (12.99 SQM)	Student Space (6)	
B00G - R0037 - Withdrawal Space - 2hb - (16.57 SQM)	Student Space (7)	
B00G - R0039 - Practical Activities - 1hb - (10.67 SQM)	Student Space (4)	
B00H - R0001 - Movement - (12.68 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Entry Vestibule - (14.81 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Clerical Office - (9 SQM)	Office (2)	
B00H - R0005 - Dental Clinic - (7.47 SQM)	Office (1)	
B00I - R0001 - Movement - (203.03 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Movement - (12.31 SQM)	Not Applicable	Circulation or storage space.
B00I - R0006 - Raised Platform - (46.65 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Movement - (14.42 SQM)	Not Applicable	Circulation or storage space.
B00I - R0016 - Communal Space - (141.27 SQM)	Student Space (65)	