


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Gosford High School (8115)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Gosford</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

8115 - Gosford High School  
Site Plan (12665)



1:1,273

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Food Technology L.S. - (95.89 SQM) - Teaching Space: 1	 Student Space (44)	
B00A - R0004 - Preparation - Materials - (10.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Computer Learning Space - (82.96 SQM) - Teaching Space: 1	 Student Space (38)	
B00A - R0008 - Movement - (42.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Art Learning Space - (85.7 SQM) - Teaching Space: 1	 Student Space (39)	
B00A - R0014 - Design/Technology L.S. - (36.77 SQM) - Teaching Space: 1	 Student Space (17)	
B00A - R0016 - Art Learning Space - (85.95 SQM) - Teaching Space: 1	 Student Space (39)	
B00A - R0020 - Art Learning Space - (54.69 SQM) - Teaching Space: 1	 Student Space (25)	
B00A - R0021 - General Learning Space - (54.48 SQM) - Teaching Space: 1	 Student Space (25)	
B00A - R0022 - General Learning Space - (54.31 SQM) - Teaching Space: 1	 Student Space (25)	
B00A - R0034 - Staff Study - (27.17 SQM)	 Office (6)	
B00A - R0036 - Staff Study - (8.46 SQM)	 Office (2)	
B00A - R0037 - Movement - (90.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (55.22 SQM) - Teaching Space: 1	 Student Space (25)	
B00A - R1002 - General Learning Space - (54.35 SQM) - Teaching Space: 1	 Student Space (25)	
B00A - R1003 - General Learning Space - (54.28 SQM) - Teaching Space: 1	 Student Space (25)	
B00A - R1004 - Leading Teacher - (9.41 SQM)	 Office (2)	
B00A - R1005 - Leading Teacher - (13.99 SQM)	 Office (3)	
B00A - R1006 - Interview/Office - Type 1 - (13.74 SQM)	 Office (3)	
B00A - R1009 - Principal Office - (26.27 SQM)	 Office (6)	
B00A - R1010 - Public Reception - (49.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R1014 - General Learning Space - (58.39 SQM) - Teaching Space: 1	 Student Space (27)	
B00A - R1015 - General Learning Space - (56.14 SQM) - Teaching Space: 1	 Student Space (26)	
B00A - R1016 - General Learning Space - (57.28 SQM) - Teaching Space: 1	 Student Space (26)	
B00A - R1021 - Deputy Principal Office - (24.1 SQM)	 Office (6)	
B00A - R1022 - Deputy Principal Office - (17.13 SQM)	 Office (4)	
B00A - R1023 - Administration - Clerical - (30.28 SQM)	 Office (7)	
B00A - R1024 - Administration - Clerical - (13.68 SQM)	 Office (3)	
B00A - R1025 - Administration - Clerical - (14.58 SQM)	 Office (3)	
B00A - R1034 - Movement - (50.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R1045 - Movement - (13.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R1046 - Student Waiting - (16.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R1048 - Clinic - (15.54 SQM)	 Office (3)	
B00A - R1049 - Commonroom - (94.08 SQM)	 Office (23)	
B00A - R1050 - Staff Kitchen - (17.92 SQM)	 Office (4)	
B00A - R1051 - Movement - (35.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R1052 - Movement - (107.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R1053 - Movement - (112.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R2001 - Seminar - (29.96 SQM)	 Office (7)	
B00A - R2004 - General Learning Space - (55.06 SQM) - Teaching Space: 1	 Student Space (25)	
B00A - R2007 - Interview/Office - Type 1 - (21.21 SQM)	 Office (5)	
B00A - R2008 - General Learning Space - (58.35 SQM) - Teaching Space: 1	 Student Space (27)	
B00A - R2009 - General Learning Space - (55.46 SQM) - Teaching Space: 1	 Student Space (25)	
B00A - R2010 - General Learning Space - (57.58 SQM) - Teaching Space: 1	 Student Space (26)	
B00A - R2011 - General Learning Space - (56.71 SQM) - Teaching Space: 1	 Student Space (26)	
B00A - R2012 - General Learning Space - (59.2 SQM) - Teaching Space: 1	 Student Space (27)	
B00A - R2014 - General Learning Space - (53.73 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R2016 - Seminar - Type 1 - (28.26 SQM)	 Office (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R2017 - General Learning Space - (55.09 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R2025 - Staff Study - (51.66 SQM)	○ Office (12)	
B00A - R2029 - Movement - (173.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - General Learning Space - Type 1 - (70.58 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R0026 - Tea Room - (5.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Interview/Office - Type 1 - (11.21 SQM)	○ Office (2)	
B00B - R0028 - Student Canteen - (51.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Tea Room - (9.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Preparation - Science - (28.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Laboratory L.S. - (92.26 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R1009 - Laboratory L.S. - (86.05 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R1010 - Preparation - Science - (25.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R1011 - Laboratory L.S. - (79.76 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R1012 - Laboratory L.S. - (92.65 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R1015 - Laboratory L.S. - (85.81 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R1018 - Laboratory L.S. - (92.62 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R1026 - Preparation - Science - (39.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R1027 - Staff Study - (35.06 SQM)	○ Office (8)	
B00B - R1029 - Staff Lounge - (23.49 SQM)	○ Office (5)	
B00B - R2004 - General Learning Space - (52.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R2009 - Music Learning Space - (58.65 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R2010 - Staff Study - (26.58 SQM)	○ Office (6)	
B00B - R2011 - Music Learning Space - (51.94 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R2014 - General Learning Space - (51.5 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R2015 - General Learning Space - (51.43 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R2016 - General Learning Space - (58.63 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R2018 - General Learning Space - (52.09 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R2020 - Staff Study - (12.14 SQM)	○ Office (3)	
B00B - R2029 - Performance Workspace - (105.62 SQM) - Teaching Space: 1	● Student Space (49)	
B00B - R2032 - Staff Lounge - (23.31 SQM)	○ Office (5)	
B00B - R2034 - Staff Study - (36.21 SQM)	○ Office (9)	
B00B - R2036 - Staff Study - (20.21 SQM)	○ Office (5)	
B00B - R2037 - Tea Room - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R2038 - General Learning Space - (64.1 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0004 - Design L.S. - (70.55 SQM) - Teaching Space: 1	● Student Space (32)	
B00C - R0009 - Wood Technology L.S. - (98.24 SQM) - Teaching Space: 1	● Student Space (45)	
B00C - R0014 - Metal Technology L.S. - (108.76 SQM) - Teaching Space: 1	● Student Space (50)	
B00C - R0016 - Wood Technology L.S. - (96.61 SQM) - Teaching Space: 1	● Student Space (44)	
B00C - R0022 - Movement - (91.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Staff Study - (18.67 SQM)	○ Office (4)	
B00C - R0027 - Textiles Technology L.S. - (52.78 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0029 - Textiles Technology L.S. - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0031 - Staff Study - (18.71 SQM)	○ Office (4)	
B00C - R0037 - Practice/Seminar - (9.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R9001 - Tea Room - (18.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R9005 - General Assistants - (29.52 SQM)	○ Office (7)	
B00C - R9009 - Darkroom Space - (12.7 SQM)	○ Office (3)	
B00C - R9010 - Dark Room - (16.98 SQM)	○ Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0001 - General Learning Space - (47.55 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0005 - General Learning Space - (42.68 SQM) - Teaching Space: 1	● Student Space (19)	
B00D - R0006 - General Learning Space - (47.13 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0007 - Movement - (16.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Audio Visual Workroom - (39.45 SQM)	● Student Space (18)	
B00D - R0015 - Movement - (8.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Main Area - (344.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Seminar - (28.41 SQM)	○ Office (7)	
B00D - R0022 - Staff Study - (25.48 SQM)	○ Office (6)	
B00D - R1001 - Computer Learning Space - (57.31 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1004 - Computer Learning Space - (74.3 SQM) - Teaching Space: 1	● Student Space (34)	
B00D - R1005 - Movement - (7.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R1010 - Senior Study - (60.1 SQM)	○ Office (15)	
B00D - R1011 - Seminar - (22.13 SQM)	○ Office (5)	
B00D - R1012 - General Learning Space - (50.5 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1013 - General Learning Space - (47.56 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1015 - General Learning Space - (48.35 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1017 - General Learning Space - (49.75 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1018 - Movement - (58.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R1025 - Staff Study - (24.17 SQM)	○ Office (6)	
B00D - R1027 - Staff Study - (23.28 SQM)	○ Office (5)	
B00D - R1028 - Staff Study - (58.06 SQM)	○ Office (14)	
B00D - R1029 - Tea Room - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Multi-Purpose Space - (456.96 SQM)	● Student Space (212)	
B00E - R0010 - Staff Kitchen - (17.58 SQM)	○ Office (4)	
B00E - R0028 - Movement - (74.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0035 - Stage - (114.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R9007 - Practice/Seminar - (62.84 SQM)	Not Applicable	Circulation or storage space.
NS 210 10784 - NS 210 10784 - Home Science/Preparation Area/Laundry - (95 SQM)	○ Office (23)	