

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Gosford Public School (2049)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Gosford</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Central Coast</b>

2049 - Gosford Public School  
Site Plan (13079)



1:1,339

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B0AS - R0055 - Movement - (297.22 SQM)	Not Applicable	Circulation or storage space.
B0AS - R1007 - Special Programs Room - (47.73 SQM)	● Student Space (22)	
B0AS - R1039 - Home Base - (64.22 SQM) - Teaching Space: 1	● Student Space (29)	
B0AS - R1041 - Practical Activities - 1hb - (18.38 SQM)	● Student Space (8)	
B0AS - R1043 - Withdrawal Space - 2hb - (11.69 SQM)	● Student Space (5)	
B0AS - R1045 - Practical Activities - (17.87 SQM)	● Student Space (8)	
B0AS - R1046 - Home Base - (58.27 SQM) - Teaching Space: 1	● Student Space (27)	
B0AS - R1047 - Home Base - (44.09 SQM) - Teaching Space: 1	● Student Space (20)	
B0AS - R1048 - Practical Activities - (21.43 SQM)	● Student Space (9)	
B0AS - R1050 - Withdrawal Space - 2hb - (11.69 SQM)	● Student Space (5)	
B0AS - R1052 - Practical Activities - (21.18 SQM)	● Student Space (9)	
B0AS - R1053 - Home Base - (50.34 SQM) - Teaching Space: 1	● Student Space (23)	
B0AS - R1054 - Home Base - (54.33 SQM) - Teaching Space: 1	● Student Space (25)	
B0AS - R1055 - Practical Activities - (18.07 SQM)	● Student Space (8)	
B0AS - R1057 - Withdrawal Space - 1hb - (10.9 SQM)	● Student Space (5)	
B0AS - R1059 - Practical Activities - (18.5 SQM)	● Student Space (8)	
B0AS - R1060 - Home Base - (61.52 SQM) - Teaching Space: 1	● Student Space (28)	
B0AS - R1061 - Home Base - (60.23 SQM) - Teaching Space: 1	● Student Space (27)	
B0AS - R1062 - Practical Activities - (18.7 SQM)	● Student Space (8)	
B0AS - R1064 - Withdrawal Space - 2hb - (11.66 SQM)	● Student Space (5)	
B0AS - R1066 - Practical Activities - (18.5 SQM)	● Student Space (8)	
B0AS - R1067 - Home Base - (63.68 SQM) - Teaching Space: 1	● Student Space (29)	
B0AS - R1072 - Withdrawal Space - 1hb - (11.3 SQM)	● Student Space (5)	
B0AS - R1074 - Practical Activities - (18.05 SQM)	● Student Space (8)	
B0AS - R1075 - Home Base - (56.8 SQM) - Teaching Space: 1	● Student Space (26)	
B0AS - R1076 - Movement - (317.83 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0001 - Practical Activities - 1hb - (19.92 SQM)	● Student Space (9)	
BOBB - R0002 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
BOBB - R0004 - Withdrawal Space - 2hb - (11.37 SQM)	● Student Space (5)	
BOBB - R0005 - Home Base - (59.76 SQM) - Teaching Space: 1	● Student Space (27)	
BOBB - R0007 - Practical Activities - 1hb - (19.73 SQM)	● Student Space (9)	
BOBB - R0008 - Practical Activities - 1hb - (19.11 SQM)	● Student Space (8)	
BOBB - R0009 - Home Base - (60.22 SQM) - Teaching Space: 1	● Student Space (27)	
BOBB - R0011 - Withdrawal Space - 1hb - (7.78 SQM)	● Student Space (3)	
BOBB - R1001 - Reading Area - (230.7 SQM)	● Student Space (107)	
BOBB - R1005 - Entry Vestibule - (6.97 SQM)	Not Applicable	Circulation or storage space.
BOCC - R0004 - Canteen - (46 SQM)	Not Applicable	Circulation or storage space.
BOCC - R1006 - Special Programs Room - (53.8 SQM)	● Student Space (24)	
BODD - R0001 - Communal Space - (204.74 SQM)	● Student Space (94)	
BODD - R0002 - Raised Platform - (56.47 SQM)	Not Applicable	Circulation or storage space.
BODD - R0004 - Movement - (7.86 SQM)	Not Applicable	Circulation or storage space.
BOEE - R1001 - Entry Vestibule - (29.2 SQM)	Not Applicable	Circulation or storage space.
BOEE - R1002 - Interview - (12.35 SQM)	● Office (3)	
BOEE - R1003 - Principal - (16.2 SQM)	● Office (4)	
BOEE - R1004 - Deputy Principal - Type 1 - (13.21 SQM)	● Office (3)	
BOEE - R1005 - Deputy Principal - Type 1 - (12.69 SQM)	● Office (3)	
BOEE - R1008 - Staff Room - (59.22 SQM)	● Office (14)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0EE - R1009 - Staff Kitchen - (10.9 SQM)	 Office (2)	
B0EE - R1010 - Staff Room Annexe - (28.88 SQM)	 Office (7)	
B0EE - R1011 - Movement - (58.15 SQM)	Not Applicable	Circulation or storage space.
B0EE - R1016 - Sick Bay - (9.12 SQM)	 Student Space (4)	
B0EE - R1018 - Clerical Office - (40.29 SQM)	 Office (10)	
B0EE - R1019 - Clerical/Printing - (41.54 SQM)	Not Applicable	Circulation or storage space.
B0EE - R1020 - Interview/Office - Type 3 - (18.66 SQM)	 Office (4)	
B0EE - R1022 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B0FF - R0001 - Practical Activities - 1hb - (19.76 SQM)	 Student Space (9)	
B0FF - R0002 - Home Base - (59.4 SQM) - Teaching Space: 1	 Student Space (27)	
B0FF - R0004 - Withdrawal Space - 2hb - (11.61 SQM)	 Student Space (5)	
B0FF - R0005 - Home Base - (59.83 SQM) - Teaching Space: 1	 Student Space (27)	
B0FF - R0007 - Practical Activities - 1hb - (19.66 SQM)	 Student Space (9)	
B0FF - R0013 - Practical Activities - 1hb - (19.64 SQM)	 Student Space (9)	
B0FF - R0015 - Home Base - (60.57 SQM) - Teaching Space: 1	 Student Space (28)	
B0FF - R0016 - Withdrawal Space - 2hb - (11.61 SQM)	 Student Space (5)	
B0FF - R0017 - Home Base - (60.56 SQM) - Teaching Space: 1	 Student Space (28)	
B0FF - R0019 - Practical Activities - 1hb - (19.58 SQM)	 Student Space (9)	
B0FF - R0021 - Withdrawal Space - 1hb - (8.69 SQM)	 Student Space (4)	
B0FF - R0022 - Home Base - (58.85 SQM) - Teaching Space: 1	 Student Space (27)	
B0FF - R0023 - Practical Activities - 1hb - (19.92 SQM)	 Student Space (9)	
B0FF - R1001 - Practical Activities - 1hb - (20.59 SQM)	 Student Space (9)	
B0FF - R1002 - Home Base - (60.34 SQM) - Teaching Space: 1	 Student Space (27)	
B0FF - R1004 - Withdrawal Space - 2hb - (10.43 SQM)	 Student Space (4)	
B0FF - R1005 - Home Base - (60.22 SQM) - Teaching Space: 1	 Student Space (27)	
B0FF - R1007 - Practical Activities - 1hb - (19.78 SQM)	 Student Space (9)	
B0FF - R1013 - Practical Activities - 1hb - (19.81 SQM)	 Student Space (9)	
B0FF - R1015 - Home Base - (60.02 SQM) - Teaching Space: 1	 Student Space (27)	
B0FF - R1016 - Withdrawal Space - 2hb - (10.36 SQM)	 Student Space (4)	
B0FF - R1017 - Home Base - (60.35 SQM) - Teaching Space: 1	 Student Space (27)	
B0FF - R1019 - Practical Activities - 1hb - (19.83 SQM)	 Student Space (9)	
B0FF - R1021 - Withdrawal Space - 1hb - (8.79 SQM)	 Student Space (4)	
B0FF - R1022 - Home Base - (58.62 SQM) - Teaching Space: 1	 Student Space (27)	
B0FF - R1023 - Practical Activities - 1hb - (19.98 SQM)	 Student Space (9)	
B0FF - R9001 - Movement - (1095.38 SQM)	Not Applicable	Circulation or storage space.
B0FF - R9006 - Movement - (19.71 SQM)	Not Applicable	Circulation or storage space.