


VENTILATION AUDIT REPORT

SCHOOL:	Goulburn North Public School (2055)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Goulburn
LOCAL GOVERNMENT AREA:	Goulburn Mulwaree

2055 - Goulburn North Public School
Site Plan (12667)



1:919

Printed: 29-Aug-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Communal Space - (134.84 SQM)	● Student Space (62)	
B00A - R0006 - Raised Platform - (30.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (36.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Staff Room Annexe - (23.42 SQM)	● Office (5)	
B00A - R0020 - Staff Room - (32.26 SQM)	● Office (8)	
B00A - R0021 - Staff Kitchen - (5.32 SQM)	● Office (1)	
B00B - R0001 - Home Base - (79.84 SQM) - Teaching Space: 1	● Student Space (37)	
B00B - R0003 - Deputy Principal - (14.96 SQM)	● Office (3)	
B00B - R0004 - Movement - (45.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Practical Activities - 1hb - (18.17 SQM)	● Student Space (8)	
B00B - R0006 - Home Base - (48.11 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0007 - Home Base - (47.08 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0002 - Withdrawal Space - 1hb - (27.06 SQM)	● Student Space (12)	
B00C - R0005 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0006 - Home Base - (57.52 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0008 - Movement - (7.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Home Base - (57.44 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0013 - Home Base - (79.12 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R0019 - Staff Room Annexe - (14.35 SQM)	● Office (3)	
B00C - R0022 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Movement - (8.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Home Base - (55.3 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R0030 - Movement - (45.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - Movement - (92.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - (59.14 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0005 - Movement - (10.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Clerical Office - (12.42 SQM)	● Office (3)	
B00D - R0008 - Sick Bay - (9.88 SQM)	● Student Space (4)	
B00D - R0013 - Duplicating Workroom - (18.45 SQM)	● Office (4)	
B00D - R0018 - Staff Kitchen - (10.99 SQM)	● Office (2)	
B00D - R0019 - Movement - (7.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Principal - (13.32 SQM)	● Office (3)	
B00D - R0024 - Interview - (13.01 SQM)	● Office (3)	
B00D - R0025 - Interview - (12.41 SQM)	● Office (3)	
B00D - R0027 - Movement - (5.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Canteen - (22.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (17.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (36.16 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Movement - (13.31 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Special Programs Room - (42.97 SQM)	● Student Space (19)	
B00K - R0002 - Reading Area - (169.34 SQM)	● Student Space (78)	
B00K - R0010 - Canteen - (13.75 SQM)	Not Applicable	Circulation or storage space.
OS 601 10727 - OS 601 10727 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 11698 - OS 602 11698 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12140 - OS 602 12140 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12426 - OS 602 12426 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	