

VENTILATION AUDIT REPORT

SCHOOL:	Goulburn West Public School (3741)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Goulburn
LOCAL GOVERNMENT AREA:	Goulburn Mulwaree

3741 - Goulburn West Public School
Site Plan (10390)



1:989

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (108.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Principal - (15.32 SQM)	Office (3)	
B00A - R0010 - Home Base - (56.88 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0011 - Home Base - (57.11 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0015 - Home Base - (56.95 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0016 - Home Base - (57.04 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0017 - Home Base - (57.58 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0020 - Movement - (38.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Canteen - (28.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Staff Room - (54.58 SQM)	Office (13)	
B00C - R0003 - Home Base - (53.81 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0004 - Home Base - (53.36 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0005 - Movement - (30.72 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Movement - (5.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Home Base - (86.48 SQM) - Teaching Space: 1	Student Space (40)	
B00E - R0005 - Home Base - (57.12 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0009 - Deputy Principal - (16.86 SQM)	Office (4)	
B00E - R0011 - Movement - (18.36 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Special Programs Room - (20.22 SQM)	Student Space (9)	
B00E - R0017 - Movement - (48.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Movement - (9.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Home Base - (56.96 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0005 - Home Base - (56.89 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0006 - Movement - (31.57 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (58.97 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (12.82 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Communal Space - (204.29 SQM)	Student Space (94)	
B00H - R0005 - Movement - (12.92 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Staff Kitchen - (9.67 SQM)	Office (2)	
B00H - R0014 - Movement - (7.5 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Movement - (5.37 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Raised Platform - (34.69 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (5.32 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Movement - (9.11 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Movement - (56.02 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Special Programs Room - (44.2 SQM)	Student Space (20)	
B00L - R0010 - Reading Area - (155.74 SQM)	Student Space (72)	
B00L - R0011 - Movement - (143.87 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Child Care Centre - (7.56 SQM)	Student Space (3)	
B00O - R0002 - Practical Activities - 1hb - (14.39 SQM)	Student Space (6)	
B00O - R0004 - Home Base - (61.15 SQM) - Teaching Space: 1	Student Space (28)	
B00O - R0005 - Withdrawal Space - 2hb - (11.71 SQM)	Student Space (5)	
B00O - R0006 - Home Base - (61 SQM) - Teaching Space: 1	Student Space (28)	
B00O - R0008 - Practical Activities - 1hb - (14.39 SQM)	Student Space (6)	
B00P - R0002 - Practical Activities - 1hb - (14.39 SQM)	Student Space (6)	
B00P - R0004 - Home Base - (61.07 SQM) - Teaching Space: 1	Student Space (28)	
B00P - R0005 - Withdrawal Space - 2hb - (11.71 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R0006 - Home Base - (61.07 SQM) - Teaching Space: 1	 Student Space (28)	
B00P - R0008 - Practical Activities - 1hb - (14.39 SQM)	 Student Space (6)	
B00R - R0001 - Entry Vestibule - (16.91 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Interview - (11.86 SQM)	 Office (2)	
B00R - R0003 - Principal - (20.45 SQM)	 Office (5)	
B00R - R0004 - Deputy Principal - (29.72 SQM)	 Office (7)	
B00R - R0005 - Movement - (31.51 SQM)	Not Applicable	Circulation or storage space.
B00R - R0006 - Staff Kitchen - (5.15 SQM)	 Office (1)	
B00R - R0007 - Staff Room - (59.99 SQM)	 Office (14)	
B00R - R0013 - Sick Bay - (6.54 SQM)	 Student Space (3)	
B00R - R0014 - Clerical/Printing - (13.59 SQM)	Not Applicable	Circulation or storage space.
B00R - R0015 - Clerical Office - (25.39 SQM)	 Office (6)	
OS 602 12888 - OS 602 12888 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16235 - OS 602 16235 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	