


VENTILATION AUDIT REPORT

SCHOOL:	Grafton Public School (2060)
AMU REGION:	North Coast
STATE ELECTORATE:	Clarence
LOCAL GOVERNMENT AREA:	Clarence Valley

2060 - Grafton Public School
Site Plan (12985)



1:928

Printed: 05-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (57.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0002 - Movement - (5.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Staff Kitchen - (11.23 SQM)	● Office (2)	
B00A - R0005 - Staff Room - (85.99 SQM)	● Office (21)	
B00A - R0013 - Canteen - (27.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Home Base - (57.38 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1005 - Home Base - (57.22 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1007 - Movement - (15.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Home Base - (57.15 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1010 - Home Base - (57.08 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0001 - Interview - (35.07 SQM)	● Office (8)	
B00B - R0002 - Movement - (22.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Sick Bay - (7.31 SQM)	● Student Space (3)	
B00B - R0007 - Clerical Office - (18.4 SQM)	● Office (4)	
B00B - R0008 - Deputy Principal - (17.28 SQM)	● Office (4)	
B00B - R0009 - Entry Vestibule - (11.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Principal - (17.27 SQM)	● Office (4)	
B00B - R0013 - Duplicating Workroom - (13.09 SQM)	● Office (3)	
B00B - R0014 - Deputy Principal - (12.27 SQM)	● Office (3)	
B00B - R1002 - Movement - (6.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Home Base - (57.3 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R1006 - Special Programs Room - (57.15 SQM)	● Student Space (26)	
B00B - R1008 - Movement - (7.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R1009 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (57.22 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1001 - Movement - (6.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Home Base - (57.15 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1006 - Home Base - (57.14 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1008 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Home Base - (55.36 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0011 - Withdrawal Space - 1hb - (16.94 SQM)	● Student Space (7)	
B00D - R0012 - Practical Activities - 2hb - (12.71 SQM)	● Student Space (5)	
B00D - R0015 - Home Base - (55.31 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0016 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Withdrawal Space - 1hb - (9.32 SQM)	● Student Space (4)	
B00E - R0001 - Practical Activities - 1hb - (10.95 SQM)	● Student Space (5)	
B00E - R0002 - Withdrawal Space - 1hb - (33.55 SQM)	● Student Space (15)	
B00E - R0006 - Home Base - S - (44.49 SQM) - Teaching Space: 1	● Student Space (20)	
B00E - R0010 - Practical Activities/Movement - 1hb - (16.46 SQM)	● Student Space (7)	
B00E - R0011 - Practical Activities/Movement - 1hb - (17.09 SQM)	● Student Space (7)	
B00G - R0001 - Home Base - (53.78 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0003 - Practical Activities - 1hb - (14.59 SQM)	● Student Space (6)	
B00G - R0004 - Withdrawal Space - 1hb - (14.7 SQM)	● Student Space (6)	
B00G - R0005 - Home Base - (53.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00I - R0004 - Home Base - (86.04 SQM) - Teaching Space: 1	● Student Space (39)	
B00I - R0007 - Home Base - (57.16 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0009 - Movement - (8.96 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0010 - Movement - (6.02 SQM)	Not Applicable	Circulation or storage space.
B00I - R0014 - Home Base - (86.29 SQM) - Teaching Space: 1	● Student Space (40)	
B00I - R0015 - Home Base - (57.31 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R0017 - Movement - (9.02 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Entry Vestibule - (20.75 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Duplicating Workroom - (11.1 SQM)	● Office (2)	
B00J - R0005 - Interview - (11.64 SQM)	● Office (2)	
B00J - R0007 - Clerical Office - (17.63 SQM)	● Office (4)	
B00J - R0008 - Sick Bay - (10.39 SQM)	● Student Space (4)	
B00J - R0009 - Staff Room - (52.8 SQM)	● Office (13)	
B00J - R0011 - Deputy Principal - (16.42 SQM)	● Office (4)	
B00J - R0013 - Movement - (9.84 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Home Base - (57.16 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0020 - Withdrawal Space - 1hb - (10.95 SQM)	● Student Space (5)	
B00J - R0021 - Movement - (7.3 SQM)	Not Applicable	Circulation or storage space.
B00J - R0023 - Home Base - (57.01 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0028 - Canteen - (21.61 SQM)	Not Applicable	Circulation or storage space.
B00J - R0029 - Home Base - (56.93 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0032 - Movement - (18.59 SQM)	Not Applicable	Circulation or storage space.
B00J - R0034 - Home Base - (57.32 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0035 - Home Base - (57.1 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0037 - Movement - (18.5 SQM)	Not Applicable	Circulation or storage space.
B00J - R0039 - Home Base - (57.01 SQM) - Teaching Space: 1	● Student Space (26)	
B00L - R0001 - Reading Area - (44.23 SQM)	● Student Space (20)	
B00L - R0002 - Practical Activities - 1hb - (31.69 SQM)	● Student Space (14)	
B00L - R0003 - Home Base - (44.56 SQM) - Teaching Space: 1	● Student Space (20)	
B00M - R0004 - Reading Area - (227.2 SQM)	● Student Space (105)	
B00N - R0003 - Communal Space - (212.04 SQM)	● Student Space (98)	
B00N - R0009 - Movement - (6.98 SQM)	Not Applicable	Circulation or storage space.
B00N - R0010 - Raised Platform - (35.06 SQM)	Not Applicable	Circulation or storage space.
B00N - R0011 - Movement - (6.72 SQM)	Not Applicable	Circulation or storage space.
B00O - R0007 - Special Programs Room - (54.94 SQM)	● Student Space (25)	
B00Q - R0002 - Practical Activities - 1hb - (19.43 SQM)	● Student Space (9)	
B00Q - R0004 - Home Base - (60.71 SQM) - Teaching Space: 1	● Student Space (28)	
B00Q - R0005 - Withdrawal Space - 2hb - (11.56 SQM)	● Student Space (5)	
B00Q - R0006 - Home Base - (60.83 SQM) - Teaching Space: 1	● Student Space (28)	
B00Q - R0008 - Practical Activities - 1hb - (19.26 SQM)	● Student Space (8)	
B00R - R0004 - Special Programs Room - (38.45 SQM)	● Student Space (17)	
B00R - R0005 - Home Base - (67.23 SQM) - Teaching Space: 1	● Student Space (31)	
B00R - R0007 - Practical Activities/Movement - 2hb - (38.83 SQM)	● Student Space (18)	
B00R - R0011 - Home Base - (67.49 SQM) - Teaching Space: 1	● Student Space (31)	