

VENTILATION AUDIT REPORT

SCHOOL:	Granville Boys High School (8811)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Granville
LOCAL GOVERNMENT AREA:	Cumberland

8811 - Granville Boys High School
Site Plan (12678)



1:887

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Administration - Clerical - (12.85 SQM)	Office (3)	
B00A - R0005 - Principal Office - (16.65 SQM)	Office (4)	
B00A - R0016 - Leading Teacher - (12.87 SQM)	Office (3)	
B00A - R0019 - General Learning Space - (47.37 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0022 - General Learning Space - (47.5 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0024 - Movement - (11.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (11.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Student Reception - (54.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Administration - Clerical - (54.58 SQM)	Office (13)	
B00A - R0043 - Public Reception - (28.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Public Reception - (9.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Clinic - (7.6 SQM)	Office (1)	
B00A - R0047 - Public Entry - (27.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Movement - (50.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0049 - Student Waiting - (9.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0050 - Deputy Principal Office - (13.02 SQM)	Office (3)	
B00A - R0051 - Principal Office - (23.83 SQM)	Office (5)	
B00A - R0053 - Staff Kitchen - (12.23 SQM)	Office (3)	
B00A - R0054 - Administration - Executive - (12.71 SQM)	Office (3)	
B00A - R1003 - Commonroom - (94.81 SQM)	Office (23)	
B00A - R1005 - Movement - (83.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - General Learning Space - (49.96 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1007 - General Learning Space - (50.77 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1008 - General Learning Space - (50.03 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1009 - General Learning Space - (49.76 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0003 - Art Learning Space - (49.28 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0004 - Art Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0013 - Study Space - (15.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Movement - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Interview/Office - Type 1 - (12.71 SQM)	Office (3)	
B00B - R0017 - General Assistants - (18.91 SQM)	Office (4)	
B00B - R0020 - Movement - (124.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Movement - (10.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Laboratory L.S. - (90.14 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R1004 - Laboratory L.S. - (90.36 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R1006 - Movement - (11.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R1007 - Laboratory L.S. - (90.21 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R1009 - Preparation - (34.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Laboratory L.S. - (90.22 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R1011 - Staff Study - (36.44 SQM)	Office (9)	
B00B - R1016 - Movement - (129.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R1017 - Preparation - Science - (45.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R2001 - General Learning Space - (60.11 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R2002 - General Learning Space - (79.56 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R2007 - Computer Learning Space - (56.01 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R2009 - Leading Teacher - (12.98 SQM)	Office (3)	
B00B - R2010 - General Learning Space - (60.04 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R2011 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R2012 - General Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R2013 - Staff Study - (25.77 SQM)	Office (6)	
B00B - R2015 - Movement - (7.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R2017 - Staff Kitchen - (5.94 SQM)	Office (1)	
B00B - R2020 - Computer Learning Space - (54.15 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R2023 - Movement - (142.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Main Area - (338.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Seminar - (12.75 SQM)	Office (3)	
B00C - R0003 - Seminar - (19.59 SQM)	Office (4)	
B00C - R0004 - Seminar - (12.79 SQM)	Office (3)	
B00C - R0005 - Workroom - (33.86 SQM)	Office (8)	
B00C - R0006 - Staff Room - (27.13 SQM)	Office (6)	
B00C - R0008 - Entry - (10.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Staff Study - (31.33 SQM)	Office (7)	
B00C - R0012 - Movement - (30.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Food Technology L.S. - (89.56 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R0004 - Movement - (14.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Metal Technology L.S. - (76.45 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R0009 - Metal Technology Bay - (22.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Metal Technology L.S. - (71 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R0012 - Movement - (16.76 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (11.49 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Music Learning Space - (81.15 SQM) - Teaching Space: 1	Student Space (37)	
B00D - R1002 - Wood Technology L.S. - (77.64 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R1003 - Movement - (14.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R1004 - Wood Technology L.S. - (86.37 SQM) - Teaching Space: 1	Student Space (40)	
B00D - R1007 - Wood Technology L.S. - (86.41 SQM) - Teaching Space: 1	Student Space (40)	
B00D - R1008 - Movement - (16.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R1009 - Music Learning Space - (77.13 SQM) - Teaching Space: 1	Student Space (35)	
B00F - R0003 - Student Canteen - (33.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Student Canteen - (27.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - General Learning Space - (81.89 SQM) - Teaching Space: 1	Student Space (37)	
B00F - R0007 - Movement - (32.99 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - General Learning Space - (97.01 SQM) - Teaching Space: 1	Student Space (45)	
B00F - R0014 - General Learning Space - (59.1 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0016 - Performance Workspace - (107.17 SQM) - Teaching Space: 1	Student Space (49)	
B00F - R0017 - Movement - (64.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Movement - (24.29 SQM)	Not Applicable	Circulation or storage space.
B00F - R0022 - Movement - (56.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0025 - General Learning Space - (49.19 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R1001 - General Learning Space - (54.27 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R1003 - Staff Study - (41.05 SQM)	Office (10)	
B00F - R1004 - General Learning Space - (71.08 SQM) - Teaching Space: 1	Student Space (32)	
B00F - R1005 - General Learning Space - (70.48 SQM) - Teaching Space: 1	Student Space (32)	
B00F - R1006 - General Learning Space - (54.92 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R1008 - General Learning Space - (55.11 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R1009 - Design L.S. - (55.88 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R1012 - Movement - (158.06 SQM)	Not Applicable	Circulation or storage space.
B00F - R2003 - General Learning Space - (54.81 SQM) - Teaching Space: 1	Student Space (25)	
B00F - R2005 - General Learning Space - (54.81 SQM) - Teaching Space: 1	Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R2006 - Staff Study - (26.98 SQM)	 Office (6)	
B00F - R2007 - General Learning Space - (57.02 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R2008 - General Learning Space - (57.1 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R2010 - General Learning Space - (54.88 SQM) - Teaching Space: 1	 Student Space (25)	
B00F - R2011 - Computer Learning Space - (69.33 SQM) - Teaching Space: 1	 Student Space (32)	
B00F - R2012 - Movement - (149.46 SQM)	Not Applicable	Circulation or storage space.
B0G1 - R0001 - Staff Study - (27.12 SQM)	 Office (6)	
B0G1 - R0002 - Multi-Purpose Space - (617.75 SQM)	 Student Space (286)	
B0G1 - R0003 - Staff Study - (13.37 SQM)	 Office (3)	
B0G1 - R0015 - Movement - (11.72 SQM)	Not Applicable	Circulation or storage space.
B0G1 - R0016 - Stage - (50.17 SQM)	Not Applicable	Circulation or storage space.
B0G1 - R0028 - Kitchen - Type 1 - (107.37 SQM)	 Student Space (49)	
B0G1 - R0029 - Preparation - Materials - (18.26 SQM)	Not Applicable	Circulation or storage space.