

VENTILATION AUDIT REPORT

SCHOOL:	Granville Public School (2064)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Granville
LOCAL GOVERNMENT AREA:	Cumberland

2064 - Granville Public School
Site Plan (12082)



1:860

Printed: 08-Sep-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (14.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Clerical Office - (13.04 SQM)	Office (3)	
B00A - R0003 - Entry Vestibule - (12.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office/Workroom - (15.6 SQM)	Office (3)	
B00A - R0005 - Duplicating Workroom - (15.56 SQM)	Office (3)	
B00A - R0006 - Staff Room - (103.42 SQM)	Office (25)	
B00A - R0008 - Movement - (46.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (303.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Canteen - (44.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Sick Bay - (8.7 SQM)	Student Space (4)	
B00A - R0024 - Deputy Principal - (13 SQM)	Office (3)	
B00A - R0025 - Principal - (20.84 SQM)	Office (5)	
B00A - R0026 - Staff Room Annexe - (12.85 SQM)	Office (3)	
B00A - R0031 - Movement - (6.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Reading Area - (250.55 SQM)	Student Space (116)	
B00A - R1010 - Movement - (36.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Seminar/Study - (13.85 SQM)	Office (3)	
B00A - R1012 - Seminar/Study - (13.81 SQM)	Office (3)	
B00B - R0001 - Movement - (22.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (5.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (7.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Home Base - (55.37 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0006 - Home Base - (41.22 SQM) - Teaching Space: 1	Student Space (19)	
B00B - R0007 - Practical Activities - 1hb - (13.82 SQM)	Student Space (6)	
B00B - R0008 - Withdrawal Space - 1hb - (6.8 SQM)	Student Space (3)	
B00B - R0009 - Home Base - (55.27 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0010 - Special Programs Room - (55.04 SQM)	Student Space (25)	
B00B - R0011 - Movement - (32.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Home Base - (46.55 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0013 - Home Base - (47.06 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0014 - Home Base - (70.76 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R0015 - Movement - (64.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (5.75 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (9.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Staff Room Annexe - (21.54 SQM)	Office (5)	
B00B - R0019 - Interview - (22.75 SQM)	Office (5)	
B00B - R0024 - Movement - (60.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Withdrawal - M - (7.55 SQM)	Student Space (3)	
B00B - R0026 - Home Base - M - (45.34 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0029 - Practical Activities - M - 1hb - (12.51 SQM)	Student Space (5)	
B00B - R0031 - Staff Room Annexe - (10.68 SQM)	Office (2)	
B00B - R0033 - Withdrawal - M - (6.79 SQM)	Student Space (3)	
B00B - R0034 - Home Base - M - (44.22 SQM) - Teaching Space: 1	Student Space (20)	
B00B - R0035 - Practical Activities - M - 1hb - (14.91 SQM)	Student Space (6)	
B00C - R0002 - Movement - (8.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Movement - (85.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (46.96 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0005 - Home Base - (47.68 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0006 - Movement - (5.88 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0007 - Home Base - (47.81 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R0008 - Home Base - (47.48 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R0010 - Movement - (8.69 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Interview - (13.23 SQM)	● Office (3)	
B00C - R1001 - Movement - (88.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Home Base - (49.03 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R1003 - Home Base - (48.56 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R1005 - Home Base - (48.14 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R1006 - Home Base - (48.28 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0001 - Movement - (8.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Communal Space - (333.39 SQM)	● Student Space (154)	
B00D - R0003 - Raised Platform - (88.07 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Staff Kitchen - (10.03 SQM)	● Office (2)	
B00D - R0011 - Movement - (5.6 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Withdrawal Space - 1hb - (10.21 SQM)	● Student Space (4)	
B00E - R0003 - Home Base - (46.14 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0005 - Home Base - (65 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0006 - Movement - (169.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Interview - (18.3 SQM)	● Office (4)	
B00E - R0013 - Movement - (120.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Home Base - (47.76 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0015 - Home Base - (47.35 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0016 - Home Base - (47.35 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0017 - Movement - (16.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Practical Activities - 1hb - (13.93 SQM)	● Student Space (6)	
B00E - R0026 - Practical Activities - 1hb - (7.12 SQM)	● Student Space (3)	
B00E - R0027 - Withdrawal Space - 1hb - (10.91 SQM)	● Student Space (5)	
B00E - R1001 - Home Base - (46.27 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R1002 - Home Base - (46.01 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R1003 - Home Base - (46.08 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R1005 - Practical Activities - 1hb - (13.6 SQM)	● Student Space (6)	
B00E - R1006 - Movement - (110.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R1007 - Home Base - (49.3 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R1008 - Home Base - (49.29 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R1009 - Home Base - (49.29 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R1010 - Movement - (7.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R1012 - Practical Activities - 1hb - (14.56 SQM)	● Student Space (6)	
B00I - R0002 - Entry Vestibule - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Home Base - Pre - (68.98 SQM) - Teaching Space: 1	● Student Space (32)	
B00I - R0006 - Practical Activities - Pre - (46.31 SQM)	● Student Space (21)	
B00I - R0015 - Movement - (69.37 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Special Programs Room - (43.99 SQM)	● Student Space (20)	
B00J - R0003 - Clerical Office - (8.85 SQM)	● Office (2)	
B00J - R0008 - Clerical Office - (8.69 SQM)	● Office (2)	
OS 602 10436 - OS 602 10436 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12243 - OS 602 12243 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13716 - OS 602 13716 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 602 19695 - OS 602 19695 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19587 - OS 606 19587 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 750 15502 - OS 750 15502 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	