

VENTILATION AUDIT REPORT

SCHOOL:	Granville South Creative and Performing Arts High (8436)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Auburn
LOCAL GOVERNMENT AREA:	Cumberland

8436 - Granville South Creative and Performing Arts High
Site Plan (10998)



1:1,233



Printed: 03-Oct-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (59.64 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0009 - Interview/Meeting - (9.9 SQM)	● Office (2)	
B00A - R0010 - Administration - Executive - (9.39 SQM)	● Office (2)	
B00A - R0012 - Administration - Clerical - (25.57 SQM)	● Office (6)	
B00A - R0013 - Clinic - (12.61 SQM)	● Office (3)	
B00A - R0016 - Principal Office - (19.11 SQM)	● Office (4)	
B00A - R0018 - Movement - (28.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Deputy Principal Office - (8.44 SQM)	● Office (2)	
B00A - R0021 - Administration - Executive - (8.42 SQM)	● Office (2)	
B00A - R0024 - Deputy Principal Office - (8.42 SQM)	● Office (2)	
B00A - R0030 - Staff Study - (35.63 SQM)	● Office (8)	
B00A - R0032 - Seminar - (52.33 SQM)	● Office (13)	
B00A - R0034 - Staff Study - (38.54 SQM)	● Office (9)	
B00A - R0041 - Student Reception - (14.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Administration - Clerical - (18.82 SQM)	● Office (4)	
B00A - R1001 - General Learning Space - (59.56 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1002 - General Learning Space - (53.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1003 - General Learning Space - (52.83 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1004 - General Learning Space - (59.57 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1008 - General Learning Space - (53.9 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R1011 - Design L.S. - (72.87 SQM) - Teaching Space: 1	● Student Space (33)	
B00A - R1012 - General Learning Space - (53.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1016 - Interview/Meeting - (25.26 SQM)	● Office (6)	
B00A - R1017 - General Learning Space - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1021 - Commonroom - (74.34 SQM)	● Office (18)	
B00A - R1022 - Staff Kitchen - (11.62 SQM)	● Office (2)	
B00A - R1023 - Staff Study - (26.1 SQM)	● Office (6)	
B00B - R0007 - Staff Study - (54.04 SQM)	● Office (13)	
B00B - R0010 - Practice/Seminar - (13.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Music Learning Space - (96.21 SQM) - Teaching Space: 1	● Student Space (44)	
B00B - R0013 - Staff Study - (23.75 SQM)	● Office (5)	
B00B - R0015 - Materials Learning Space - Type 1 - (95.39 SQM) - Teaching Space: 1	● Student Space (44)	
B00B - R0020 - Food Technology L.S. - (72.81 SQM) - Teaching Space: 1	● Student Space (33)	
B00B - R0022 - Preparation - (16.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Food Technology L.S. - (66.05 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1001 - Wood Technology Bay - (16.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Materials Learning Space - Type 1 - (82.38 SQM) - Teaching Space: 1	● Student Space (38)	
B00B - R1004 - Materials Learning Space - Type 1 - (82.53 SQM) - Teaching Space: 1	● Student Space (38)	
B00B - R1010 - Art Learning Space - (54.12 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1011 - Art Learning Space - (53.99 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1016 - Art Learning Space - (66.31 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1017 - Art Learning Space - (59.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1020 - Design/Technology L.S. - (53.9 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R1026 - Dark Room - (18.2 SQM)	● Office (4)	
B00B - R1027 - Staff Study - (24.19 SQM)	● Office (6)	
B00C - R0003 - Movement - (5.7 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Student Canteen - (58.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - General Assistants - (5.77 SQM)	● Office (1)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0025 - Movement - (26.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Multi-Purpose Space - (312.1 SQM)	● Student Space (144)	
B00C - R0027 - Movement - (12.85 SQM)	Not Applicable	Circulation or storage space.
B00C - R1016 - Movement - (14.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R1022 - Movement - (14.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Interview/Office - Type 1 - (13.58 SQM)	● Office (3)	
B00D - R0010 - Computer Learning Space - (50.52 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0015 - Laboratory L.S. - (86.51 SQM) - Teaching Space: 1	● Student Space (40)	
B00D - R0016 - General Learning Space - (65.11 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0025 - Laboratory L.S. - (45.73 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0026 - General Learning Space - (40.15 SQM) - Teaching Space: 1	● Student Space (18)	
B00D - R0027 - Preparation - Science - (39.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0028 - Laboratory L.S. - (49.85 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0029 - General Learning Space - (50.07 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1001 - General Learning Space - (59.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1002 - Staff Study - (26.21 SQM)	● Office (6)	
B00D - R1003 - General Learning Space - (52.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1007 - Music Learning Space - (59.4 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1013 - General Learning Space - (59.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1014 - General Learning Space - (52.94 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1015 - General Learning Space - (52.94 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1016 - General Learning Space - (59.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1017 - General Learning Space - (65.19 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1021 - Staff Study - (75.22 SQM)	● Office (18)	
B00E - R0001 - Laboratory L.S. - (86 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R0005 - Movement Studio - (92.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Fitness Laboratory - (51.7 SQM)	● Student Space (23)	
B00E - R0013 - General Learning Space - (46 SQM) - Teaching Space: 1	● Student Space (21)	
B00E - R0014 - General Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0015 - General Learning Space - (51.26 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0017 - General Learning Space - (59.84 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0023 - Performance Workspace - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0033 - Staff Study - (23.73 SQM)	● Office (5)	
B00E - R1001 - General Learning Space - (59.44 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1002 - Shared Study Space - (12.64 SQM)	● Office (3)	
B00E - R1003 - Shared Study Space - (12.57 SQM)	● Office (3)	
B00E - R1004 - Deputy Principal Office - (16.44 SQM)	● Office (4)	
B00E - R1005 - Staff Study - (8.98 SQM)	● Office (2)	
B00E - R1010 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1011 - General Learning Space - (59.61 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1015 - Staff Study - (24.56 SQM)	● Office (6)	
B00E - R1017 - Senior Study - (15.99 SQM)	● Office (3)	
B00E - R1018 - Senior Study - (16 SQM)	● Office (4)	
B00E - R1020 - Audio Visual Workroom - (19.43 SQM)	● Student Space (9)	
B00E - R1029 - Main Entry - (55.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R1030 - Main Area - (118.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R1031 - General Learning Space - (53.34 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0003 - Movement - (5.96 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0006 - Movement - (6.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Multi-Purpose Space - (478.22 SQM)	 Student Space (221)	
B00F - R0018 - Movement - (25.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Staff Kitchen - (12.46 SQM)	 Office (3)	
B00F - R0031 - Stage - (84.74 SQM)	Not Applicable	Circulation or storage space.
B00F - R1003 - Movement - (133.57 SQM)	Not Applicable	Circulation or storage space.