

VENTILATION AUDIT REPORT

SCHOOL:	Granville South Public School (2066)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Granville
LOCAL GOVERNMENT AREA:	Cumberland

2066 - Granville South Public School
Site Plan (10393)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Special Programs Room - (45.93 SQM)	● Student Space (21)	
B00A - R0002 - Home Base - (45.91 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0005 - Principal - (15.55 SQM)	● Office (3)	
B00A - R0006 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (7.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (13.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Clerical Office - (12.1 SQM)	● Office (3)	
B00A - R0013 - Entry Vestibule - (15.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Clerical Office - (80.85 SQM)	● Office (20)	
B00A - R0015 - Staff Room - (41.45 SQM)	● Office (10)	
B00A - R0021 - Staff Kitchen - (11.79 SQM)	● Office (2)	
B00A - R0023 - Staff Room - (47.42 SQM)	● Office (11)	
B00A - R0024 - Home Base - (45.58 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0025 - Home Base - (45.77 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0026 - Movement - (27.47 SQM)	Not Applicable	Circulation or storage space.
B00N - R0002 - Practical Activities - 3hb - (47.01 SQM)	● Student Space (21)	
B00N - R0003 - Home Base - (47.02 SQM) - Teaching Space: 1	● Student Space (21)	
B00O - R0002 - Home Base - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00O - R0003 - Home Base - (52.14 SQM) - Teaching Space: 1	● Student Space (24)	
B00P - R0002 - Practical Activities/Movement - 1hb - (19.12 SQM)	● Student Space (8)	
B00P - R0004 - Home Base - (60.49 SQM) - Teaching Space: 1	● Student Space (28)	
B00P - R0005 - Withdrawal Space - 2hb - (11.75 SQM)	● Student Space (5)	
B00P - R0006 - Home Base - (60.58 SQM) - Teaching Space: 1	● Student Space (28)	
B00P - R0008 - Practical Activities/Movement - 1hb - (18.66 SQM)	● Student Space (8)	
B00Q - R0002 - Practical Activities/Movement - 1hb - (19.13 SQM)	● Student Space (8)	
B00Q - R0004 - Home Base - (60.49 SQM) - Teaching Space: 1	● Student Space (28)	
B00Q - R0005 - Withdrawal Space - 2hb - (11.75 SQM)	● Student Space (5)	
B00Q - R0006 - Home Base - (60.58 SQM) - Teaching Space: 1	● Student Space (28)	
B00Q - R0008 - Practical Activities/Movement - 1hb - (18.66 SQM)	● Student Space (8)	
OS 602 12397 - OS 602 12397 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14198 - OS 602 14198 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 16794 - OS 602 16794 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 15639 - OS 606 15639 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 751 11958 - OS 751 11958 - Learning Unit - ESL - (76 SQM)	● Student Space (35)	
OS 811 14259 - OS 811 14259 - FSU/Shelter/Stores - (209 SQM)	Not Applicable	Circulation or storage space.