

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Grays Point Public School (3914)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Cronulla</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>

3914 - Grays Point Public School  
Site Plan (12679)



1:881

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal - (20.81 SQM)	Office (5)	
B00A - R0003 - Duplicating Workroom - (18.42 SQM)	Office (4)	
B00A - R0009 - Movement - (8.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Sick Bay - (7.16 SQM)	Student Space (3)	
B00A - R0013 - Movement - (29.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Clerical Office - (26.65 SQM)	Office (6)	
B00A - R0015 - Staff Room - (48.28 SQM)	Office (12)	
B00A - R0016 - Staff Kitchen - (8.81 SQM)	Office (2)	
B00B - R0001 - Movement - (115.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Reading Area - (156.19 SQM)	Student Space (72)	
B00C - R0001 - Movement - (5.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Deputy Principal - (16.33 SQM)	Office (4)	
B00C - R0005 - Movement - (8.13 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Home Base - (57.38 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0009 - Home Base - (56.76 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0012 - Movement - (6.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Home Base - (57.23 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0001 - Movement - (13.63 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Withdrawal Space - 1hb - (6.86 SQM)	Student Space (3)	
B00E - R0003 - Home Base - (56.13 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0010 - Home Base - (56.39 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0015 - Movement - (73.8 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Special Programs Room - (63.78 SQM)	Student Space (29)	
B00E - R0018 - Canteen - (30.83 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Movement - (67.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R1003 - Staff Room Annexe - (17.08 SQM)	Office (4)	
B00G - R1007 - Staff Room Annexe - (16.94 SQM)	Office (4)	
B00G - R1008 - Movement - (16.51 SQM)	Not Applicable	Circulation or storage space.
B00G - R1009 - Home Base - (56.82 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R1012 - Home Base - (56.9 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R1015 - Home Base - (57.68 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0001 - Movement - (17.42 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Movement - (25.71 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Home Base - (84.13 SQM) - Teaching Space: 1	Student Space (39)	
B00H - R0009 - Practical Activities - 1hb - (18.76 SQM)	Student Space (8)	
B00H - R0015 - Home Base - (84.44 SQM) - Teaching Space: 1	Student Space (39)	
B00H - R0017 - Practical Activities - 1hb - (18.63 SQM)	Student Space (8)	
B00H - R0018 - Movement - (5.61 SQM)	Not Applicable	Circulation or storage space.
B00H - R0022 - Movement - (36.53 SQM)	Not Applicable	Circulation or storage space.
B00H - R1002 - Movement - (83.57 SQM)	Not Applicable	Circulation or storage space.
B00H - R1004 - Practical Activities - 1hb - (21.57 SQM)	Student Space (10)	
B00H - R1005 - Home Base - (67.12 SQM) - Teaching Space: 1	Student Space (31)	
B00H - R1009 - Home Base - (69.8 SQM) - Teaching Space: 1	Student Space (32)	
B00H - R1010 - Practical Activities - 1hb - (18.46 SQM)	Student Space (8)	
B00I - R0001 - Communal Space - (138.39 SQM)	Student Space (64)	
B00I - R0002 - Raised Platform - (65.82 SQM)	Not Applicable	Circulation or storage space.
B00I - R0014 - Movement - (8.09 SQM)	Not Applicable	Circulation or storage space.
B00I - R0016 - Movement - (13.38 SQM)	Not Applicable	Circulation or storage space.
B00I - R0017 - Movement - (5.9 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 601 14507 - OS 601 14507 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 17122 - OS 602 17122 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 11143 - OS 603 11143 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 603 16315 - OS 603 16315 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	