

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Great Lakes College Senior Campus (8281)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Myall Lakes</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Mid-Coast</b>

8281 - Great Lakes College Senior Campus  
Site Plan (14614)



1:2,373

Printed: 23-Jul-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0001 - General Learning Space - Type 2 - (64.66 SQM) - Teaching Space: 1	Student Space (29)	
B00I - R0003 - General Learning Space - Type 1 - (59.55 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0004 - General Learning Space - Type 1 - (58.45 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0005 - Seminar - Type 1 - (24.36 SQM)	Office (6)	
B00I - R0006 - General Learning Space - Type 1 - (59.11 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0007 - General Learning Space - Type 1 - (59.61 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0008 - Shared Learning Space - (130.6 SQM)	Student Space (60)	
B00I - R0009 - General Learning Space - Type 2 - (64.67 SQM) - Teaching Space: 1	Student Space (30)	
B00I - R0010 - Movement - (25.74 SQM)	Not Applicable	Circulation or storage space.
B00I - R1001 - General Learning Space - Type 2 - (67.58 SQM) - Teaching Space: 1	Student Space (31)	
B00I - R1003 - General Learning Space - Type 1 - (61.82 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R1004 - General Learning Space - Type 1 - (57.93 SQM) - Teaching Space: 1	Student Space (26)	
B00I - R1005 - Seminar - Type 1 - (24.77 SQM)	Office (6)	
B00I - R1006 - General Learning Space - Type 1 - (59.7 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R1007 - General Learning Space - Type 1 - (62.54 SQM) - Teaching Space: 1	Student Space (29)	
B00I - R1008 - Shared Learning Space - (132.46 SQM)	Student Space (61)	
B00I - R1009 - General Learning Space - Type 2 - (67.41 SQM) - Teaching Space: 1	Student Space (31)	
B00I - R1010 - Movement - (26.48 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - General Learning Space - Type 8 - (61.86 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0005 - Materials Workshop - Type 2 - (125.95 SQM)	Student Space (58)	
B00J - R0007 - Outdoor Workshop - (100.29 SQM)	Not Applicable	Circulation or storage space.
B00J - R0008 - Movement - (8.35 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Visual Arts Workshop - (95.58 SQM)	Student Space (44)	
B00J - R0013 - Photographic Studio - (29.86 SQM)	Office (7)	
B00J - R0014 - Movement - (9.42 SQM)	Not Applicable	Circulation or storage space.
B00J - R0015 - Dark Room - (28.61 SQM)	Office (7)	
B00J - R0017 - General Learning Space - Type 5 - (60.14 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0018 - General Learning Space - Type 4 - (60.29 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0020 - General Learning Space - Type 9 - (59.07 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0025 - Outdoor Workshop - (110.2 SQM)	Not Applicable	Circulation or storage space.
B00S - R0003 - Materials Workshop - Type 2 - (169.7 SQM)	Student Space (78)	
BOAA - R0001 - Public Reception - (61.34 SQM)	Not Applicable	Circulation or storage space.
BOAA - R0002 - Visitors Office - (13.17 SQM)	Office (3)	
BOAA - R0003 - Administration - Clerical - (98.41 SQM)	Office (24)	
BOAA - R0004 - Movement - (48.53 SQM)	Not Applicable	Circulation or storage space.
BOAA - R0005 - Movement - (53.11 SQM)	Not Applicable	Circulation or storage space.
BOAA - R0006 - Deputy Principal Office - (12.21 SQM)	Office (3)	
BOAA - R0007 - Interview/Meeting - (10.56 SQM)	Office (2)	
BOAA - R0008 - Interview/Meeting - (9.98 SQM)	Office (2)	
BOAA - R0009 - Principal Office - (20.28 SQM)	Office (5)	
BOAA - R0010 - Interview/Office - Type 1 - (12.76 SQM)	Office (3)	
BOAA - R0011 - Principal Office - (18.97 SQM)	Office (4)	
BOAA - R0012 - Clinic - Girls - (12.63 SQM)	Office (3)	
BOAA - R0015 - Clinic - Boys - (12.32 SQM)	Office (3)	
BOAA - R0018 - Deputy Principal Office - (12.56 SQM)	Office (3)	
BOAA - R0019 - Principal Office - (19.97 SQM)	Office (4)	
BOAA - R0020 - Interview/Office - Type 1 - (12.1 SQM)	Office (3)	
BOAA - R0021 - Interview/Office - Type 1 - (11.25 SQM)	Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0AA - R0030 - Tea Room - (6.11 SQM)	Not Applicable	Circulation or storage space.
B0AA - R1001 - Main Entry - (35.57 SQM)	Not Applicable	Circulation or storage space.
B0AA - R1002 - Main Area - (392.8 SQM)	Not Applicable	Circulation or storage space.
B0AA - R1003 - Seminar - Type 3 - (14.24 SQM)	Office (3)	
B0AA - R1004 - Seminar - Type 3 - (33.27 SQM)	Office (8)	
B0AA - R1005 - Seminar - Type 3 - (16 SQM)	Office (4)	
B0AA - R1006 - Seminar - Type 3 - (16 SQM)	Office (4)	
B0AA - R1008 - Senior Study - (95.27 SQM)	Office (23)	
B0AA - R1011 - Computer Learning Space - (62.61 SQM) - Teaching Space: 1	Student Space (29)	
BOBB - R0001 - Lecture Space - (78.06 SQM)	Student Space (36)	
BOBB - R0005 - Movement - (17.31 SQM)	Not Applicable	Circulation or storage space.
BOBB - R1001 - Movement - (7.75 SQM)	Not Applicable	Circulation or storage space.
BOCC - R0003 - Movement - (48.14 SQM)	Not Applicable	Circulation or storage space.
BOCC - R0004 - Seminar - Type 1 - (20.49 SQM)	Office (5)	
BOCC - R0010 - Seminar - Type 1 - (22.24 SQM)	Office (5)	
BOCC - R0011 - Movement - (8.9 SQM)	Not Applicable	Circulation or storage space.
BOCC - R0014 - General Learning Space - Type 1 - (58.24 SQM) - Teaching Space: 1	Student Space (27)	
BOCC - R0015 - Staff Kitchen - (31.24 SQM)	Office (7)	
BOCC - R0018 - General Learning Space - Type 1 - (59.75 SQM) - Teaching Space: 1	Student Space (27)	
BOCC - R0019 - Seminar - Type 1 - (12.38 SQM)	Office (3)	
BOCC - R0026 - Movement - (124.05 SQM)	Not Applicable	Circulation or storage space.
BOCC - R0027 - Movement - (33.61 SQM)	Not Applicable	Circulation or storage space.
BOCC - R1001 - Interview/Meeting - (13.15 SQM)	Office (3)	
BOCC - R1002 - Interview/Meeting - (13.19 SQM)	Office (3)	
BOCC - R1007 - Staff Lounge - (28.88 SQM)	Office (7)	
BOCC - R1011 - Interview/Meeting - (13.04 SQM)	Office (3)	
BOCC - R1012 - Interview/Meeting - (13.04 SQM)	Office (3)	
BOCC - R1013 - Staff Lounge - (13.12 SQM)	Office (3)	
BOCC - R1014 - Staff Study - (130.93 SQM)	Office (32)	
BOCC - R1015 - Staff Study - (123.2 SQM)	Office (30)	
BOCC - R1016 - Staff Lounge - (118.54 SQM)	Office (29)	
BOCC - R1017 - Staff Study - (123.09 SQM)	Office (30)	
BOCC - R1018 - Staff Study - (123.94 SQM)	Office (30)	
BOCC - R1020 - Staff Lounge - (17.45 SQM)	Office (4)	
BOCC - R1023 - Movement - (114.37 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0002 - Kitchen - Type 1 - (99.81 SQM)	Student Space (46)	
B0DD - R0004 - Preparation - Materials - (23.8 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0006 - Kitchen - Type 1 - (99.39 SQM)	Student Space (46)	
B0DD - R0008 - General Learning Space - Type 6 - (59.61 SQM) - Teaching Space: 1	Student Space (27)	
B0DD - R0009 - General Learning Space - Type 7 - (58.75 SQM) - Teaching Space: 1	Student Space (27)	
B0DD - R0010 - Seminar - Type 2 - (20.89 SQM)	Office (5)	
B0DD - R0011 - Seminar - Type 2 - (20.89 SQM)	Office (5)	
B0DD - R1001 - Science Laboratory - (103.46 SQM)	Student Space (48)	
B0DD - R1002 - Preparation - Science - (65.61 SQM)	Not Applicable	Circulation or storage space.
B0DD - R1003 - Science Laboratory - (109.3 SQM)	Student Space (50)	
B0DD - R1005 - General Learning Space - Type 3 - (63.12 SQM) - Teaching Space: 1	Student Space (29)	
B0DD - R1006 - General Learning Space - Type 3 - (65.3 SQM) - Teaching Space: 1	Student Space (30)	
B0DD - R1008 - Seminar - Type 2 - (17.25 SQM)	Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOEE - R0004 - Outdoor Workshop - (88.16 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0006 - Visual Arts Workshop - (100.57 SQM)	● Student Space (46)	
BOEE - R0008 - Dark Room - (34.95 SQM)	● Office (8)	
BOEE - R0016 - Materials Workshop - Type 2 - (119.28 SQM)	● Student Space (55)	
BOEE - R0020 - Staff Study - (9.96 SQM)	● Office (2)	
BOEE - R0022 - Welding/Hot Metals Area - (7.75 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0029 - Welding/Hot Metals Area - (5.92 SQM)	Not Applicable	Circulation or storage space.
BOEE - R1001 - Shared Learning Space - (163.01 SQM)	● Student Space (75)	
BOEE - R1006 - Seminar - Type 1 - (25.28 SQM)	● Office (6)	
BOEE - R1009 - Movement - (35.12 SQM)	Not Applicable	Circulation or storage space.
BOFF - R0001 - Gymnasium - (620.35 SQM)	● Student Space (287)	
BOFF - R0004 - Stage - (54.18 SQM)	Not Applicable	Circulation or storage space.
BOFF - R0006 - Movement - (6.99 SQM)	Not Applicable	Circulation or storage space.
BOFF - R0011 - Movement Studio - (159.88 SQM)	Not Applicable	Circulation or storage space.
BOGG - R0001 - Practice/Seminar - (19.54 SQM)	Not Applicable	Circulation or storage space.
BOGG - R0003 - Performance Workshop - (100.82 SQM)	● Student Space (46)	
BOGG - R0006 - Fitness Laboratory - (95.6 SQM)	● Student Space (44)	
BOGG - R0007 - Practice/Seminar - (20.29 SQM)	Not Applicable	Circulation or storage space.
BOGG - R0009 - Practice/Seminar - (19.5 SQM)	Not Applicable	Circulation or storage space.
BOGG - R0011 - Performance Workshop - (106.31 SQM)	● Student Space (49)	
BOGG - R0018 - General Learning Space - Type 1 - (59.15 SQM) - Teaching Space: 1	● Student Space (27)	
BOGG - R0019 - General Learning Space - Type 1 - (60.15 SQM) - Teaching Space: 1	● Student Space (27)	
BOGG - R0020 - General Learning Space - Type 1 - (58.73 SQM) - Teaching Space: 1	● Student Space (27)	
BOHH - R0001 - Student Canteen - (93.85 SQM)	Not Applicable	Circulation or storage space.
BOHH - R0006 - Student Canteen - (136.05 SQM)	Not Applicable	Circulation or storage space.
OS 520 80068 - OS 520 80068 - Staff Study - (57 SQM)	● Office (14)	
OS 601 14211 - OS 601 14211 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 606 15862 - OS 606 15862 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 621 19534 - OS 621 19534 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	