


VENTILATION AUDIT REPORT

SCHOOL:	Green Valley Public School (2075)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Liverpool
LOCAL GOVERNMENT AREA:	Liverpool

2075 - Green Valley Public School
Site Plan (11552)



1:1,236

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0004 - Staff Kitchen - (7.66 SQM)	Office (1)	
B00G - R0003 - Practical Activities - 1hb - (13.84 SQM)	Student Space (6)	
B00G - R0004 - Practical Activities - 1hb - (13.84 SQM)	Student Space (6)	
B00G - R0006 - Home Base - (59.94 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0007 - Special Programs Room - (59.94 SQM)	Student Space (27)	
B00G - R0009 - Outdoor Learning Area - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Withdrawal Space - 1hb - (12.28 SQM)	Student Space (5)	
B00G - R0011 - Outdoor Learning Area - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Practical Activities - 1hb - (13.84 SQM)	Student Space (6)	
B00H - R0004 - Practical Activities - 1hb - (13.84 SQM)	Student Space (6)	
B00H - R0006 - Home Base - (59.94 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0007 - Home Base - (59.94 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0009 - Outdoor Learning Area - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Withdrawal Space - 1hb - (12.28 SQM)	Student Space (5)	
B00H - R0011 - Outdoor Learning Area - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Practical Activities - 1hb - (19.42 SQM)	Student Space (9)	
B00I - R0002 - Home Base - (59.01 SQM) - Teaching Space: 1	Student Space (27)	
B00I - R0004 - Withdrawal Space - 2hb - (11.87 SQM)	Student Space (5)	
B00I - R0005 - Practical Activities - 1hb - (19.46 SQM)	Student Space (9)	
B00I - R0006 - Home Base - (60.11 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0003 - Practical Activities - 1hb - (13.84 SQM)	Student Space (6)	
B00J - R0004 - Practical Activities - 1hb - (13.84 SQM)	Student Space (6)	
B00J - R0006 - Home Base - (59.94 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0007 - Home Base - (59.94 SQM) - Teaching Space: 1	Student Space (27)	
B00J - R0009 - Outdoor Learning Area - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Withdrawal Space - 1hb - (12.28 SQM)	Student Space (5)	
B00J - R0011 - Outdoor Learning Area - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Practical Activities - 1hb - (19.42 SQM)	Student Space (9)	
B00K - R0002 - Home Base - (59.01 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0004 - Withdrawal Space - 2hb - (11.87 SQM)	Student Space (5)	
B00K - R0005 - Practical Activities - 1hb - (19.46 SQM)	Student Space (9)	
B00K - R0006 - Home Base - (60.11 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0001 - Reading Area - (170.12 SQM)	Student Space (78)	
B00M - R0002 - Practical Activities - 1hb - (19.39 SQM)	Student Space (8)	
B00M - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0005 - Withdrawal Space - 2hb - (11.35 SQM)	Student Space (5)	
B00M - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0008 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00N - R0002 - Entry Vestibule - (23.09 SQM)	Not Applicable	Circulation or storage space.
B00N - R0003 - Clerical Office - (34.86 SQM)	Office (8)	
B00N - R0004 - Duplicating Workroom - (24.46 SQM)	Office (6)	
B00N - R0005 - Movement - (60.78 SQM)	Not Applicable	Circulation or storage space.
B00N - R0006 - Interview - (16.58 SQM)	Office (4)	
B00N - R0007 - Principal - (17.31 SQM)	Office (4)	
B00N - R0008 - Deputy Principal - (13.25 SQM)	Office (3)	
B00N - R0009 - Deputy Principal - (13.37 SQM)	Office (3)	
B00N - R0010 - Sick Bay - (8.85 SQM)	Student Space (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R0012 - Staff Kitchen - (7.99 SQM)	Office (1)	
B00N - R0013 - Staff Room - (56.85 SQM)	Office (14)	
B00N - R0014 - Staff Room - (27.98 SQM)	Office (6)	
B00N - R0019 - Interview - (18.07 SQM)	Office (4)	
B00O - R0006 - Canteen - (44.2 SQM)	Not Applicable	Circulation or storage space.
B00O - R0011 - Communal Space - (186.33 SQM)	Student Space (86)	
B00O - R0012 - Raised Platform - (70.51 SQM)	Not Applicable	Circulation or storage space.
B00O - R0013 - Movement - (16.02 SQM)	Not Applicable	Circulation or storage space.
B00O - R0014 - Movement - (16 SQM)	Not Applicable	Circulation or storage space.
B00P - R0004 - Movement - (6.22 SQM)	Not Applicable	Circulation or storage space.
B00P - R0005 - Special Programs Room - (33.01 SQM)	Student Space (15)	
B00P - R0007 - Practical Activities - 1hb - (19.09 SQM)	Student Space (8)	
B00P - R0009 - Home Base - (60.12 SQM) - Teaching Space: 1	Student Space (27)	
B00P - R0010 - Withdrawal Space - 2hb - (11.77 SQM)	Student Space (5)	
B00P - R0011 - Home Base - (60.06 SQM) - Teaching Space: 1	Student Space (27)	
B00P - R0012 - Practical Activities - 1hb - (19.69 SQM)	Student Space (9)	
B00Q - R0001 - Practical Activities - 1hb - (19.11 SQM)	Student Space (8)	
B00Q - R0002 - Home Base - (60.02 SQM) - Teaching Space: 1	Student Space (27)	
B00Q - R0004 - Withdrawal Space - 2hb - (11.74 SQM)	Student Space (5)	
B00Q - R0005 - Practical Activities - 1hb - (19.67 SQM)	Student Space (9)	
B00Q - R0006 - Home Base - (60.2 SQM) - Teaching Space: 1	Student Space (27)	
B00R - R0002 - Practical Activities - 1hb - (21.61 SQM)	Student Space (10)	
B00R - R0004 - Home Base - (62.71 SQM) - Teaching Space: 1	Student Space (29)	
B00R - R0005 - Withdrawal Space - 2hb - (10.83 SQM)	Student Space (5)	
B00R - R0006 - Home Base - (62.73 SQM) - Teaching Space: 1	Student Space (29)	
B00R - R0008 - Practical Activities - 1hb - (21.61 SQM)	Student Space (10)	
OS 601 11418 - OS 601 11418 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	