


VENTILATION AUDIT REPORT

SCHOOL:	Greenethorpe Public School (2070)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Cootamundra
LOCAL GOVERNMENT AREA:	Weddin

2070 - Greenethorpe Public School
Site Plan (12683)













1:539

Printed: 30-Oct-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (24.29 SQM)	 Office (6)	
B00A - R0004 - Movement - (9.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Entry Vestibule - (8.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Clerical Office - (10.63 SQM)	 Office (2)	
B00A - R0008 - Principal - (13.78 SQM)	 Office (3)	
B00B - R0002 - Reading Area - (43.62 SQM) - Teaching Space: 1	 Student Space (20)	
B00B - R0003 - Home Base - (44.01 SQM) - Teaching Space: 1	 Student Space (20)	
B00B - R0004 - Duplicating Workroom - (11.1 SQM)	 Office (2)	
B00B - R0005 - Home Base - (48.28 SQM)	 Student Space (22)	
B00B - R0006 - Withdrawal Space - 1hb - (11.66 SQM)	 Student Space (5)	
B00B - R0007 - Movement - (35.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (47.74 SQM) - Teaching Space: 1	 Student Space (22)	
B00B - R0009 - Movement - (13.32 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Home Base - (59.86 SQM) - Teaching Space: 1	 Student Space (27)	