

VENTILATION AUDIT REPORT

SCHOOL:	Greenwich Public School (2076)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Lane Cove
LOCAL GOVERNMENT AREA:	Lane Cove

2076 - Greenwich Public School
Site Plan (12689)



1:511

Printed: 07-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (6.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Staff Room - (27.76 SQM)	Office (6)	
B00A - R0010 - Clerical Office - (17.42 SQM)	Office (4)	
B00A - R0012 - Raised Platform - (23.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Duplicating Workroom - (17.39 SQM)	Office (4)	
B00A - R0023 - Movement - (45.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Staff Kitchen - (20.64 SQM)	Office (5)	
B00A - R0026 - Staff Room - (51.72 SQM)	Office (12)	
B00A - R0027 - Movement - (25.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (15.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Clerical Office - (36.77 SQM)	Office (9)	
B00A - R0032 - Clerical/Printing - (8.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Sick Bay - (15.7 SQM)	Student Space (7)	
B00A - R1003 - Interview - (10.91 SQM)	Office (2)	
B00A - R1005 - Reading Area - (64.46 SQM)	Student Space (29)	
B00A - R1011 - Home Base - (48.64 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1016 - Movement - (36 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Interview - (16.6 SQM)	Office (4)	
B00A - R1018 - Deputy Principal - (23.95 SQM)	Office (5)	
B00A - R1019 - Home Base - (37.63 SQM) - Teaching Space: 1	Student Space (17)	
B00A - R1020 - Practical Activities - (6.32 SQM)	Student Space (2)	
B00B - R0001 - Home Base - (56.72 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0004 - Movement - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Movement - (5.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R9001 - Movement - (8.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R9002 - Canteen - (30.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Movement - (15.18 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (52.59 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0002 - Home Base - (52.39 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0004 - Movement - (26.41 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Deputy Principal - (16.02 SQM)	Office (4)	
B00H - R0009 - Movement - (46.28 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Practical Activities - 1hb - (14.44 SQM)	Student Space (6)	
B00H - R0014 - Home Base - (48.73 SQM) - Teaching Space: 1	Student Space (22)	
B00H - R0015 - Movement - (8.52 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Clerical Office - (18.82 SQM)	Office (4)	
B00H - R0018 - Duplicating Workroom - (17.68 SQM)	Office (4)	
B00H - R0019 - Duplicating Workroom - (17.05 SQM)	Office (4)	
B00H - R1001 - Home Base - (50.16 SQM) - Teaching Space: 1	Student Space (23)	
B00H - R1002 - Staff Room - (21.54 SQM)	Office (5)	
B00H - R1003 - Movement - (79.65 SQM)	Not Applicable	Circulation or storage space.
B00H - R1004 - Home Base - (51.23 SQM) - Teaching Space: 1	Student Space (23)	
B00H - R1005 - Home Base - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00I - R0003 - Movement - (17.57 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Raised Platform - (63.01 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Movement - (16.91 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Movement - (12.24 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Communal Space - (276.54 SQM)	Student Space (128)	
B00M - R0002 - Clerical Office - (8.67 SQM)	Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B000 - R0001 - Movement - (29.26 SQM)	Not Applicable	Circulation or storage space.
B000 - R0002 - Movement - (17.06 SQM)	Not Applicable	Circulation or storage space.
B000 - R0003 - Withdrawal Space - 2hb - (11.88 SQM)	● Student Space (5)	
B000 - R0019 - Practical Activities - 4hb - (108.93 SQM)	● Student Space (50)	
B000 - R0020 - Movement - (17.12 SQM)	Not Applicable	Circulation or storage space.
B000 - R0021 - Home Base - (64.22 SQM) - Teaching Space: 1	● Student Space (29)	
B000 - R0022 - Home Base - (65.11 SQM) - Teaching Space: 1	● Student Space (30)	
B000 - R0023 - Home Base - (65.44 SQM) - Teaching Space: 1	● Student Space (30)	
B000 - R0024 - Home Base - (65.35 SQM) - Teaching Space: 1	● Student Space (30)	
B000 - R0025 - Home Base - (65.42 SQM) - Teaching Space: 1	● Student Space (30)	
B000 - R0026 - Home Base - (65.48 SQM) - Teaching Space: 1	● Student Space (30)	
B000 - R0027 - Home Base - (61.51 SQM) - Teaching Space: 1	● Student Space (28)	
B000 - R0028 - Home Base - (63.53 SQM) - Teaching Space: 1	● Student Space (29)	
B000 - R0029 - Home Base - (61.01 SQM) - Teaching Space: 1	● Student Space (28)	
B000 - R0030 - Withdrawal Space - 2hb - (12.45 SQM)	● Student Space (5)	
B000 - R0031 - Withdrawal Space - 2hb - (12.45 SQM)	● Student Space (5)	
B000 - R0032 - Practical Activities - 4hb - (120.32 SQM)	● Student Space (55)	
B000 - R0033 - Tiered Learning Space - (24.23 SQM)	● Student Space (11)	
B000 - R0034 - Special Programs Room - (107.4 SQM)	● Student Space (49)	
B000 - R0035 - Withdrawal Space - 2hb - (12.33 SQM)	● Student Space (5)	
B000 - R1001 - Movement - (29.47 SQM)	Not Applicable	Circulation or storage space.
B000 - R1002 - Movement - (7.39 SQM)	Not Applicable	Circulation or storage space.
B000 - R1003 - Withdrawal Space - 2hb - (11.96 SQM)	● Student Space (5)	
B000 - R1020 - Home Base - (64.28 SQM) - Teaching Space: 1	● Student Space (29)	
B000 - R1021 - Home Base - (65.04 SQM) - Teaching Space: 1	● Student Space (30)	
B000 - R1022 - Home Base - (65 SQM) - Teaching Space: 1	● Student Space (30)	
B000 - R1023 - Home Base - (65.36 SQM) - Teaching Space: 1	● Student Space (30)	
B000 - R1024 - Home Base - (65.27 SQM) - Teaching Space: 1	● Student Space (30)	
B000 - R1025 - Home Base - (65.26 SQM) - Teaching Space: 1	● Student Space (30)	
B000 - R1026 - Home Base - (61.69 SQM) - Teaching Space: 1	● Student Space (28)	
B000 - R1027 - Home Base - (63.76 SQM) - Teaching Space: 1	● Student Space (29)	
B000 - R1028 - Home Base - (61.01 SQM) - Teaching Space: 1	● Student Space (28)	
B000 - R1029 - Withdrawal Space - 2hb - (12.46 SQM)	● Student Space (5)	
B000 - R1030 - Withdrawal Space - 2hb - (12.46 SQM)	● Student Space (5)	
B000 - R1031 - Tiered Learning Space - (24.29 SQM)	● Student Space (11)	
B000 - R1032 - Practical Activities - 4hb - (120.71 SQM)	● Student Space (56)	
B000 - R1033 - Practical Activities - 4hb - (109.49 SQM)	● Student Space (50)	
B000 - R1034 - Special Programs Room - (106.96 SQM)	● Student Space (49)	
B000 - R1035 - Withdrawal Space - 1hb - (12.3 SQM)	● Student Space (5)	
B000 - R2001 - Movement - (29.97 SQM)	Not Applicable	Circulation or storage space.
B000 - R2017 - Movement - (7.29 SQM)	Not Applicable	Circulation or storage space.
B000 - R2022 - Clerical Office - (32.76 SQM)	● Office (8)	
B00P - R0001 - Home Base - (64.36 SQM) - Teaching Space: 1	● Student Space (29)	
B00P - R0002 - Home Base - (65.52 SQM) - Teaching Space: 1	● Student Space (30)	
B00P - R0003 - Home Base - (65.22 SQM) - Teaching Space: 1	● Student Space (30)	
B00P - R0004 - Home Base - (64.85 SQM) - Teaching Space: 1	● Student Space (30)	
B00P - R0005 - Practical Activities - 4hb - (209.53 SQM)	● Student Space (97)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R0006 - Tiered Learning Space - (17.56 SQM)	● Student Space (8)	
B00P - R0007 - Withdrawal Space - 2hb - (19.84 SQM)	● Student Space (9)	
B00P - R0008 - Withdrawal Space - 2hb - (12.24 SQM)	● Student Space (5)	
B00P - R0020 - Movement - (30.7 SQM)	Not Applicable	Circulation or storage space.
B00P - R1001 - Home Base - (64.36 SQM) - Teaching Space: 1	● Student Space (29)	
B00P - R1002 - Home Base - (65.52 SQM) - Teaching Space: 1	● Student Space (30)	
B00P - R1003 - Home Base - (65.22 SQM) - Teaching Space: 1	● Student Space (30)	
B00P - R1004 - Home Base - (64.85 SQM) - Teaching Space: 1	● Student Space (30)	
B00P - R1006 - Withdrawal Space - 2hb - (21.26 SQM)	● Student Space (9)	
B00P - R1008 - Withdrawal Space - 2hb - (12.24 SQM)	● Student Space (5)	
B00P - R1009 - Practical Activities - 4hb - (209.66 SQM)	● Student Space (97)	
B00P - R1018 - Movement - (32.02 SQM)	Not Applicable	Circulation or storage space.
OS 523 15833 - OS 523 15833 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 601 11360 - OS 601 11360 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14943 - OS 601 14943 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14944 - OS 601 14944 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10138 - OS 602 10138 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11093 - OS 602 11093 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 12794 - OS 603 12794 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 16275 - OS 603 16275 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	