


VENTILATION AUDIT REPORT

SCHOOL:	Greystanes High School (8385)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Prospect
LOCAL GOVERNMENT AREA:	Cumberland

8385 - Greystanes High School
Site Plan (11001)



1:1,567





















Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Laboratory L.S. - (86.24 SQM) - Teaching Space: 1	● Student Space (40)	
B00A - R0010 - Movement - (116.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Food Technology L.S. - (66.49 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0027 - Staff Study - (42 SQM)	● Office (10)	
B00A - R0028 - Special Learning Space - (100.65 SQM) - Teaching Space: 1	● Student Space (46)	
B00A - R0029 - General Learning Space - (37.81 SQM) - Teaching Space: 1	● Student Space (17)	
B00A - R0030 - General Learning Space - (94.45 SQM) - Teaching Space: 1	● Student Space (43)	
B00A - R1001 - General Learning Space - (53.16 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1006 - General Learning Space - (52.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1007 - General Learning Space - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1008 - Staff Study - (25.28 SQM)	● Office (6)	
B00A - R1011 - Movement - (111.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - General Learning Space - (39.87 SQM) - Teaching Space: 1	● Student Space (18)	
B00A - R1013 - General Learning Space - (65.44 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1017 - Materials Technology L.S. - (65.73 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1018 - Design L.S. - (51.65 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1025 - Staff Study - (47.51 SQM)	● Office (11)	
B00B - R0007 - Movement - (6.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Movement - (326.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Student Canteen - (52.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Movement - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Materials Technology L.S. - (78.37 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R0009 - Materials Technology L.S. - (79.3 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R0011 - Materials Technology L.S. - (75.08 SQM) - Teaching Space: 1	● Student Space (34)	
B00C - R0018 - Movement - (102.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Computer Learning Space - (38.87 SQM) - Teaching Space: 1	● Student Space (18)	
B00C - R0020 - Metal Technology Bay - (78.84 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Metal Technology Bay - (13.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Staff Study - (66 SQM)	● Office (16)	
B00D - R0002 - General Learning Space - (51.28 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0003 - General Learning Space - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0004 - Staff Kitchen - (17.05 SQM)	● Office (4)	
B00D - R0005 - Clinic - Boys - (20.95 SQM)	● Office (5)	
B00D - R0021 - Deputy Principal - (25.57 SQM)	● Office (6)	
B00D - R0022 - Art Learning Space - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0023 - Art Learning Space - (51.93 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0024 - Visual Arts Workshop - (16.78 SQM)	● Student Space (7)	
B00D - R0028 - Clinic-Waiting - (16.87 SQM)	● Office (4)	
B00D - R0029 - Interview/Office - Type 1 - (11.86 SQM)	● Office (2)	
B00D - R0030 - Administration - Clerical - (6.99 SQM)	● Office (1)	
B00D - R0031 - Deputy Principal Office - (21.01 SQM)	● Office (5)	
B00D - R0033 - Public Entry - (35.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0037 - Administration - Clerical - (64.41 SQM)	● Office (16)	
B00D - R0038 - Principal Office - (26.99 SQM)	● Office (6)	
B00D - R0039 - Movement - (59.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R0040 - Movement - (58.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - General Learning Space - (53.09 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1002 - General Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1008 - Movement - (105.53 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1009 - Movement - (37.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R1010 - General Learning Space - (52.95 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1011 - General Learning Space - (65.49 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1014 - Music Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1016 - Music Learning Space - (66.36 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1017 - Staff Study - (64.66 SQM)	● Office (16)	
B00D - R1019 - General Learning Space - (52.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0002 - Movement - (122.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - General Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0004 - General Learning Space - (52.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0005 - General Learning Space - (52 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0006 - General Learning Space - (52.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0007 - Staff Study - (25.14 SQM)	● Office (6)	
B00E - R0010 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0011 - Laboratory L.S. - (85.23 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R0012 - Preparation - (34.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Laboratory L.S. - (85.95 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R1001 - General Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1002 - General Learning Space - (52.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1003 - General Learning Space - (52.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1004 - General Learning Space - (52.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1005 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1006 - Movement - (114 SQM)	Not Applicable	Circulation or storage space.
B00E - R1007 - General Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1008 - General Learning Space - (52.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1009 - General Learning Space - (52.15 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1010 - Staff Study - (51.72 SQM)	● Office (12)	
B00E - R1011 - Staff Study - (25.28 SQM)	● Office (6)	
B00F - R0004 - Stage - (110.91 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Multi-Purpose Space - (454.86 SQM)	● Student Space (211)	
B00F - R0009 - Student Canteen - (17.57 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Entry - (69.36 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Movement - (16.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Laboratory L.S. - (100.62 SQM) - Teaching Space: 1	● Student Space (46)	
B00G - R0009 - Laboratory L.S. - (92.78 SQM) - Teaching Space: 1	● Student Space (43)	
B00G - R0012 - General Learning Space - (60.41 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0013 - Darkroom Space - (25.42 SQM)	● Office (6)	
B00G - R0026 - Laboratory L.S. - (100.35 SQM) - Teaching Space: 1	● Student Space (46)	
B00G - R0027 - Movement - (247.37 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Preparation - Science - (11.19 SQM)	Not Applicable	Circulation or storage space.
B00G - R0032 - Staff Room - (74.07 SQM)	● Office (18)	
B00G - R0033 - Movement - (81.73 SQM)	Not Applicable	Circulation or storage space.
B00G - R0036 - Staff Study - (39.31 SQM)	● Office (9)	
B00G - R0037 - Preparation - Science - (39.49 SQM)	Not Applicable	Circulation or storage space.
B00G - R0039 - Staff Study - (49.53 SQM)	● Office (12)	
B00G - R1001 - Staff Room Annexe - (33.6 SQM)	● Office (8)	
B00G - R1008 - Art Learning Space - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1009 - Art Learning Space - (52.29 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R1012 - Deputy Principal Office - (16.97 SQM)	 Office (4)	
B00G - R1013 - Administration - Clerical - (10.05 SQM)	 Office (2)	
B00G - R1014 - Movement - (6.21 SQM)	Not Applicable	Circulation or storage space.
B00G - R1019 - General Learning Space - (60.39 SQM) - Teaching Space: 1	 Student Space (28)	
B00G - R1022 - General Learning Space - (52.58 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R1023 - General Learning Space - (52.58 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R1024 - Special Learning Space - (52.58 SQM) - Teaching Space: 1	 Student Space (24)	
B00G - R1027 - General Learning Space - (60.25 SQM) - Teaching Space: 1	 Student Space (27)	
B00G - R1032 - Ancillary Staff - (15.32 SQM)	 Office (3)	
B00G - R1034 - Administration - Clerical - (21.27 SQM)	 Office (5)	
B00G - R1035 - Movement - (224.43 SQM)	Not Applicable	Circulation or storage space.
B00G - R1036 - Staff Study - (12.75 SQM)	 Office (3)	
B00G - R1043 - Staff Study - (37.01 SQM)	 Office (9)	
B00H - R0010 - Seminar - (13.4 SQM)	 Office (3)	
B00H - R0011 - Senior Study - (20.71 SQM)	 Office (5)	
B00H - R0014 - Entry - (7.74 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Main Area - (336.23 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Senior Study - (63.77 SQM)	 Office (15)	
B00H - R0019 - Staff Study - (28.98 SQM)	 Office (7)	
B00H - R0021 - Staff Lounge - (13.2 SQM)	 Office (3)	
B00H - R0022 - Staff Kitchen - (7.46 SQM)	 Office (1)	
B00I - R0001 - Performance Workspace - (95.07 SQM) - Teaching Space: 1	 Student Space (44)	
B00I - R0002 - Gymnasium - (127.47 SQM)	 Student Space (59)	