


VENTILATION AUDIT REPORT

SCHOOL:	Greystanes Public School (2086)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Prospect
LOCAL GOVERNMENT AREA:	Cumberland

2086 - Greystanes Public School
Site Plan (12690)



1:1,221

Printed: 12-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Practical Activities - 1hb - (12.6 SQM)	● Student Space (5)	
B00A - R0005 - Home Base - (42.15 SQM) - Teaching Space: 1	● Student Space (19)	
B00A - R0006 - Home Base - (42.55 SQM) - Teaching Space: 1	● Student Space (19)	
B00A - R0007 - Practical Activities - 1hb - (13.45 SQM)	● Student Space (6)	
B00A - R0009 - Movement - (6.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (47.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Movement - (50.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Movement - (94.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Movement - (6.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Principal - (20.77 SQM)	● Office (5)	
B00A - R1011 - Duplicating Workroom - (8.72 SQM)	● Office (2)	
B00A - R1018 - Home Base - (57.17 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1022 - Home Base - (56.77 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1023 - Movement - (13.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - Clerical Office - (16.39 SQM)	● Office (4)	
B00A - R1026 - Staff Room - (64.82 SQM)	● Office (16)	
B00A - R1027 - Movement - (19.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R1028 - Movement - (23.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R1029 - Clerical/Printing - (25.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R1030 - Clerical Office - (9.67 SQM)	● Office (2)	
B00A - R1035 - Clerical Office - (8.83 SQM)	● Office (2)	
B00B - R0005 - Home Base - (85.81 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R0006 - Home Base - (56.59 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0010 - Home Base - (55.87 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0011 - Movement - (8.39 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (35.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Deputy Principal - (17.31 SQM)	● Office (4)	
B00B - R0016 - Staff Room Annexe - (21.07 SQM)	● Office (5)	
B00B - R9003 - Practical Activities - 1hb - (55.5 SQM)	● Student Space (25)	
B00C - R0002 - Home Base - (57.13 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0004 - Home Base - (57.13 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0007 - Special Programs Room - (57.13 SQM)	● Student Space (26)	
B00C - R0009 - Movement - (50.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Seminar/Study - (16.32 SQM)	● Office (4)	
B00D - R0003 - Reading Area - (175.27 SQM)	● Student Space (81)	
B00D - R0006 - Entry Vestibule - (12.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Movement - (23.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (28.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (22.43 SQM)	● Student Space (10)	
B00E - R0003 - Communal Space - (135.97 SQM)	● Student Space (63)	
B00E - R0006 - Movement - (36.06 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Home Base - (66.62 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R0006 - Home Base - (63.78 SQM) - Teaching Space: 1	● Student Space (29)	
B00F - R0007 - Practical Activities - 1hb - (5.51 SQM)	● Student Space (2)	
B00F - R0008 - Movement - (56.95 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Home Base - (70.29 SQM) - Teaching Space: 1	● Student Space (32)	
B00F - R1003 - Home Base - (67.6 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R1004 - Home Base - (51.53 SQM) - Teaching Space: 1	● Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1005 - Practical Activities - 1hb - (16 SQM)	● Student Space (7)	
B00F - R1006 - Movement - (56.98 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Home Base - (52.49 SQM)	● Student Space (24)	
B00G - R0005 - Movement - (9.84 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Movement - (13.05 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (13.91 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Canteen - (18.56 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Movement - (12.35 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Movement - (46.35 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Communal Space - (202.94 SQM)	● Student Space (94)	
B00J - R0002 - Raised Platform - (61.49 SQM)	Not Applicable	Circulation or storage space.
B00J - R0017 - Movement - (5.65 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Movement - (13.59 SQM)	Not Applicable	Circulation or storage space.
B00J - R0025 - Canteen - (41.57 SQM)	Not Applicable	Circulation or storage space.
OS 601 10143 - OS 601 10143 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 10427 - OS 601 10427 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 70105 - OS 601 70105 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10058 - OS 602 10058 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11159 - OS 602 11159 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11652 - OS 602 11652 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11937 - OS 602 11937 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13619 - OS 602 13619 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13693 - OS 602 13693 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14516 - OS 602 14516 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14726 - OS 602 14726 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15743 - OS 602 15743 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 17726 - OS 602 17726 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 10396 - OS 603 10396 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 11221 - OS 603 11221 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	