



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Canteen - (16.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Practical Activities - 1hb - (26.18 SQM)	● Student Space (12)	
B00B - R0007 - Home Base - (65.79 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0008 - Movement - (13.39 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (11.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Home Base - (51.2 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0011 - Practical Activities - 1hb - (18.33 SQM)	● Student Space (8)	
B00B - R0014 - Home Base - (51.83 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0015 - Practical Activities - 1hb - (17.53 SQM)	● Student Space (8)	
B00B - R0016 - Movement - (64.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (6.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (64.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Staff Room - (45.85 SQM)	○ Office (11)	
B00B - R1007 - Staff Room Annexe - (13.63 SQM)	○ Office (3)	
B00B - R1009 - Movement - (29.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Principal - (15.97 SQM)	○ Office (3)	
B00B - R1011 - Home Base - (51.37 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R1012 - Staff Room Annexe - (11.77 SQM)	○ Office (2)	
B00B - R1013 - Entry Vestibule - (12.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R1014 - Clerical Office - (12.47 SQM)	○ Office (3)	
B00B - R1015 - Duplicating Workroom - (13.28 SQM)	○ Office (3)	
B00B - R1016 - Sick Bay - (11.46 SQM)	● Student Space (5)	
B00B - R1017 - Staff Room - (16.21 SQM)	○ Office (4)	
B00B - R1018 - Practical Activities - 1hb - (18.29 SQM)	● Student Space (8)	
B00B - R1019 - Clerical Office - (6.67 SQM)	○ Office (1)	
B00B - R1020 - Sick Bay - (6.33 SQM)	● Student Space (2)	
B00C - R0001 - Movement - (33.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practical Activities - 1hb - (16.52 SQM)	● Student Space (7)	
B00C - R0003 - Home Base - (59.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0005 - Movement - (13.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Withdrawal Space - 1hb - (11.87 SQM)	● Student Space (5)	
B00C - R0007 - Movement - (13.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Home Base - (59.7 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0010 - Practical Activities - 1hb - (17.61 SQM)	● Student Space (8)	
B00D - R0001 - Practical Activities - 1hb - (17.01 SQM)	● Student Space (7)	
B00D - R0002 - Home Base - (59.9 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0004 - Movement - (14.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Special Programs Room - (11.77 SQM)	● Student Space (5)	
B00D - R0006 - Practical Activities - 1hb - (17.03 SQM)	● Student Space (7)	
B00D - R0007 - Home Base - (59.77 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0009 - Movement - (14.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Movement - (36.41 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Communal Space - (199.1 SQM)	● Student Space (92)	
B00H - R0002 - Raised Platform - (58.82 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (7.69 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (15.01 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Movement - (11.24 SQM)	Not Applicable	Circulation or storage space.
OS 534 15212 - OS 534 15212 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	
OS 601 14261 - OS 601 14261 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 603 13735 - OS 603 13735 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	

