

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Guise Public School (4461)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Macquarie Fields</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Campbelltown</b>

4461 - Guise Public School  
Site Plan (10396)



1:1,358

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Practical Activities - 1hb - (9.93 SQM)	Student Space (4)	
B00A - R0003 - Home Base - (89.28 SQM) - Teaching Space: 1	Student Space (41)	
B00A - R0004 - Home Base - (89.29 SQM) - Teaching Space: 1	Student Space (41)	
B00A - R0005 - Practical Activities - 1hb - (9.93 SQM)	Student Space (4)	
B00A - R0018 - Communal Space - (114.06 SQM)	Student Space (52)	
B00A - R0019 - Withdrawal Space - 1hb - (33.87 SQM)	Student Space (15)	
B00A - R0021 - Practical Activities - 1hb - (9.93 SQM)	Student Space (4)	
B00A - R0022 - Home Base - (89.29 SQM) - Teaching Space: 1	Student Space (41)	
B00A - R0023 - Home Base - (89.29 SQM) - Teaching Space: 1	Student Space (41)	
B00A - R0024 - Practical Activities - 1hb - (9.93 SQM)	Student Space (4)	
B00A - R0027 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (54.08 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1002 - Practical Activities - 1hb - (19.85 SQM)	Student Space (9)	
B00A - R1004 - Home Base - (64.69 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1005 - Home Base - (65.21 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1006 - Practical Activities - 1hb - (9.48 SQM)	Student Space (4)	
B00A - R1007 - Practical Activities - 1hb - (9.48 SQM)	Student Space (4)	
B00A - R1008 - Home Base - (65.21 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1009 - Movement - (6.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Movement - (56.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Movement - (105.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Home Base - (75.08 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R1013 - Home Base - (64.85 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1014 - Practical Activities - 1hb - (9.79 SQM)	Student Space (4)	
B00A - R1015 - Practical Activities - 1hb - (9.66 SQM)	Student Space (4)	
B00A - R1016 - Home Base - (63.2 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1017 - Home Base - (64.85 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0002 - Movement - (15.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Interview - (16.99 SQM)	Office (4)	
B00B - R0009 - Sick Bay - (15.84 SQM)	Student Space (7)	
B00B - R0010 - Duplicating Workroom - (17.44 SQM)	Office (4)	
B00B - R0013 - Entry Vestibule - (14.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Clerical Office - (15.95 SQM)	Office (3)	
B00B - R0015 - Principal - (17.05 SQM)	Office (4)	
B00B - R0020 - Staff Room Annexe - (15.12 SQM)	Office (3)	
B00B - R0021 - Staff Room Annexe - (15.12 SQM)	Office (3)	
B00B - R0022 - Reading Area - (230.78 SQM)	Student Space (107)	
B00B - R0025 - Movement - (6.21 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Staff Room - (56.69 SQM)	Office (14)	
B00B - R0034 - Movement - (40.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Staff Room Annexe - (20.21 SQM)	Office (5)	
B00B - R0036 - Staff Kitchen - (19.56 SQM)	Office (4)	
B00C - R0001 - Home Base - (55.24 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0002 - Practical Activities - 1hb - (18.76 SQM)	Student Space (8)	
B00C - R0003 - Practical Activities - 1hb - (18.76 SQM)	Student Space (8)	
B00C - R0004 - Home Base - (55.24 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0008 - Canteen - (47.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (79.81 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0001 - Home Base - (55.25 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0002 - Practical Activities - 1hb - (18.71 SQM)	● Student Space (8)	
B00D - R0003 - Practical Activities - 1hb - (18.71 SQM)	● Student Space (8)	
B00D - R0004 - Home Base - (55.25 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0007 - Practical Activities - 1hb - (18.72 SQM)	● Student Space (8)	
B00D - R0008 - Home Base - (55.25 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0009 - Home Base - (55.25 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0010 - Practical Activities - 1hb - (18.71 SQM)	● Student Space (8)	
B00D - R0014 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Home Base - (54.68 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1002 - Practical Activities - 1hb - (19.68 SQM)	● Student Space (9)	
B00D - R1003 - Home Base - (54.68 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1004 - Practical Activities - 1hb - (19.84 SQM)	● Student Space (9)	
B00D - R1005 - Practical Activities - 1hb - (18.89 SQM)	● Student Space (8)	
B00D - R1006 - Home Base - (54.68 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1007 - Home Base - (54.69 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1008 - Practical Activities - 1hb - (18.9 SQM)	● Student Space (8)	
B00D - R1009 - Movement - (54.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R1010 - Movement - (6.05 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Communal Space - (144.84 SQM)	● Student Space (67)	
B00H - R0002 - Raised Platform - (60.47 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (7.58 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (12.7 SQM)	Not Applicable	Circulation or storage space.