


VENTILATION AUDIT REPORT

| | |
|-------------------------------|-----------------------------------|
| SCHOOL: | Gulgong High School (8546) |
| AMU REGION: | North Western NSW |
| STATE ELECTORATE: | Dubbo |
| LOCAL GOVERNMENT AREA: | Mid-Western |

8546 - Gulgong High School
Site Plan (12993)



Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00A - M1002 - Computer Learning Space - (55.85 SQM) - Teaching Space: 1 | ● Student Space (25) | |
| B00A - M1005 - Movement - (6.53 SQM) | Not Applicable | Circulation or storage space. |
| B00A - M1006 - Senior Study - (41.62 SQM) | ● Office (10) | |
| B00A - R0001 - Deputy Principal Office - (19.03 SQM) | ● Office (4) | |
| B00A - R0002 - Interview/Office - Type 1 - (11.97 SQM) | ● Office (2) | |
| B00A - R0003 - Principal Office - (22.52 SQM) | ● Office (5) | |
| B00A - R0004 - Commonroom - (75.83 SQM) | ● Office (18) | |
| B00A - R0011 - Seminar - (12.44 SQM) | ● Office (3) | |
| B00A - R0012 - Seminar - (12.44 SQM) | ● Office (3) | |
| B00A - R0013 - Staff Study - (12.47 SQM) | ● Office (3) | |
| B00A - R0014 - Clinic - Girls - (12.98 SQM) | ● Office (3) | |
| B00A - R0018 - Administration - Clerical - (12.84 SQM) | ● Office (3) | |
| B00A - R0023 - Movement - (80.02 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0026 - Administration - Clerical - (29.37 SQM) | ● Office (7) | |
| B00A - R1001 - Movement - (69.83 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1002 - Main Area - (187.92 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1003 - Seminar - (12.69 SQM) | ● Office (3) | |
| B00A - R1004 - Audio Visual Workroom - (15.43 SQM) | ● Student Space (7) | |
| B00A - R1006 - Workroom - (18.1 SQM) | ● Office (4) | |
| B00B - R0006 - Student Canteen - (41.11 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0007 - Movement - (22.61 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0009 - Stage - (24.21 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0011 - Multi-Purpose Space - (179.29 SQM) | ● Student Space (83) | |
| B00B - R0015 - Movement - (57.04 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0005 - Music Learning Space - (62.62 SQM) - Teaching Space: 1 | ● Student Space (29) | |
| B00C - R0006 - Music Learning Space - (65.06 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B00D - R0001 - Darkroom Space - (7.93 SQM) | ● Office (1) | |
| B00D - R0004 - Preparation - (44.39 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0008 - General Learning Space - Type 10 - (37.51 SQM) - Teaching Space: 0.5 | ● Student Space (17) | |
| B00D - R0009 - Science Laboratory - (53.56 SQM) | ● Student Space (24) | |
| B00D - R0010 - General Learning Space - Type 10 - (53.19 SQM) - Teaching Space: 0.5 | ● Student Space (24) | |
| B00D - R0011 - Science Laboratory - (38.05 SQM) | ● Student Space (17) | |
| B00E - R0013 - General Learning Space - (34.3 SQM) - Teaching Space: 1 | ● Student Space (15) | |
| B00E - R0016 - Kitchen - Type 1 - (109.08 SQM) | ● Student Space (50) | |
| B00E - R0019 - Preparation - Materials - (10.39 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0020 - Preparation - Materials - (17.42 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0004 - General Learning Space - (63.51 SQM) - Teaching Space: 1 | ● Student Space (29) | |
| B00F - R0005 - General Learning Space - (63.97 SQM) - Teaching Space: 1 | ● Student Space (29) | |
| B00G - R0010 - Materials Technology L.S. - (127.26 SQM) - Teaching Space: 1 | ● Student Space (59) | |
| B00G - R0011 - Outdoor Workshop - (96.19 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0001 - Art Learning Space - (64.51 SQM) - Teaching Space: 1 | ● Student Space (29) | |
| B00H - R0002 - Workshop - (54.18 SQM) | ● Student Space (25) | |
| B00H - R0004 - Design L.S. - (64.42 SQM) - Teaching Space: 1 | ● Student Space (29) | |
| B00J - R0001 - General Learning Space - (47.75 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00J - R0002 - General Learning Space - (63.98 SQM) - Teaching Space: 1 | ● Student Space (29) | |
| B00J - R0004 - Staff Study - (68.54 SQM) | ● Office (17) | |
| B00K - R0006 - Staff Study - (46.34 SQM) | ● Office (11) | |
| B00L - R0001 - General Learning Space - (37.42 SQM) - Teaching Space: 1 | ● Student Space (17) | |
| B00L - R0002 - Materials Workshop - Type 2 - (157.27 SQM) | ● Student Space (72) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00L - R0003 - Welding Area - (10.39 SQM) | Not Applicable | Circulation or storage space. |
| B00L - R0004 - Outdoor Workshop - (81.15 SQM) | Not Applicable | Circulation or storage space. |
| B00M - R0002 - General Assistants - (47.39 SQM) | Office (11) | |
| B00N - R0001 - General Learning Space - (64.9 SQM) - Teaching Space: 1 | Student Space (30) | |
| B00N - R0002 - General Learning Space - (65.06 SQM) - Teaching Space: 1 | Student Space (30) | |
| B00N - R0003 - Practice/Seminar - (20.46 SQM) | Not Applicable | Circulation or storage space. |
| B00N - R0005 - Music Learning Space - (102.22 SQM) - Teaching Space: 1 | Student Space (47) | |
| B00O - R0002 - Special Learning Space - (58.53 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00O - R0003 - General Learning Space - (61.74 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00O - R0004 - General Learning Space - (61.58 SQM) - Teaching Space: 1 | Student Space (28) | |
| BOGY - R0001 - Gymnasium - (688.19 SQM) | Student Space (319) | |
| BOGY - R0007 - Movement - (17.33 SQM) | Not Applicable | Circulation or storage space. |
| BOGY - R0010 - Staff Study - (18.65 SQM) | Office (4) | |
| OS 601 12263 - OS 601 12263 - Learning Unit - Standard/Withdrawal - (76 SQM) | Student Space (35) | |
| OS 601 19482 - OS 601 19482 - Learning Unit - Standard/Withdrawal - (76 SQM) | Student Space (35) | |
| OS 606 19077 - OS 606 19077 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | Student Space (35) | |
| OS 606 19077 - OS 606 19077 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | Student Space (35) | |
| OS 606 19077 - OS 606 19077 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | Student Space (35) | |
| OS 606 19077 - OS 606 19077 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | Student Space (35) | |