

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Gulmarrad Public School (2099)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Clarence</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Clarence Valley</b>

2099 - Gulmarrad Public School  
Site Plan (12696)



1:854

Printed: 20-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0008 - Canteen - (16.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (30.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Clerical Office - (11.03 SQM)	Office (2)	
B00A - R0012 - Clerical Office/Workroom - (17.5 SQM)	Office (4)	
B00A - R0013 - Entry Vestibule - (12.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Sick Bay - (8.83 SQM)	Student Space (4)	
B00A - R0016 - Staff Room - (38.53 SQM)	Office (9)	
B00A - R0018 - Interview - (13.32 SQM)	Office (3)	
B00A - R0019 - Principal - (12.84 SQM)	Office (3)	
B00A - R0020 - Movement - (6.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (54.01 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0002 - Practical Activities - 1hb - (7.67 SQM)	Student Space (3)	
B00B - R0004 - Movement - (5.37 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (13.39 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (55.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (13.91 SQM)	Student Space (6)	
B00F - R0003 - Home Base - (59.19 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0005 - Outdoor Learning Area - (14.56 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Withdrawal Space - 1hb - (12.38 SQM)	Student Space (5)	
B00F - R0007 - Home Base - (59.32 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0008 - Practical Activities - 1hb - (13.94 SQM)	Student Space (6)	
B00F - R0010 - Outdoor Learning Area - (14.6 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Special Programs Room - (28.47 SQM)	Student Space (13)	
B00H - R0018 - Practical Activities - 3hb - (47.36 SQM)	Student Space (21)	
B00H - R0020 - Special Programs Room - (21.98 SQM)	Student Space (10)	
B00I - R0001 - Withdrawal Space - 1hb - (8.82 SQM)	Student Space (4)	
B00I - R0003 - Withdrawal Space - 1hb - (6.48 SQM)	Student Space (3)	
B00I - R0004 - Home Base - (50.52 SQM) - Teaching Space: 1	Student Space (23)	
B00I - R0005 - Practical Activities - 1hb - (25.23 SQM)	Student Space (11)	
B00I - R0006 - Reading Area - (82.08 SQM)	Student Space (38)	
B00I - R0013 - Movement - (33.08 SQM)	Not Applicable	Circulation or storage space.
B00I - R0014 - Movement - (26.47 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Movement - (17.86 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Communal Space - (147.63 SQM)	Student Space (68)	
B00L - R0002 - Raised Platform - (56.84 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Movement - (8.25 SQM)	Not Applicable	Circulation or storage space.
B00L - R0017 - Movement - (11.91 SQM)	Not Applicable	Circulation or storage space.
OS 601 12831 - OS 601 12831 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 15257 - OS 601 15257 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 602 16286 - OS 602 16286 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 10878 - OS 603 10878 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	